

DOCUMENT RESUME

ED 438 699

EF 005 658

TITLE Wake County Public School System Design Guidelines.  
INSTITUTION Wake County Public School System, Raleigh, NC.  
PUB DATE 1999-03-00  
NOTE 201p.  
AVAILABLE FROM For full text: [http://www.wcpss.net/Auxiliary/Facilities/design\\_guidelines.html](http://www.wcpss.net/Auxiliary/Facilities/design_guidelines.html).  
PUB TYPE Guides - Non-Classroom (055) -- Legal/Legislative/Regulatory Materials (090)  
EDRS PRICE MF01/PC09 Plus Postage.  
DESCRIPTORS Educational Environment; \*Educational Facilities Design; \*Educational Facilities Planning; Elementary Secondary Education; \*Facility Guidelines; \*Public Schools; \*School Construction; Site Development; \*Specifications  
IDENTIFIERS \*Wake County Public School System NC

ABSTRACT

The Wake County Public School System has published its guidelines for planning and design of functional, cost effective, and durable educational facilities that are attractive and enhance the students' educational experience. The guidelines present basic planning requirement and design criteria for the entire construction process, including: codes and standards; site development; construction materials; thermal and moisture protection; doors and windows; finishes; equipment and furnishings; plumbing; electrical and mechanical systems; and specialty areas such as toilet facilities, lockers, fire extinguishers and cabinets, and operable partitions. Attachments cover detailed installation and construction specifications for such items as wiring, landscaping, fencing, stage equipment, cable installation, and laminate casework. (GR)

Reproductions supplied by EDRS are the best that can be made  
from the original document.

# WAKE COUNTY PUBLIC SCHOOL SYSTEM DESIGN GUIDELINES

*March, 1999*

U.S. DEPARTMENT OF EDUCATION  
Office of Educational Research and Improvement  
EDUCATIONAL RESOURCES INFORMATION  
CENTER (ERIC)

This document has been reproduced as received from the person or organization originating it.

Minor changes have been made to improve reproduction quality.

Points of view or opinions stated in this document do not necessarily represent official OERI position or policy.

PERMISSION TO REPRODUCE AND  
DISSEMINATE THIS MATERIAL HAS  
BEEN GRANTED BY

Christina Lighthall

TO THE EDUCATIONAL RESOURCES  
INFORMATION CENTER (ERIC)

1

Available at:  
[http://www.wcpss.net/Auxiliary/Facilities/  
design\\_guidelines.html](http://www.wcpss.net/Auxiliary/Facilities/design_guidelines.html)

DEFINITIONS AND ABBREVIATIONS - 01000 -1

## INTRODUCTION

1 These Guidelines have been developed to assist the Architect-Engineer in the planning and  
2 design of functional, cost effective and durable educational facilities that are attractive and  
3 enhance the educational experience for their students. Designers are encouraged to develop  
4 the attractiveness in a straightforward manner by utilizing standard building materials and  
5 details with a minimum of ornamentation and special treatments. Highest priority should be  
6 placed on the development of the interior learning environment with full attention given to  
7 the development of appropriate casework, outlets, lighting, etc.

The Guidelines incorporate experiences and lessons learned from past building improvement programs and have been organized in accordance with CSI's format. They are not intended to limit or control opportunities for innovative design but rather to assist the Designers in understanding certain planning requirements, design criteria, and concern regarding reduction of energy consumption. Nevertheless, whenever the design of facilities varies from the requirements and considerations of the Guidelines, the Designer shall obtain prior approval in writing from the Owner.

Please note that separate Educational Specifications and Building Programs listing detailed space and equipment requirements will be issued for each building project. In event of any conflict between the two, the Education Specifications shall supersede the requirements of the Guidelines.

These Guidelines should be of great benefit to Designers as well as the Owner. The entire design and construction process will be strengthened and less complicated if all concerned utilize the Guidelines at each phase of project design and approval. As the Guidelines will continue to evolve through the Owner's experience and desire to improve projects, your comments and recommendations are invited for future revisions.

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
**DESIGN GUIDELINES**  
March, 1999

**ACKNOWLEDGMENTS**

These Guidelines have been prepared and revised by the Wake County Public School System Department of Facilities Planning and Construction under the direction of Ray Massey, Jr., Associate Superintendent for Auxiliary Services and Christina Lighthall, Senior Director of Facilities Planning and Construction.

Acknowledgement is made to the various staff members of the Wake County Public School System and to several outside design and technical consultants who reviewed various drafts of the document. The advice and help of all of these sources is greatly appreciated.

Particular thanks are also extended to the staff and consultants of WCPSS who met several times to review each draft copy of the guide in its formative stages and made many valuable contributions.

1

**TABLE OF CONTENTS**

Introduction  
Acknowledgements  
Table of Contents

**DIVISION 1 - GENERAL NOTES**

01000 Definitions and Abbreviations  
01010 Codes and Standards  
01020 Asbestos Note  
01030 Energy Conservation  
01040 Drawing, Specification and Bid Alternate Requirements  
01050 Warranties and Maintenance Agreements  
01060 Project Close-Out

**DIVISION 2 - SITE WORK**

02001 Site Development Design Considerations  
02050 Demolition  
02270 Slope Protection and Erosion Control  
02280 Termite Control  
02510 Walkway, Road and Parking Paving  
02530 Athletic Paving and Surface  
02605 Manholes  
02610 Storm Drainage Pipe and Fittings  
02830 Fencing  
02900 Grass Seeding  
02910 Landscape Planting

**DIVISION 3 - CONCRETE**

03300 Cast-in-Place Concrete

**DIVISION 4 - MASONRY**

04200 Masonry

**DIVISION 5 - METALS**

05500 Metal Fabrications

**DIVISION 6 - WOOD AND PLASTICS**

06100 Rough Carpentry  
06200 Finish Carpentry  
06410 Interior Architectural Woodwork

**DIVISION 7 - THERMAL AND MOISTURE PROTECTION**

07000 Thermal and Moisture Protection Design Considerations  
07100 Waterproofing  
07310 Asphalt Shingle Roofing  
07420 Sheet Metal Roofing  
07500 Membrane Roofing  
07600 Flashing and Sheet Metal

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
**DESIGN GUIDELINES**  
March, 1999

**DIVISION 8 - DOORS AND WINDOWS**

08100	Hollow Metal Doors and Frames
08200	Wood Doors
08300	Special Doors
08400	Aluminum Entrances
08500	Metal Windows
08710	Finish Hardware
08800	Glazing

**DIVISION 9 - FINISHES**

09200	Gypsum Plaster
09250	Gypsum Wallboard
09300	Tile Work
09510	Acoustical Panel Ceilings
09550	Wood Flooring
09650	Resilient Flooring
09680	Carpet
09720	Wallcovering
09900	Painting

**DIVISION 10 - SPECIALTIES**

10110	Dry Erase Boards and Tackboards
10155	Toilet Partitions
10426	Identifying Devices
10500	Lockers
10520	Fire Extinguishers and Cabinets
10650	Operable Partitions
10700	Window Treatments, Stage Curtains and Banners
10800	Toilet Accessories

**DIVISION 11 - EQUIPMENT**

11000	Miscellaneous Equipment
11400	Food Service Equipment
11480	Athletic Equipment
11600	Laboratory Equipment and Casework
11970	Stage Equipment

1

**DIVISION 12 - FURNISHINGS**

12304	Laminate Clad Casework
-------	------------------------

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
**DESIGN GUIDELINES**  
6 May 1992

**DIVISION 15 - PLUMBING**

15000	General Plumbing & Mechanical Requirements
15050	Plumbing System, General
15100	Plumbing Valves
15110	Potable Water and Fire Water Systems
15120	Sewage Disposal
15125	Irrigation System
15131	Kitchen Plumbing
15140	Plumbing Supports and Anchors
15190	Plumbing Identification
15250	Plumbing Insulation
15411	Domestic Water Piping
15420	Drainage and Vent Systems
15440	Plumbing Fixtures
15488	Natural Gas Systems

**DIVISION 15 - MECHANICAL**

15500	Heating, Ventilating and Air Conditioning, General
15550	HVAC Piping Systems
15760	Cooling Towers
15855	Air Handling Units and Fan Coil Units
15860	Ductwork
15865	Diffusers and Grilles
15900	Building Automation and Control Systems (BAS)

**DIVISION 16 - ELECTRICAL**

16000	Electrical Work
16110	Conduit
16120	Wires and Cables
16142	Electrical Connections to Equipment
16143	Wiring Devices
16420	Service Entrance
16470	Panelboards
16515	Lighting
16721	Fire Alarm Systems
16740	Telephone/Data Systems
16770	Intercom/Public Address Systems
16780	MATV System
16900	Security Systems

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
**DESIGN GUIDELINES**  
March, 1999

**ATTACHMENTS**

01020-A	Asbestos Notice to Contractors, Subcontractors & Short-Term Workers
01020-B	Asbestos Contractor Certification Form
02510-A	Triassic Boundary Map for Western Wake County
02830-A	Chain Link Fencing Specification
02910-A	Preferred Tree, Shrub and Ground Cover Plant List
06410-A	Millwork/Casework Planning Data
10110-A	Dry Erase Board & Tackboard
11970-A	Stage Equipment Guide Specifications for Elementary Schools
11970-B	Stage Equipment Guide Specifications for Middle Schools
11970-C	Stage Equipment Guide Specifications for High Schools
12304-A	Laminate Casework Features
15900-A	Building Level Direct Digital Control System Specification
16142-A	Standard Electrical Connections to Equipment
16142-B	Standard Pulse Relay Conduit Detail
16470-A	Panelboard Working Space Requirements
16515-A	Standard Two-Level Lighting Detail
16515-B	Lighting Level Table
16740-1A	Cable Schedule
16740-1B	Cable Schedule Con't
16740-2	Hub Cabinet Detail
16740-3A	Description of Phone/Data System Labeling
16740-3B	Typical Labeling - Hub Cabinet with Copper outlets
16740-3C	Typical Labeling - IDF with Copper Outlets
16740-3D	Typical Labeling - Hub Cabinet Feeds and Fiber Outlets
16740-3E	Typical MDF or IDF Rack Elevation
16780-A	Standard Cable TV Diagram

1  
2 **SECTION 01000 - DEFINITIONS AND ABBREVIATIONS**

3  
4 **DEFINITIONS**

5 Throughout this guide, mandated requirements are differentiated from recommendations or  
6 commentary as follows:

7  
8 Mandates: Indicated by use of “**shall**”, “**will**”, “**use**”, or “**shall not**”, “**do not**” (in bold  
9 type)

10  
11 Recommendations or commentary: Indicated by words or phrases such as “should”, “may”,  
12 “it is recommended” and the like. Any such words or phrases indicate an option that is to be  
13 decided by the Designer.

14  
15 **ABBREVIATIONS**

16 Owner: Wake County Public School System

17  
18 WCPSS: Wake County Public School System

19  
20 Designer: Design professional registered to practice in North Carolina. This **shall** be an  
21 architect for the design of all-new structures, additions, and renovations or alterations to  
22 existing structures. The scope of the architect’s services **shall** include the services of  
23 professional engineers to design the structural, plumbing, mechanical and electrical portion of  
24 the project. The services of the architect may be deleted and comparable services of an  
25 engineer or landscape architect may be substituted in lieu of where a project is almost entirely  
26 with the design realm of such professionals.

27  
28 ADA: The American’s with Disabilities Act

29 AHERA: Asbestos Hazard Emergency Response Act of 1987

30 ASHRAE: American Society Heating, Refrigeration, and Air Conditioning Engineers

31 ASTM: American Society for Testing Materials

32 BOCA: Building Officials and Code Administrators International

33 HVAC: Heating, Ventilation and Air Conditioning

34 ICBO: International Conference of Building Officials

35 NCSBC and/or State Building Code: North Carolina State Building Code including the  
36 General, Mechanical, Electrical, Handicap and Gas Volumes.

37 NEMA: National Electrical Manufacturer’s Association

38 NFPA: National Fire Protection Association

39 NRCA: National Roofing Contractors Association

40 OSHA: U.S. Occupational Safety and Health Administration

41 SBCCI: Southern Building Code Congress International

42 SMACNA: Sheet Metal and Air Conditioning Contractors National Association, Inc.

43 UL: United Laboratories, Inc.  
44

45 **END OF SECTION**

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
March, 1999

1  
2 **SECTION 01010 - CODES AND STANDARDS**  
3

- 4  Project design and construction **shall** meet all governing codes, standards and regulations.  
5 These codes and standards **shall** supersede the WCPSS Design Guidelines in event of a  
6 conflict. Among the codes and standards to be complied with are the following:  
7

8 North Carolina State Building Code including the General, Mechanical, Electrical,  
9 Handicap and Gas Volumes.

10  
11 ADA Requirements

12  
13 NEMA Standards

14  
15 ASHRAE Guide (latest edition) including ASHRAE 90 and ASHRAE Standard for  
16 Energy Conservation in new buildings. UL Standards (or compatible accepted  
17 standards by NCSBC)

18  
19 NFPA Guide including the following:

20  
21 NFPA 17 Range Hood Fire Extinguishing Equipment

22 NFPA 31 Oil Burning Equipment

23 NFPA 72A Local Protection Signaling Systems

24 NFPA 90A Ducts, Fire Dampers, Air Conditioning and Ventilation

25 Systems

26 NFPA 91 Blower and Exhaust Systems

27 NFPA 96 Removal of Smoke and Grease-Laden Vapors from

28 Commercial Cooking Equipment

29 NFPA 101 Life Safety Code

30  
31 Code for Energy Conservation in new building construction (Jointly prepared by  
32 BOCA, ICBO, and SBCCI Codes)

33  
34 Local Zoning Ordinances

35  
36 WCPSS Project Educational Specifications

37  
38 **END OF SECTION**

1  
2 **SECTION 01020 - ASBESTOS NOTE**  
3

- 4  No asbestos containing building materials **shall** be used in the construction of the project.  
5 The design consultant **will** be required to submit a signed statement that “no asbestos  
6 containing building material was specified as a building material in any construction  
7 document for the project, or to the best of the consultant’s knowledge, was used in the  
8 building.  
9
- 10  If any materials suspected to contain asbestos are encountered in addition or renovation  
11 work, the Owner’s “AHERA DESIGNEE” **shall** be immediately contacted to arrange an  
12 investigation and testing of these materials. The Owner **shall** supervise the removal of  
13 any asbestos containing material by an independent contractor hired and paid by the  
14 Owner. A statement to this effect **shall** be included in the General Requirements of the  
15 project specifications.  
16
- 17  All projects occurring on existing campuses are required to include in specifications the  
18 notice to contractors, subcontractors and short-term workers regarding asbestos  
19 containing building materials that may be present in the existing buildings. (See  
20 Attachment 01020-A) It **shall** also be required that all contractors and subcontractors  
21 return the completed certification form (included in Attachment 01020-B) prior to  
22 beginning work.  
23  
24

**END OF SECTION**

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
March, 1999

1  
2 **ATTACHMENT 01020-A**

3  
4 NOTICE TO CONTRACTORS, SUBCONTRACTORS, & SHORT-TERM WORKERS

5  
6 RE: ASBESTOS-CONTAINING BUILDING MATERIALS IN SCHOOLS/FACILITIES


7  
8 DATE: November 29, 1994

9  
10 This notice is to advise you that asbestos-containing building materials must not be disturbed  
11 if encountered during repairs, renovations, and other construction and installation activities  
12 in buildings owned by the Wake County Public School System. A management plan manual is  
13 located in the main office of each facility which specifies the location(s), if any, of asbestos-  
14 containing building materials. Copies of the manuals are also available for reference in  
15 Raleigh at the school system's Operations Department at 1551 Rock Quarry Road and the  
16 Department of Environmental Management (Facilities Building) 1551 Rock Quarry Road.  
17 Contractors shall review the appropriate manual prior to beginning any construction activity  
18 in order to determine if that activity has the potential for disturbing asbestos-containing  
19 building material.

20  
21 If disturbance of these materials cannot be reasonably avoided, no work shall begin until the  
22 AHERA Designee of the Wake County Public School System has been notified and has issued  
23 specific instructions on the proper procedures for the activity in accordance with federal,  
24 state and local regulation. The attached **Contractor Certification Form** must be signed  
25 and returned to the AHERA Designee prior to the start of work.

26  
27 Contractors, subcontractors, and short-term workers shall also be responsible for determining,  
28 prior to the start of work, the location(s) of any areas of restricted or prohibited access on  
29 the site where the work is to be performed. **Such areas shall not be entered, for any**  
30 **reason, without prior authorization of the AHERA Designee.** The Wake County  
31 Public School System will not be responsible for claims of any kind from contractors,  
32 subcontractors or short-term workers who fail to comply with provisions of this notice.

33  
34 Sincerely,



35  
36 Frank Koontz, AHERA Designee  
37 Wake County Public School System  
38 Environmental Management  
39 1551 Rock Quarry Road, Facilities Building  
40 Raleigh, North Carolina 27610  
41 Phone (919) 856-8286

1  
2 **ATTACHMENT 01020-B**

3  
4 **CONTRACTOR CERTIFICATION FORM**  
5 Wake County Public School System – Environmental Management  
6

7 The undersigned certify that they have received and read the “Notice to Contractors,  
8 Subcontractors and Short-Term Workers” issued by the Wake County Public School System  
9 regarding asbestos-containing building materials that may be present in school buildings.  
10

11 The Undersigned further certify the following:

- 12
- 13 • That they have informed their workers and/or subcontractors of this notice and the proper procedures to
- 14 follow
- 15
- 16 • That they will contact the AHERA Designee for the Wake County Public School System to determine
- 17 if there are restricted access areas at the facility where work is planned and, if there are such areas, that
- 18 they will notify their workers and subcontractors accordingly
- 19
- 20 • That they will be responsible for proper notification of these conditions to all subcontractors and for
- 21 obtaining the signature(s) of the authorized representatives of those subcontractors in the spaces
- 22 provided below
- 23
- 24 • That this form will be properly completed, signed, and returned to the AHERA Designee for the Wake
- 25 County Public School System prior to the start of work
- 26

27 **Project/School/Facility:** \_\_\_\_\_

28  
29 **Project Number:** \_\_\_\_\_

30  
31 Prime Contractor: \_\_\_\_\_  
32 President/Manager/Owner \_\_\_\_\_ Date: \_\_\_\_\_

33  
34 Subcontractor: \_\_\_\_\_  
35 President/Manager/Owner \_\_\_\_\_ Date: \_\_\_\_\_

36  
37 Subcontractor: \_\_\_\_\_  
38 President/Manager/Owner \_\_\_\_\_ Date: \_\_\_\_\_

39  
40 Subcontractor: \_\_\_\_\_  
41 President/Manager/Owner \_\_\_\_\_ Date: \_\_\_\_\_

42  
43 Subcontractor: \_\_\_\_\_  
44 President/Manager/Owner \_\_\_\_\_ Date: \_\_\_\_\_

45  
46 Subcontractor: \_\_\_\_\_  
47 President/Manager/Owner \_\_\_\_\_ Date: \_\_\_\_\_

48  
49 **Remit To:** Frank Koontz, AHERA Designee  
50 Wake County Public School System  
51 Environmental Management/Facilities Building  
52 1551 Rock Quarry Road  
53 Raleigh, NC 27610



1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33

**SECTION 01030 - ENERGY CONSERVATION**

**ENERGY CONSERVATION**

- The requirements of ASHRAE Standard "Energy Conservation in New Building Design" and Volume X of the North Carolina State Building Code **shall** be complied with in the design of all new and renovated facilities, except that the following considerations **shall** take precedence over the ASHRAE standard and Volume X:
  1. The roof/ceiling "U" factor **shall not** exceed .05.
  2. Wall "U" factor **shall not** exceed .10.
  3. Exceptions may be made for these two (2) items noted above on special designs where  
the roof structure is utilized for solar collection or natural lighting.
- The Design Team **shall** make every effort to provide a system design with maximum utilization of energy conservation measures, consistent with functional requirements of the building. Close coordination between the Mechanical Engineer, Electrical Engineer and Architect in the interest of energy conservation **shall** be required.
- The following design items **shall** be performed by or complied with by the Design Teams for all work, both new and renovation.
  1. Review building insulation strategies with Energy Management department of WCPSS during design development phase. Insulation levels **shall** be maximized to enhance long term benefits and comfort. Considerable care **shall** be taken to minimize infiltration in building shell. Major areas of concern are windows, ceiling/roof assemblies and entry areas.
  2. Natural day lighting **shall** be thoroughly examined and it is strongly recommended that it be utilized in all appropriate spaces.
  3. Specify water savings features on all water consuming devices such as water closets, etc.
- Other guidelines related to energy conservation are found in specific sections of this document.

**END OF SECTION**



1  
2 **SECTION 01050 - WARRANTIES AND MAINTENANCE AGREEMENTS**  
3

4 **WARRANTIES**

- 5  All work **shall** be fully warranted for one year from the date of substantial completion by  
6 the contractor who **shall** replace any defective materials and repair any defective  
7 workmanship. In addition, written warranties **shall** be provided for the following  
8 products and time periods. These warranties **shall** include any material and labor cost to  
9 repair defective materials and correct defective workmanship.

10  
11 **5 YEAR WARRANTY**

- 12 Soil Termiticide Treatment  
13 Wood Doors  
14 HVAC Compressors including Refrigeration  
15

16 **10 YEAR WARRANTY**

- 17 Glass and Glazing Materials  
18

19 **20 YEAR WARRANTY**

- 20 Sheet Metal Roofing (this **shall** include finish cracking, peeling or color fading)  
21

22 **20 YEAR NO DOLLAR LIMIT "SYSTEM" WARRANTY**

- 23 Single Ply Membrane Roofing  
24 Modified Bitumen Roofing  
25

26 **30 YEAR WARRANTY**

- 27 Asphalt Shingle Roofing  
28

29 **END OF SECTION**

1  
2 **SECTION 01060 - PROJECT CLOSE-OUT**

3  
4 **OPERATION AND MAINTENANCE MANUALS**

5  The Contractors shall deliver four complete sets of all operation and maintenance  
6 manuals to the Owner through the Designer, two (2) weeks before the pre-final  
7 inspection is held. The manuals **shall** be installed in 3 ring notebooks with the name of  
8 the project and the words "Operation and Maintenance" manuals on the cover and spine.  
9 The manuals **shall** contain the following items as a minimum:

- 10  
11       • Index and page numbers.  
12  
13       • Complete start-up, operation, and shutdown procedures for each system including  
14 sequence of events, locations of switches, emergency procedures and any other  
15 critical items.  
16  
17       • Lubrication schedules and types of lubricates.  
18  
19       • Complete set of current shop drawings and equipment description showing all  
20 capacities and other operation conditions.

21  
22  See Section 15000 for additional requirements.  
23

24 **FINAL INSPECTIONS**

25  Each project **shall** have both a pre-final and final inspection made before it is finally  
26 accepted by the Owner. A complete and thorough training **shall** be conducted by the  
27 design consultant(s), contractors and subcontractors for the WCPSS Maintenance  
28 Department after the pre-final inspection.

29  The pre-final inspection **shall** be held after all systems are in place and in operation. All  
30 contractors **shall** demonstrate to the Designer that all systems in the building are  
31 properly installed, balanced, and performing as designed and specified. All Contractors  
32 and Subcontractors **shall** attend this inspection including the HVAC air and water balance  
33 subcontractor.

34  The final inspection **shall** be held with the Owner, Designer, all Contractors and  
35 Subcontractors to demonstrate to the Owner that all systems in the building are operating  
36 as designed and to their satisfaction. The final HVAC inspection results **shall** be certified  
37 by design professionals.  
38

39 **POST INSPECTIONS**

40  Two post construction inspections **shall** be held by the Designer with the Contractors  
41 and Owner to assure that the building is continuing to operate in accordance with the  
42 plans and specifications and that no unusual problems are occurring in the building  
43 systems. The first post construction inspection **will** be held approximately six months  
44 after substantial completion. This inspection **will** address Plumbing, HVAC and electrical  
45 work. The second post construction inspection **shall** be held prior to expiration of the 1  
46 year warranty period. It **shall** address general construction as well as plumbing, HVAC  
47 and electrical work. All problems discovered during these inspections that relate to  
48 defective materials or defective workmanship **shall** be corrected by the Contractor at no  
49 additional cost to the Owner.

50 **RECORD DRAWINGS (AS-BUILTS)**

51  The Designer **shall** specify that during construction operations the Contractor **shall**  
52 faithfully record all changes from the contract drawings, including accurate dimensions

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
**DESIGN GUIDELINES**  
March, 1999

1 where applicable including invert elevations for all below-grade outside utilities with  
2 reference to permanent above-grade objects.

- 3  The Designer **shall** also specify that at completion of the work all such changes **shall** be  
4 recorded neatly with red ink by the contractor on an unused set of the contract drawing  
5 prints supplied by the Designer. The red line changes **shall** be reviewed by the Designer  
6 who **shall** modify all contract drawings to reflect and incorporate all field changes.  
7  The resulting Record Drawings **shall** be turned over to the Owner in hard copy Mylar  
8 form and on CD in AutoCAD format. In addition, the Designer **shall** provide the Owner  
9 with a half-size set of Record Drawings on either bond or blueprint paper.

10  
11 **SCHOOL SITE STORAGE OF DRAWINGS AND MANUALS**

- 12  The Design **shall** provide space in either the main HVAC equipment room or electrical  
13 equipment room for a 36" wide x 18" x 72" high metal storage cabinet supplied by the  
14 Owner. This will be used to store the school's copy of record drawings, project  
15 specifications and operation and maintenance manuals.

16  
17 **SUBSTANTIAL COMPLETION**

- 18  Substantial Completion is the date that the Owner and Designer determine the project is  
19 complete enough for the Owner to achieve beneficial occupancy. It is also the date that  
20 begins the warranty periods. Please refer to the General Conditions Section of the  
21 Specifications, which will be furnished by the Owner for detailed listing of Substantial  
22 Completion requirements.

23  
24 **FINAL COMPLETION**

- 25  Please refer to the General Conditions Section of the Specifications for a detailed listing  
26 of documentation, certification and submittals required for Final Completion and Final  
27 Payment.

28  
29 **END OF SECTION**

1  
2 SECTION 02001 - SITE DEVELOPMENT DESIGN CONSIDERATIONS  
3

4 GENERAL

- 5  There are various issues, which need to be addressed in the site design of a school. These  
6 considerations include:  
7 1) the allowance for future building expansion and accommodation of future re-  
8 locatable classrooms.  
9 2) the development of circulation patterns that separate pedestrian from vehicular  
10 traffic, the bus drop/parking from the parent drop off and staff parking from  
11 student parking  
12 3) main building entrances which are readily identifiable;  
13 4) building orientations and configurations which conserve energy and allow for  
14 natural day-lighting and ventilation  
15 5) the utilization of exterior terraces/patios for outdoor learning areas.  
16 6) providing handicap accessibility to all buildings and play areas as per Building  
17 Code and ADA requirements.  
18 7) the identification and preservation of natural site features such as rock  
19 outcroppings and wooded areas to be used to enhance the science program.  
20 8) minimize the building's environmental impact on the site, i.e.:  
21  run-off control (watershed issue)  
22  minimize excavation  
23  protect trees  
24  minimize grounds maintenance  
25  protect wetlands  
26  Projects within the City of Raleigh **shall** be required to comply with City of Raleigh  
27 Stormwater Management Policy.  
28

29 EXECUTION

- 30  BUILDING EXPANSION AND RE-LOCATABLE CLASSROOMS: The planning for  
31 future building expansion and re-locatable classrooms **shall** consider grading, circulation  
32 patterns and utility stub outs.  
33  BUS DROP OFF, PARENT DROP OFF AND PARKING TRAFFIC: These three  
34 functions **shall** be separated as much as possible. At all drop off areas the discharge or  
35 pick-up of students at the loading-unloading zones **shall** be from the side of the vehicle  
36 opposite the driver and towards the building.  
37  Parking bays for full-service buses **shall** be a minimum of 15 ft. wide.  
38  Backing up of buses **shall not** be permitted.  
39  A minimum turning radius of 7 ft. **shall** be provided at bus driveways and parking areas.  
40  Linear sidewalks **shall** be provided at each loading/unloading area.  
41  All primary building entrances used for students **shall** be protected from weather by  
42 overhead cover or soffit. It is recommended that each loading/unloading area have a  
43 covered canopy and covered walkway leading into the building. At larger schools it is  
44 recommended the bus drop canopy be a minimum of 12 ft. wide and 50 ft. long and  
45 walkway canopy to the building be a minimum of 8 ft. wide. Bottom of canopy soffits  
46 **shall** be a minimum of 10 ft. above finish grade at bus drops. Columns supporting  
47 canopies **shall** be set back from curbs a minimum of 4 ft. to allow car or bus doors to  
48 open. Canopies **shall** be designed to avoid roosting of birds.  
49  SERVICE DOCKS: It is recommended service docks be covered or partially covered.  
50 Dock height should be at 48 in. Use concrete and not asphalt for dock surface.

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
March, 1999

- 1  ENERGY CONSERVATION: Designers **shall** consider building orientations and  
2 configurations that minimize heat loss and facilitate beneficial solar gain during heating  
3 season, allow for natural ventilation and promote natural day-lighting of building interior.  
4 South facing window surfaces, particularly at large glazed areas, should be protected by  
5 horizontal overhangs, which maximize solar heat gain during the heating season and  
6 minimize it during the cooling season.
- 7  Also recommended is the use of deciduous trees for summer sun shading, winter sun  
8 penetration and use of conifer trees for summer sun shading and winter wind breaks.
- 9  Enclosed courtyards often present maintenance problems and should be used with great  
10 discretion. If used, provide for maintenance access and **do not** install large tree plantings.  
11 Provide hose bibbs and adequate sized storm drain structures.
- 12  RETAINING WALLS: All retaining walls with a height of 5 ft. or greater or walls  
13 subjected to surcharge loading (i.e., vehicle traffic, sloping backfill, or point loads) **shall**  
14 be designed by a professional engineer and drawings **shall** be signed and sealed  
15 accordingly.
- 16  PLAYGROUNDS: **shall** be provided as per program requirements. Playground  
17 equipment to be supplied and installed by the Contractor.
- 18  Playground equipment to be installed on a poured in place, ADA compliant, soft rubber  
19 surface, installed over a concrete pad. Size of surface **shall** be determined from  
20 equipment manufacturer's requirements. Access to playground equipment **shall** meet  
21 ADA requirements.
- 22  STORAGE BUILDING: **shall** be provided as per program requirements. Designers are  
23 encouraged to **use** finish materials and colors to match adjacent buildings.
- 24  EXTERIOR MECHANICAL AREAS: **shall** be enclosed with security fencing as noted in  
25 Section 02830. Provide reinforced concrete slab with fenced area with proper sized  
26 pads/curbs for equipment mounting. Slope slab away from building.
- 27  BOILER ROOMS: **shall** have exterior door only.
- 28  MAIN MECHANICAL EQUIPMENT ROOMS: **shall** have exterior doors where  
29 possible.
- 30  BIKE RACKS: Two (2) bike racks capable of holding 8 bikes each **shall** be supplied and  
31 installed by Contractor.

32  
33  
**END OF SECTION**

1  
2  
3  
4  
5  
6  
7  
8

**SECTION 02050 - DEMOLITION**

**EXECUTION**

- EQUIPMENT REMOVAL:** The Designer and Project Manager **shall** schedule time for Owner to remove material and equipment to be saved.

**END OF SECTION**

1  
2 **SECTION 02270 - SLOPE PROTECTION AND EROSION CONTROL**  
3

4 **EXECUTION**

- 5  GRADING: **shall** allow for storm drainage away from building, parking areas and  
6 driveways. Consider flow of concentrated storm drainage, design to slow down velocity.  
7 Concentrated drainage across walks **shall not** be allowed, **nor will** ponding be allowed.  
8 Discharge from canopies **shall** be directed away from walks and tied into underground  
9 storm drain line system. All drainage **shall** be directed into underground storm drains.
- 10  Top of finish grade next to exterior walls **shall** be set a minimum of 8 in. below top of  
11 finish floor except at building entrance locations.
- 12  All slopes **shall** be less than 1 in 3.
- 13  The recommended slope for paving is between 1% and 2%. Slopes in excess of 5% **will**  
14 **not** be permitted except in special circumstances where the Owner's prior approval **will**  
15 be required.
- 16  **Do not** stockpile excavations permanently on site.
- 17  All cleaned topsoil **shall** be stockpiled for site use or other use by WCPSS.

18  
19 **END OF SECTION**

1  
2 **SECTION 02280 - TERMITE CONTROL**  
3

4 **GENERAL**

- 5  RE-TREATMENT AND REPAIR: If subterranean termite activity is discovered during  
6 warranty period, Contractor **will** re-treat soil and repair or replace damage caused by  
7 termite infestation, without cost to the Owner.  
8  The Pest Control Subcontractor **shall** pay the entire cost of re-treatment if required by  
9 the North Carolina Department of Agriculture or if required to comply with these  
10 specifications including the costs of providing access to the soil, repair of resulting  
11 damage to concrete, and project delays.  
12

13 **PRODUCTS**

- 14  SOIL TREATMENT SOLUTION: Use an emulsible concentrate termiticide for dilution  
15 with water, specially formulated to prevent infestation by termites. Provide a solution  
16 recommended by Applicator and acceptable to Architect and approved for intended  
17 application by the manufacturer and registered and approved by EPA and the N. C.  
18 Department of Agriculture, Structural Pest Control Division. Use only soil treatment  
19 solutions which are not injurious to planting.  
20

21 **EXECUTION**

- 22  SURFACE PREPARATION: Remove foreign matter which could decrease effectiveness  
23 of treatment on areas to be treated. Loosen, rake, and level soil to be treated, except  
24 previously compacted areas under slabs and foundations. Toxicants may be applied before  
25 placement of compacted fill under slabs, if recommended by toxicant manufacturer.  
26  Mixing: Mix emulsible concentrate termiticide into solution on site with confirmation by  
27 the Owner's testing laboratory.  
28  Apply according to manufacturer's recommendations as approved by the Designer. All  
29 Wake County Public Schools **shall** be treated at labeled rates.  
30  After application, the contractor **shall** request soil samples be taken by the North  
31 Carolina Department of Agriculture Structural Pest Control Division (919.733.6100).  
32 The pesticide recovery level must meet their minimum requirements prior to proceeding  
33 with construction.  
34  Reapply soil treatment solution to areas disturbed by subsequent excavation or other  
35 construction activities following application.  
36

37 **END OF SECTION**

1  
2 **SECTION 02510 - WALKWAY, ROAD AND PARKING PAVING**  
3

4 **PRODUCTS**

- 5  **CONCRETE WALKWAYS:** shall be minimum of 4 in. thick and 5 ft. wide with a broom  
6 finish. Use Fiber Reinforcement and install construction joints at a maximum of 5 ft. on  
7 center and expansion joints at a maximum of 30 ft. on center. Use wider walkways at  
8 entrances and bus and parent drop off areas.
- 9  **CONCRETE PAVING:** shall be made of reinforced concrete and a minimum of 6 in.  
10 thick on a compacted sub-grade. Where sidewalks are used for maintenance access they  
11 shall be reinforced/thickened to meet vehicular load requirements.
- 12  **ASPHALT PAVING:** shall be a minimum of 1-1/2 in. Type I-1 surfacing with reflective  
13 aggregate on 2 in. of binder on 6 in. compacted ABC base course at driveways, heavy  
14 truck access and bus parking areas. At car parking areas paving shall be a minimum of 2  
15 in. Type I-1 surfacing on 6 in. compacted ABC base course. All work shall be in  
16 accordance with the NC Department of Transportation "Standard Specifications for  
17 Roads and Structures" and the Asphalt Handbook Manual Series No. 4 (MS-4) 1989  
18 Edition. Compliance to these standards shall be verified with density testing by either  
19 core samples or nuclear density gauge at all paved areas, with particular attention given to  
20 bus driveways and parking areas. The testing shall be done by the Contractor and  
21 overseen by the Designer as required for reimbursement by the state.
- 22  All pavements located in Triassic soils shall be designed in accordance with these  
23 specifications by a Professional Engineer with expertise in geotechnical engineering.  
24 These areas are shown on Attachment 02510-A which includes all areas located west of  
25 the line designated as A-A.
- 26  All materials, mixes and construction techniques shall comply with Section 1008,  
27 Aggregate Base Course for Stabilization, Section 640, Asphalt Concrete Binder Course  
28 and Section 645, Asphalt Concrete Surface Course, of the North Carolina Department Of  
29 Transportation Standard Specifications for Road and Structures (1995). A job mix  
30 formula shall be furnished prior to the application of the asphalt.
- 31  **CONCRETE CURB AND GUTTER:** shall be integral, one-piece curb and gutter with a  
32 broom finish. Height of curb shall be six inches and width of curb and gutter shall be a  
33 minimum of 24 in. Install construction joints at a maximum of 5 ft. on center and  
34 expansion joints at a maximum of 30 ft. on center. Extruded curb is acceptable;  
35 however, it shall be properly installed and back-filled. Use of extruded curbs installed on  
36 the surface of the roadway is unacceptable. Eliminate Curb and Gutter when possible to  
37 permit natural drainage.
- 38  **FIRE DEPARTMENT ACCESS ROADS:** shall be constructed of a masonry paver  
39 system which allows for turf to in-fill between and among the units. Coordinate location  
40 with authorities and with WCPSS maintenance departments

41  
42 **EXECUTION**


- 43  **CONCRETE WALKS:** Top of walks shall be flush with ground. Flare out walk surfaces at  
44 intersections.
- 45  **CONCRETE PAVING:** shall be provided in front of dumpster pad locations and service  
46 docks for a minimum distance of 16 ft. and minimum thickness of 8 in. with fiber  
47 reinforcement.
- 48  **CONCRETE CURB & GUTTER:** shall be provided at all concrete and asphalt paved  
49 areas. The grade of driveway shoulders shall be flush with top of curb.
- 50  **GRAVEL SERVICE ROADS:** Use of gravel surfaced roads is discouraged and requires prior  
51 written approval from the owner.

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
**DESIGN GUIDELINES**  
6 May 1992

1  
2

**END OF SECTION**

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
 DESIGN GUIDELINES  
 March, 1999



1

2 ATTACHMENT 02510-A – TRIASSIC BOUNDARY MAP **Y MAP**

3 LIMITS OF THE TRIASSIC AREA:  
 4 ALL DEVELOPMENTS  
 5 WEST OF THIS LINE MUST

**WAKE COUNTY**  
 DEPT. OF AGRICULTURE SOIL SURVEY MANUAL – NOV. 1970

1  
2 **SECTION 02530 - ATHLETIC PAVING AND SURFACE**

3  
4 **GENERAL**

- 5  Grading and marking of athletic paving and surfaces **shall** be in compliance with National  
6 Federation High School Association Standards as adopted by the North Carolina High  
7 School Athletic Association. Copies of the standards are available by contacting the  
8 NCHSAA at 919-962-2345 or PO Box 3216, Chapel Hill, NC 27515.

9  
10 **PRODUCTS**

- 11  TRACK AND TENNIS COURT SURFACING: **shall** be 1 in. SASC F-1, (60 lb./sq. yd.)  
12 on 2 in. I-2 asphalt surfacing on 6 inches of compacted stone base course.
- 13  BASKETBALL COURTS AND HARD SURFACE PLAY AREAS: 4 in. fiber reinforced  
14 concrete on compacted sub-grade is acceptable.
- 15  Provide oval 220 yd. track with screenings for surface at elementary sites.
- 16  PLAYGROUND SURFACE MATERIALS: Surface materials for use under and around  
17 playground equipment **shall** be Unitary synthetic materials, such as Carlisle's Playguard,  
18 Vitricon's Vitriturf VPS, or Surface America's Playbound (poured in place). These  
19 surfaces assist in making playgrounds accessible in compliance with the Americans with  
20 Disabilities Act (ADA).

21  
22 **EXECUTION**

- 23  TRACK SURFACING: It is recommended that track-surfacing slope 2% towards in-field.  
24 This **will** require installation of curbs and underground drainage systems. At existing sites  
25 where such drainage systems do not exist, it is acceptable to slope 2% away from in-field.  
26 Two (2) 4 in. diameter empty conduits **shall** be provided under track installations for  
27 future water and power lines. Swells should be installed to divert water away from these  
28 areas.

29  
30 **END OF SECTION**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13

**SECTION 02605 - MANHOLES**

**EXECUTION**

- MANHOLES:** Covers of storm drainage manholes **shall** be set flush with top of surrounding paving or finish grade. Where required by local zoning ordinances mount covers of sanitary sewer manholes 12 in. above finish grade at lawn or planted areas.
- CLEANOUTS:** A concrete pad **shall** be provided around all cleanouts. Size of pad to be 24 in. x 24 in. x 4 in. thick. Top of pad to be flush with finished grade. Cleanouts **shall** be installed within 10 ft. of building wall or downspout location at all underground storm drainage lines.

**END OF SECTION**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20

**SECTION 02610 - STORM DRAINAGE PIPE & FITTINGS**

**GENERAL**

- A magnetic locator tape **shall** be installed at all underground non-metallic pipe installations. This tape **shall** be buried at a depth of 12 in. below top surface of earth and 12 in. below top of subgrade at pavements and walks.

**PRODUCTS**

- REINFORCED CONCRETE PIPE: **shall** be ASTM C 76 Class III.
- POLYVINYL CHLORIDE (PVC) PIPE: **shall** be ASTM D 3033, Type PSP SDR 35 or ASTM D 3034, Type PSM, SDR 35.

**EXECUTION**

- Reinforced concrete is recommended for all pipes 12 inches and larger under paving and for all pipes over 24 inches in dia. Proper bedding and compaction details for larger diameter PVC pipe **shall** be included in construction documents. PVC is recommended for smaller pipe.

**END OF SECTION**

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
**DESIGN GUIDELINES**  
March, 1999

1  
2 **SECTION 02830 - FENCING**  
3

4 **GENERAL**

- 5  Fencing is required for security around exterior mechanical equipment areas and for  
6 security and sport function at tennis courts, high school baseball and softball fields.  
7 Where equipment enclosure fencing is adjacent to main buildings it is desirable for fence  
8 construction to match building construction.  
9

10 **PRODUCTS**

- 11  **CHAIN LINK FENCING:** Galvanized steel chain link fence and gates with all accessories,  
12 fittings, and fastenings to be obtained from the fence manufacturer. Fabric of fence  
13 **shall** have knuckled selvage at both top and bottom. **Do not** extend fabric above top  
14 rail. See Attachment 02830-A for fence specification and installation detail.  
15

16 **EXECUTION**

- 17  **MECHANICAL EQUIPMENT AREAS:** **shall** be enclosed with fence construction a  
18 minimum of 6 ft. high. Provide clearance around equipment as required for service and  
19 operation. Gates **shall** be a minimum of 4 ft. wide. Enclosures **shall** meet local  
20 ordinance requirements  
21  **TENNIS COURTS:** **Shall** be enclosed with a 10 ft. high chain link fence with 4 ft. wide  
22 gates.  
23  **HIGH SCHOOL BASEBALL AND SOFTBALL FIELDS:** **shall** be enclosed with a 6 ft.  
24 high chain link fence with 14 ft. wide service and 4 ft. wide player gates. Crowd  
25 separation fences only need to be 4 ft. high. A 12 ft. high chain link backstop with a 5  
26 ft. high foul ball screen set at 45 deg. **shall** also be provided at softball fields. At baseball  
27 fields the backstop **shall** be 18 ft. high and the foul ball screen **shall** be 6 ft. high.  
28 Dugouts **shall** be a minimum of 8 ft. high and the fencing between the backstop wing and  
29 the dugouts **shall** be a minimum of 10 ft. high. All framework on backstops and hoods  
30 **shall** be welded.  
31  **MIDDLE SCHOOL SOFTBALL FIELDS:** No enclosure fence is required; however, a  
32 10 ft. high chain link backstop with a 5 ft. high foul ball screen set at 45 deg. **shall** be  
33 provided.  
34

35 **END OF SECTION**

1  
2 **ATTACHMENT 02830-A - CHAIN LINK FENCING**  
3 **SPECIFICATION AND INSTALLATION DETAIL**  
4

5 **GENERAL NOTES**

- 6  Provide chain link fences and gates as complete units obtained from a single source  
7 including necessary erection accessories, fittings and fastenings. Dimensions indicated for  
8 pipe, roll-formed, and H-sections are outside dimensions, exclusive of coatings.
- 9  **MANUFACTURERS:** Subject to compliance with requirements, the following  
10 manufacturers are acceptable for use:  
11 Allied Tube and Conduit Corp.  
12 American Fence Corp.  
13 Anchor Fence, Inc.  
14 Page Fence Div/Page-Wilson Corp.  
15 Cyclone Fence/United States Steel Corp.  
16

17 **MATERIALS**

- 18  **FABRIC:** shall typically be No. 9 gauge (0.148 in.) finished size steel wires, 2 in. woven  
19 mesh, with knuckled salvage at both top and bottom. **Do not** extend fabric above top  
20 rail. At baseball and softball backstops **use** No. 6 gauge wire. Furnish one-piece fabric  
21 widths for fencing up to 12 ft. high. Fabric finish shall be galvanized, ASTM A 392,  
22 Class II, with not less than 2.0 oz. Zinc per sq. ft. of surface or aluminum, ASTM A 491,  
23 Class II, with not less than 0.40 oz. aluminum per sq. ft. of surface.
- 24  **FITTINGS AND ACCESSORIES:** galvanized, ASTM A 153, with zinc weights per Table  
25 I.
- 26  **FRAMING AND ACCESSORIES:** manufacture framing of galvanized steel, ASTM A 120  
27 or ASTM A 123, with not less than 1.8 oz. Zinc per sq. ft. of surface.
- 28  **END, CORNER AND PULL POSTS** shall have minimum sizes and weights as follows:  
29 • Up to 6 ft. fabric height, 2.375in. OD steel pipe, 3.65 lbs./lin. ft., or 3.5in. x 3.5 in.  
30 roll-formed sections, 4.85 lbs./lin. ft.  
31 • Over 6 ft. fabric height, 2.875 in. OD steel pipe, 5.79 lbs./lin. ft., or 3.5 in. x 3.5 in.  
32 roll-formed sections, 4.85 lbs./lin. ft.
- 33  **LINE POSTS:** Space line posts 10 ft. on center maximum, unless otherwise indicated of  
34 following minimum sizes and weights:  
35 • Up to 6 ft. fabric height, 1.90 in. OD steel pipe, 2.70 lbs./lin. ft. or 1.875 in. x 1.625  
36 in.  
37 C-sections, 2.28 lbs./lin. ft.  
38 • 6 ft. to 8 ft. fabric height, 2.375 in. OD steel pipe, 3.65 lbs./lin. ft. or 2.25 in. x  
39 1.875 in. H-sections, 2.64 lbs./lin. ft.  
40 • Over 8 ft. fabric height, 2.875 in. OD steel pipe, 5.79 lbs./lin. ft. or 2.25 in. x 1.875  
41 in.  
42 H-sections, 3.26 lbs./lin. ft.
- 43  **BASEBALL AND SOFTBALL BACKSTOP POSTS:** 4.000 in. OD pipe, 9.11 lbs./lin. ft.  
44 Connecting joints of all framework at backstops shall be welded.

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
**DESIGN GUIDELINES**  
 March, 1999

- 1     GATE POSTS: Furnish gate posts for supporting single gate leaf, or one leaf of a double  
 2    gate installation, for nominal gate widths as follows:  
 3  
 4  
 5

Leaf Width	Gate Post	Lbs./Lin. Ft.
Up to 6 ft.	3.5 in. x 3.5 in. roll-formed section or 2.875 in. OD pipe	4.85 5.79
Over 6 ft. to 13 ft.	4.000 in. OD pipe	9.11
Over 13 ft. to 18 ft.	6.625 in. OD pipe	18.97
Over 18 ft.	8.625 in. OD pipe	28.55

- 12
- 13     TOP RAILS: Top rail pipe sections **shall not** be less than 18 ft. long and **shall** be fitted  
 14    with couplings for connected lengths into a continuous run. The couplings **shall not** be  
 15    less than 6 in. long, with 0.070-in. minimum wall thickness, and **shall** allow for  
 16    expansion and contraction of the rail. Open seam outside sleeves **shall** be permitted  
 17    only with a minimum wall thickness of 0.100 in. Top rail **shall** pass through the line  
 18    post tops. Top rail **shall** be securely fastened to terminal posts by either pressed steel or  
 19    malleable steel galvanized connections.
- 20     TENSION WIRE: Provide 7 gauge, coated coil spring tension wire (metal and finish to  
 21    match fabric) and locate at bottom and top of fabric.
- 22     POST BRACE ASSEMBLY: Provide manufacturer's standard adjustable brace at end and  
 23    gate posts and at both sides of corner and pull posts, with horizontal brace located at mid-  
 24    height of fabric. Use 1.66 OD pipe, 2.27 lbs./lin. ft. or equal, for brace, and truss to line  
 25    posts with 0.375 dia. rod and adjustable tightner.
- 26     POST TOPS: Provide weathertight closure cap with loop to receive tension wire or top  
 27    rail; one cap for each post.
- 28     STRETCHER BARS: Use one-piece lengths equal to full height of fabric, with minimum  
 29    cross-section of 3/16 in. x 3/4 in.. Provide one (1) stretcher bar for each gate and end  
 30    post, and two (2) for each corner and pull post, except where fabric is integrally woven  
 31    into post. **Do not** space stretcher bar bands over 15 in. on center, to secure stretcher  
 32    bars to end, corner, pull and gate posts.
- 33     GATES: Fabricate perimeter frames of gates from minimum 1.90 in. OD pipe with finish  
 34    to match fence providing security against removal or breakage connections. Provide  
 35    horizontal and vertical members to ensure proper gate operation and attachment of  
 36    fabric, hardware and accessories. Space frame members' a maximum of 8 ft. apart unless  
 37    otherwise indicated. Provide same fabric as for fence, unless otherwise indicated. Install  
 38    fabric with stretcher bars at vertical edges and at top and bottom edges. Attach stretcher  
 39    bars to gate frame at not more than 15 in. on center. Install diagonal cross bracing  
 40    consisting of 3/8 in. dia. adjustable length truss rods on gates to ensure frame rigidity  
 41    without sag or twist.
- 42     GATE HARDWARE: Provide hardware and accessories for each gate, galvanized per  
 43    ASTM A 153. Hinges **shall** be of a size and material to suit gate size, non-lift-off type,  
 44    offset to permit 180 deg. gate opening. Provide 1-1/2 pair of hinges for each leaf over 6  
 45    ft. nominal height. Latch **shall** be forked type of plunger-bar type to permit operation  
 46    from either side of gate, with padlock eye as integral part of latch. Provide keeper for  
 47    vehicle gates, which automatically engages gate leaf and holds it in open position until  
 48    manually released. For double gates, provide gate stops consisting of mushroom type  
 49    flush plate with anchors, set in concrete, and designed to engage center drop rod or  
 50    plunger-bar. Include locking device and padlock eyes as integral part of latch, permitting  
 51    both gate leaves to be locked with single padlock.



- 1  **SLIDING GATES:** Provide manufacturer's standard heavy duty inverted channel track,  
2 ball-bearing hanger sheaves, overhead framing and supports, guides, stays, bracing,  
3 hardware, and accessories as required.
- 4  **WIRE TIES:** For tying fabric to line posts, **use** wire ties spaced 12 in. on center. For  
5 tying fabric to rails and braces, **use** wire ties spaced 24 in. on center. For tying fabric to  
6 tension wire, **use** hog rings spaced 24 in. on center. Manufacturer's standard procedure  
7 will be accepted if of equal strength and durability.
- 8  **CONCRETE:** Provide concrete consisting of Portland Cement, ASTM C 150, aggregates  
9 ASTM C 33 and clean water. Mix materials to obtain concrete with a minimum 28-day  
10 compressive strength of 2500-psi using at least four (4) sacks of cement per cubic yard, 1  
11 in. maximum size aggregate and maximum 3 in. slump.

12  
13 **INSTALLATION**

- 14  Install chain link fence in accordance with ASTM F 567 and written installation  
15 instructions of fencing manufacturer to provide secure, aligned installation. If not shown  
16 on drawings, excavate postholes to minimum depth and diameter as recommended by  
17 fence manufacturer. Fill holes with concrete and set posts plumb, in line, and at proper  
18 spacing. Specify that no concrete is to be exposed above finished grade at fence posts.
- 19  Equipment enclosures made of chain link shall have posts set with-in perimeter of  
20 concrete pad. Concrete pad to be sloped to allow for proper drainage. Chain link  
21 equipment enclosures to have top, middle and bottom rails.
- 22  All gates to be secured with padlock furnished by Owner.
- 23  
24

**END OF SECTION**

1  
2 **SECTION 02900 - GRASS SEEDING**  
3

4 **GENERAL**

- 5  The Designer **shall** require the contractor to stage construction so all playground and  
6 athletic field grass seeding occurs early enough to allow grass to develop through one  
7 growing season prior to substantial completion. When substantial completion is  
8 scheduled for June through December, grass seeding **shall** occur prior to April 15. It **will**  
9 be the contractor's responsibility to fertilize, irrigate and cut the maturing grass until  
10 substantial completion. The areas of playground and athletic grass seeding along with  
11 scheduled seeding date **shall** be shown on Designer's Landscape Planting Plans.
- 12  At renovation/addition projects, the Designer **shall** require the Contractor to isolate and  
13 protect existing lawn areas not involved in the new construction.
- 14  Irrigation should be provided for front of school and athletic playing fields.  
15

16 **PRODUCTS**

- 17  **LAWN GRASS SEEDING:** **shall** be 5 lbs. of Kentucky 31 Tall Fescue and 1 lb. of  
18 Kentucky Bluegrass/1,000 sq. ft. from September 15 through March 30. From April 1  
19 through June 15 seeding **shall** be Hulled Common Bermuda at a rate of 2 lbs./1000 sq. ft.
- 20  **ATHLETIC FIELD GRASS SEEDING:** **shall** be composed of sod forming grasses. The  
21 best variety for the Wake County area is Bermuda. The first preference is hybrid  
22 Bermuda Tifton 419. Sodding has given best results with sprigging being satisfactory  
23 when given enough time to establish. Hulled Common Bermuda is next and should be  
24 seeded at 2 lbs./1,000 sq. ft. This seeding needs the entire growing season from April 15  
25 through August 30 to develop. Annual Rye Grass can be planted during fall and winter  
26 months for temporary cover.  
27

28 **EXECUTION**

- 29  **SEEDBED PREPARATION:** After weed eradication, rough grading and seedbed cleaning  
30 is done; limestone, basic fertilizers and any soil improving additions **shall** be well mixed  
31 into the top 4 to 6 in. of soil. This can be accomplished with a rotary tiller, disking,  
32 plowing or even spading. Amount of limestone application should be determined through  
33 soil testing. Following rate of basic inorganic fertilizers are recommended for seedbed  
34 preparation.
- 35  **WCPSS shall** review, test, and approve seedbed preparation and seeding methods prior to  
36 and during seeding.  
37

38 **NOTE**

- 39  Establishment of an acceptable lawn has been a dismal failure in most projects before  
40 yours. Accordingly, this area requires added attention in contract documents and project  
41 administration and supervision. It is essential that a well-established stand of grass is  
42 present when school first begins.

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
**DESIGN GUIDELINES**  
 6 May 1992

1	Application Rate in Pounds Per:			
2		<u>Fertilizer</u>	<u>1000 SF</u>	<u>Acre</u>
3				
4	10-20-10	25-40	1000-1750	
5				
6	5-10-5	50-80	2000-3500	
7				
8	10-10-10 and	25	1000	
9	20% super phosphate	12-25	500-1000	
10				
11	5-10-10 and	40	1750	
12	20% super phosphate	5-20	220-880	
13				
14	6-10-4	50-80	2000-3500	
15				
16	10-20-20	25	1000	

- 17
- 18  **FINAL GRADING AND STARTER FERTILIZER:** Check slope, remove all foreign
- 19 materials and stones larger than 1/2 in. Level soil and roll with heavy (250-300 lbs.)
- 20 roller. Keep soil damp, not dry or wet, when it is worked. Alternately rake and roll area
- 21 until foot marks cannot be seen readily or they are less than 1/4 in. deep.
- 22  Apply starter fertilizer at a rate that will provide 1 to 1-1/2 lbs. of actual nitrogen/1000
- 23 sq. ft. Rake starter fertilizers into soil surface about 1 in. deep and proceed with grass
- 24 seeding.
- 25  **IRRIGATION:** From time of seeding to substantial completion the Contractor **shall**
- 26 keep maturing grass irrigated on a regular basis. This **shall** be a minimum of once a day
- 27 until two (2) weeks after date of seeding. Thereafter, irrigation **shall** be done a minimum
- 28 of once every week.
- 29

30 **END OF SECTION**

1  
2 **SECTION 02910 - LANDSCAPE PLANTING**

3  
4 **GENERAL**

- 5  Landscape planting offers a cost effective means to enhance overall project appearance,  
6 provide privacy at outdoor learning areas and provide summer sun shading and winter  
7 wind breaks. All species should be of hearty, durable variety and require minimum  
8 maintenance. **Do not use** plants with thorns, thistles or toxic foliage, flowers or fruit.  
9  At renovation/addition projects, the Design **shall** require the Contractor to isolate and  
10 protect existing planting not involved in the new construction.  
11

12 **PRODUCTS**

- 13  TREE, SHRUB AND GROUND COVER PLANTING: Drought-tolerant species **shall** be  
14 specified where possible. See Attachment 2910-A for preferred species and species to  
15 avoid.  
16  IMPORTED FIRE ANT CONTROL: In order to limit importation of Fire Ants, WCPSS  
17 prefers that local plants be used. However, whether local or imported from outside the  
18 area, plants **shall** be accompanied by a certificate stating "certified under all applicable  
19 state and federal quarantines." In addition, the specifications **shall** require that the  
20 Design Consultant **shall** inspect each shipment of plant materials for the presence of  
21 imported fire ants.  
22  See section 02900-1  
23

24 **EXECUTION**

- 25  TREE, SHRUB, AND GROUND COVER PLANTING: **shall** have 8 in. minimum deep  
26 plant beds with incorporation of 2 in. of decomposed organic matter. All plant beds  
27 **shall** receive an application of pre-emergent "herbicide" before area is mulched. All  
28 trees and shrubs **shall** be mulched with a minimum of 3 in. of pine bark mulch. Islands in  
29 parking lots should be mulched in their entirety. They **shall not** be planted with grass.  
30  Where slopes exceed 1 in 5 it is recommended ground cover such as Parson or Blue  
31 Pacific Juniper be planted and mulched with a minimum of 3 in. (after compaction) of  
32 pine bark, hardwood mulch or pine straw.  
33  All trees and shrubs **shall** be mulched with a minimum of 3 in. (after compaction) of pine  
34 bark, hardwood mulch, or pine straw.  
35  All shade trees **shall** be placed in a manner so that mature size limbs **will not** overhang  
36 buildings or power lines. At driveway and parking areas all trees **shall** be at height at  
37 installation that they **will not** obstruct motorists' line of sight.  
38  All shrubs placed near buildings **shall** be selected from varieties so that at mature height  
39 the planting **will not** overgrow or obstruct vision from windows. At driveway and  
40 parking areas shrubs **shall** be selected from varieties so that at mature height the planting  
41 **will** stay below the motorists' line of sight.  
42

43 **END OF SECTION**

1  
2 **ATTACHMENT 02910-A PREFERRED TREE, SHRUB, & GROUND. COVER**  
3 **PLANT LIST**  
4

5  **TREES**

- 6 Acer Ginnala - Amur Maple  
7 Acer Palmatum - Japanese Maple (protected location)  
8 Acer Platanoides - Norway Maple  
9 Acer Rubrum - Red Maple (all varieties)  
10 Betula Nigra - River birch  
11 Cedrus Deodata - Deodara cedar  
12 Carpinus spp. - Hornbeam  
13 Cercis Canadensis - Redbud  
14 Cornus Kousa- Dogwood (all varieties-can use Cornus Florida but concern has been  
15 raised because of susceptability to anthracnose - prefer Cornus Kousa)  
16 Cryptomeria Japonica - Japanese Cedar  
17 Fagus spp. - Beech  
18 Ginkgo Biloba - Ginkgo-males only due to smell of fruit  
19 Gleditsia Triacanthos Inermis - Thornless Locust  
20 Juniperus Virgimana - Eastern Red Cedar  
21 Koelreuteria Paniculata - Golden-Rain Tree  
22 Lagerstromia Indica - Crepe Myrtle (mildew-resistant var.)  
23 Magnolia Grandiflora - Southern Magnolia  
24 Magnolia Stellata - Star Magnolia  
25 Magnolia Virginiana - Bay Magnolia  
26 Metasequoia Glyptostroboides - Dawn Redwood  
27 Platanus spp. - Sycamore-**do not use** near buildings or parking lots  
28 Pinus Taeda - Loblolly Pine (Avoid planting near building or parged arcs)  
29 Pinus Thunbergiana - Japanese Black Pine  
30 Prunus Caroliniana - Carolina Cherry Laurel  
31 Prunus Calleryana - (Aristocrat & Bradford only)  
32 Prunus Cerasifera - Purple Leaf  
33 Prunus X'yedoensis - Yoshino Cherry  
34 Prunus X'okame - Okame Cherry  
35 Quercus spp. Oak (prefer Sawtooth, Pin and Willow)  
36 Quercus Virginiana  
37 Taxodium distichum - Bald Cypress  
38 Tsuga canadensis - Canadian Hemlock  
39 Ulmus Parvifolia - Chinese  
40 Zelkova Serrata - Japanese Elm

41

42  **SHRUBS**

- 43 Abelia Grandiflora - (Sherwood & Goucher var. only) -**do not use** on Elementary campuses,  
44 near windows, on or around playgrounds anywhere, or near parked cars due to bees.  
45 Acuba Japonica (shaded locations only)  
46 Barberry Thumbergii - Crimson Barberry (dwarf variety only) -**do not use** on Elementary  
47 campuses or near widows or playgrounds anywhere. **Do not** plant near parking lot  
48 medians.  
49 Camellia spp. - shaded protected locations  
50 Chaenomoles Japonica - where pruning is not needed  
51 Chamaecyparis spp. - false Cypress (all var.)

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
March, 1999

- 1 Cleyera Japonica - where pruning is **not** needed
- 2 Cupressocyparis Leylandii - Leyland Cypress
- 3 Euonymus Alatus - Dwarf Burning Bush
- 4 Forsythia spp. - where pruning is **not** needed
- 5 Hibiscus Syriacus - Althea
- 6 Ilex spp. - Holly - (All var. - Var. w/berries placed away from windows) -dwarf variety
- 7 preferred due to no pruning needed.
- 8 Illicium Parvifolium - Anise Bush
- 9 Jasminum spp - (all var except climbers)
- 10 Kumof[eris Chinensis spp. - Avoid planting near or under windows.
- 11 Juniperus Virginiana - Eastern Red Cedar
- 12 Lagerstromia Indica - Dwarf Crepe Myrtle (mildew resistant variety)
- 13 Leucothoe spp (shaded location only)
- 14 Ligustrum spp. - all var. where pruning is **not** needed
- 15 Mahonia spp (Holly grape all var.) -**do not use** on Elementary campuses or near windows or
- 16 playgrounds at other campuses or near parking areas due to bees.
- 17 Myrica Cerifera - Wax Myrtle -where pruning is **not** needed
- 18 Nandina Domestica - (prefer dwarf var.)
- 19 Osmanthus spp. - Tea Olive (all var.) -**do not use** near any windows or playgrounds
- 20 Pieris Japonica - Andromeda - (shaded location)
- 21 Pinus Mugo - Dwarf Pine
- 22 Prunus L. Schipkaensis - Skiplaurel
- 23 Rhododendron - (shaded location only)
- 24 Sarcococca spp. (shaded location only)
- 25 Spirea spp. (all var.)
- 26 Thuja spp. (dwarf var. only)
- 27 Viburnum spp. (all var. dwarf is preferred)
- 28 Weigela Florida (all var) -**do not use** on Elementary campuses or near windows or
- 29 playgrounds at other campuses or near parking areas due to bees.

30

31  **GROUND COVER**

- 32 Ajuga Reptans - (shade only)
- 33 Hemerocallis spp - Daylilly
- 34 Hosta spp - (shade only)
- 35 Juniperus - (prefer Blue Pacific, Procumbens and Parson varieties; **do not use** Shore, Blue
- 36 Rug Andorra and Sargent varieties)
- 37 Liriope - (Big Blue or Variegata only)
- 38 Mondo Grass
- 39 Ophiopogen Jap. - Nana Dwarf
- 40 Pachasandra-(shade only)
- 41 Phlox Subulata -(where spreading is not a problem)
- 42 Vinca Minor - (shade only)

43

44  **PLANTS TO AVOID**

- 45 Acer Saccharinum - Silver Maple
- 46 Acer Saccharum - Sugar Maple
- 47 Albizia Julibrissin - Mimosa
- 48 Amelanchier Canadensis - Service Berry
- 49 Berberis Julianne - Wintergreen Barberry
- 50 Buxus spp. - Boxwood
- 51 Cotoneaster spp - (all var.)
- 52 Cunninghamia Lanceolata - China Fir

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
**DESIGN GUIDELINES**  
6 May 1992

- 1 Crataegus spp. - Hawthorne
- 2 Elaeagnus Pungens -Thorny Elaeagnus
- 3 Evonymus Fortuni - Wintercreeper
- 4 Fraxinus spp. - Ash
- 5 Gardenia spp.
- 6 Hedera Helix
- 7 Liquidambar Straraciflua - Sweetgum
- 8 Liriodendron Tulipifera - Tulip Poplar
- 9 Lonicera spp. - Honeysuckle
- 10 Magnolia Virginiana - Bay Magnolia
- 11 Malus spp. - all apple & crabapple
- 12 Nerium Oleander - Oleander
- 13 Photinia Fraseri
- 14 Phyllostachys spp - and all bamboo spp.
- 15 Populus spp. - (all var.)
- 16 Pyracantha spp. - Firethorn (all var.)
- 17 Rosea - Rose (all var.)
- 18 Salix spp. - (Willow)
- 19 Sophora spp - Pagoda tree
- 20 Yucca spp - (all var)
- 21
- 22

**END OF SECTION**

1  
2 **SECTION 03300 - CAST-IN-PLACE CONCRETE**  
3

4 **GENERAL**

5  **CODES AND STANDARDS:** Comply with applicable provisions of ACI 301  
6 "Specifications for Structural Concrete for Buildings", ACI 318, "Building Code  
7 Requirements for Reinforced Concrete", and ACI 347, "Recommended Practice for  
8 Concrete Formwork".

9  **TESTING:** Owner's testing laboratory will perform sampling and testing as indicated in  
10 Field Quality Control paragraph.

11  **FIELD QUALITY CONTROL:** During placement of concrete the following tests and  
12 sampling **shall** be made:

13       Sampling: ASTM C 172.

14       Slump: ASTM C 143.

15       Air Content: ASTM C 173.

16       Compressive Strength: ASTM C 39; one specimen tested at seven (7) days, and one  
17 specimen tested at twenty-eight (28) days, and one retained for later testing if  
18 required.

19  **CONCRETE MIXES:** Contractor **shall** employ an acceptable testing laboratory to  
20 perform materials evaluation and testing, and to design concrete mixes.

21  **RECYCLED MATERIALS:** The use of 20% fly ash and/or 30% slag is permissible.  
22

23 **PRODUCTS**

24  **CONCRETE:** Use air-entraining admixture in all concrete, providing not less than 4%  
25 nor more than 6% entrained air for concrete exposed to freezing and thawing, and from  
26 2% to 4% for other concrete. Unless otherwise noted, all concrete **shall** have a twenty-  
27 eight (28) day strength of at least 3000 psi. When placed, concrete **shall** have a slump  
28 between 3 and 5 inches.

29  **VAPOR BARRIER:** **shall** be a reinforced material such as "Moistop II by Fortifiber  
30 Corporation.

31  **WATER REDUCING** or **ANTI-FREEZE** admixtures **shall not** be permitted.

32  **Use Chemical Hardener** or **Surface Sealer** on all interior concrete slabs to remain exposed.

33  At exposed concrete floors **use** clear epoxy seal. Allow concrete to cure for 30 days  
34 prior to application of seal. Follow manufacturer's recommendation for surface  
35 preparation. Apply two (2) coats of clear solvent base epoxy seal. In the event that  
36 North Carolina changes its ambient air quality standard preventing the use of a solvent  
37 base, a water base epoxy seal should be used.

38  
39 **EXECUTION**

40  **COLD WEATHER CONCRETING:** All concrete placed when temperature is below 40  
41 deg. F. **shall** be placed in strict accordance with "Cold Weather Concreting" (ACI-306).

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
**DESIGN GUIDELINES**  
6 May 1992

- 1  CONTROL JOINTS: Construct using pre-molded key joints, inserts, tooled joints or  
2 sawcut joints. Minimum depth of control joints **shall** be one-fourth (1/4) of the slab  
3 thickness. Maximum spacing of joints **shall** be 40 ft. by 40 ft. Isolate all slabs from  
4 exterior walls.
- 5  REINFORCEMENT: Position support and secure reinforcement against displacement.
- 6  PLACEMENT: Comply with ACI 318.
- 7  CURING: **shall** begin within eight (8) hours after placing, by moisture retaining covering  
8 (curing sheets) weighted down with sand.
- 9  SURFACE TOLERANCE: Not to exceed 1/8 in. under a 10 ft. straightedge.
- 10  Contractor **shall** be responsible to control rinse water run off.

11

12

**END OF SECTION**

1

2 **SECTION 04200 - MASONRY**

3

4 **GENERAL**

- 5  Cavity wall (masonry veneer on concrete masonry unit back-up) and veneer wall  
6 (masonry veneer on steel stud back-up with cavity space) construction is strongly  
7 recommended at exterior masonry walls. Control joints, expansion joints and flashing  
8 **shall** be located and installed as per the recommendations of the Brick Institute of  
9 America and National Concrete Masonry Association.
- 10  Use of load bearing wall construction is discouraged.
- 11  Where masonry walls supported by elevated floor construction meet ground supported  
12 walls, control joints **shall** be installed.
- 13  All concrete masonry units **shall** be kept free from coal cinder aggregate, waste products,  
14 organic impurities, and any other deleterious substance that will cause rusting, staining or  
15 pop outs. Blended and light weight concrete masonry units free from the above  
16 impurities and substances are acceptable for use.

17

18 **EXECUTION**

- 19  MASONRY: Particular attention **shall** be given to workmanship.
- 20  Rinse water run-off **shall** be controlled during clean up.
- 21  Any enclosed planters must have minimum 1 in. weep holes every 6 ft.
- 22  If any wall of planted area encloses a heated space, waterproofing **shall** be used from  
23 footing to finished grade.
- 24  Cavities **shall** be kept clean of mortar drippings.
- 25  **Do not use** raked mortar joints.
- 26  Flush masonry wall construction is preferred. Special shape (sloping) units **shall** be used  
27 at projecting courses. No horizontal ledges will be allowed.
- 28  Direct particular attention to the design and installation of through-wall flashing.
- 29  Areas of exterior masonry where through-wall flashing is not required should have "clear  
30 waterproofing sealant" applied.
- 31  Special shape bullnose units **shall** be provided at corners of interior CMU wall  
32 construction in high traffic areas.
- 33  At all interior and at exterior expansion joints adjacent to high traffic areas vandal  
34 resistant metal covers **shall** be provided.

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
**DESIGN GUIDELINES**  
6 May 1992

- 1  COLD WEATHER MASONRY: Masonry may be laid when the temperature of the  
2 outside air is below 40 deg. F. if protection requirements are in compliance with  
3 "Recommended Practices for Cold Weather Masonry Construction", as published by the  
4 International Masonry Industry All-Weather Council. Accelerator or water-reducing  
5 admixtures are not recommended for cold weather masonry work.

6

7

**END OF SECTION**

1

2 SECTION 05500 - METAL FABRICATIONS

3

4 GENERAL

- 5  CODES AND STANDARDS: Comply with applicable provisions of AISC "Specifications  
6 for the Design, Fabrication and Erection of Structural Steel for Buildings" and AWS  
7 "Structural Welding Code", unless otherwise indicated.

8

9 PRODUCTS

- 10  RAILS: Exterior rails **shall** be aluminum or galvanized steel.
- 11  INTERIOR METAL STAIRS: Stair stringers **shall** be steel channels or tubing.
- 12  LADDERS: Provide metal ladder to roof with locked scuttle or ladder guard. Provide stair  
13 for roof access, if feasible. Ladders **shall** be attached or anchored in solid building  
14 materials. Anchoring in drywall is unsafe and **will not** be acceptable.

15

16

END OF SECTION

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

**SECTION 06100 - ROUGH CARPENTRY**

**GENERAL**

- GRADING AND INSPECTION AGENCIES: Each piece of lumber or plywood **shall** be grade stamped by one of the following agencies:
  - APA - American Plywood Association
  - CRA - California Redwood Association
  - SPIB- Southern Forest Products Association
  - WWPA- Western Wood Products Association

**PRODUCTS**

- LUMBER, GENERAL: Provide seasoned lumber 19 percent moisture content. Provide preservative treated lumber for cants, nailers, blocking, furring, grounds, stripping and similar items in connection with roofing, flashing and waterproofing or in direct contact with concrete or masonry.
- BUILDING PAPER: Asphalt saturated organic felt, or polyethylene sheet.
- PRESERVATIVE TREATED WOOD: All preservative treated lumber and plywood **shall** be pressure treated with water-borne preservatives to comply with AWWA C2 and C9.

**EXECUTION**

- Store lumber and plywood materials off the ground and under cover which has been vented to prevent condensation.

**END OF SECTION**

1  
2 **SECTION 06200 - FINISH CARPENTRY**  
3

4 **GENERAL**

- 5  GRADING AND INSPECTION AGENCIES: Each piece of lumber or plywood **shall** be  
6 grade stamped by one of the following agencies:

7 APA - American Plywood Association

8 CRA - California Redwood Association

9 SPIB- Southern Forest Products Association

10 WWPA- Western Wood Products Association

11 WMMP- Wood Molding and Millwork

12 Producers

13  
14 **PRODUCTS**

- 15  LUMBER STANDARDS: Comply with PS 20 "American Softwood Lumber Standard".  
16  PLYWOOD STANDARDS: Comply with PS 1 "U. S. Product Standard for Construction  
17 and Industrial Plywood" for plywood and for products manufactured under PS 1, with  
18 APA PRP-108. Formaldehydes in adhesives and binders **shall not** be permitted.

19  
20 **EXECUTION**

- 21  Store lumber and plywood materials off the ground and under cover which has been  
22 vented to prevent condensation.  
23  Cope at returns and miter at corners to produce tight fitting joints. Use scarf joints for  
24 end-to-end joints.  
25  Repair damaged or defective finish carpentry where possible to eliminate functional or  
26 visual defects. Where not possible to repair, replace finish carpentry. Adjust joinery for  
27 uniform appearance.

28  
29 **END OF SECTION**

1  
2 **SECTION 06200 - FINISH CARPENTRY**  
3

4 **GENERAL**

- 5  GRADING AND INSPECTION AGENCIES: Each piece of lumber or plywood **shall** be  
6 grade stamped by one of the following agencies:

7 APA - American Plywood Association

8 CRA - California Redwood Association

9 SPIB- Southern Forest Products Association

10 WWPA- Western Wood Products Association

11 WMMP- Wood Molding and Millwork

12 Producers

13  
14 **PRODUCTS**

- 15  LUMBER STANDARDS: Comply with PS 20 "American Softwood Lumber Standard".  
16  PLYWOOD STANDARDS: Comply with PS 1 "U. S. Product Standard for Construction  
17 and Industrial Plywood" for plywood and for products manufactured under PS 1, with  
18 APA PRP-108. Formaldehydes in adhesives and binders **shall not** be permitted.

19  
20 **EXECUTION**

- 21  Store lumber and plywood materials off the ground and under cover which has been  
22 vented to prevent condensation.  
23  Cope at returns and miter at corners to produce tight fitting joints. Use scarf joints for  
24 end-to-end joints.  
25  Repair damaged or defective finish carpentry where possible to eliminate functional or  
26 visual defects. Where not possible to repair, replace finish carpentry. Adjust joinery for  
27 uniform appearance.

28  
29 **END OF SECTION**

1

2 **SECTION 06410 - INTERIOR ARCHITECTURAL WOODWORK**

3

4

**GENERAL**

5

- STANDARDS: Comply with "Architectural Woodwork Quality Standards" published by Architectural Woodwork Institute (AWI).

6

7

- SAMPLES: Contractors should be required to submit samples of transparent finishes which show the extremes in color variation.

8

9

10

**PRODUCTS**

11

- TRANSPARENT FINISHED CASEWORK: Casework **shall** be of a heavy-duty construction. It is suggested that Campbell Rhea be used as a standard. In the past, Collegedale and Kewanee have been considered equals. See Section 12304 for detailed information on laminate clad casework.

12

13

14

15

- DOORS: Construction and thickness **shall** be "as required" to prevent warpage.

16

17

- SHELVES: **Do not** exceed spans of 3 ft. for 3/4 in. thick shelves and 4 ft. for 1 in. thick shelves.

18

19

20

- COUNTERTOP: Plastic laminate surface. Base material for countertops may be dense particleboard (no formaldehydes permitted), except that marine grade plywood **shall** be used in wet locations.

21

- CABINET HARDWARE:

22

Drawer and Door Pulls: Heavy duty, 4 in. rod

23

pull

24

Drawer Slides: 60 lb. capacity wheeled slides

25

with self-closing feature

26

Door Hinges: Concealed hinges, European Style, self-closing with built-in horizontal

27

and vertical adjustment.

28

Door Silencers: **shall** be provided at all

29

cabinet doors

30

- MILLWORK/CASEWORK PLANNING DATA: See Attachment 06410-A.

31

32

**EXECUTION**

33

- PRECAUTIONS: **Do not** install architectural woodwork until the building is enclosed, the permanent heating and cooling system is in operation, and residual moisture from plaster, concrete, masonry or terrazzo has dissipated.

34

35

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
**DESIGN GUIDELINES**  
March, 1999

- 1  **ADDITIONAL REQUIREMENTS: Use French Dovetail mortise and tenon to attach**  
2 **drawer sides to drawer fronts.**
- 3  **Where transparent finish is shown, cut doors and drawer fronts of each run of cabinets**  
4 **from one "Counterfront" sheet of plywood (with particleboard or lumber core) and install**  
5 **them in the same position so that the grain runs vertically and grain matches between**  
6 **adjacent doors and/or drawers.**

7

8

**END OF SECTION**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28

**ATTACHMENT 06410-A - MILLWORK/CASEWORK PLANNING DATA**

(Use the following standards unless noted otherwise by Project Building Program requirements)

**RECOMMENDED HEIGHTS**

**Tables:**

Pre-Kindergarten	25 in.
Elementary	25 in., 27.5 in., and 29 in.
Middle	29 in.
High	29 in.

**Chairs and other seating:**

Pre-Kindergarten	13.5 in. classroom, 14 in. media center
Elementary	13.5 in., 15.5 in., and 17.5 in. classroom; 14 in., 16 in., and 18 in. media center
Middle	17.5 in. classroom, 18 in. media center
High	17.5 in. classroom, 18 in. media center

**Perimeter Shelving:**

**shall** be 82 in. high except at window locations where 42 in. high shelving is recommended.

**Freestanding Shelving:**

None over 42 in. high

**Depth of Shelves:**

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
**DESIGN GUIDELINES**  
March, 1999

- 1 Books, regular 12 in.
- 2 Picture Books 12 in. to 14 in.
- 3 Reference Books 12 in.
- 4 Print & Non-print 12 in.
- 5 Kits & Oversize Books 16 in.

6

7 **Shelf Capacities per 3 ft. Unit:**

- 8 Average Hard Books 30
- 9 Reference Books 18
- 10 Picture Books 60

11

12 **Access Space:**

13 At least 42 in. between rows of shelves

14 At least 60 in. between rows of shelves and furniture involving seating or  
15 traffic

16 At least 60 in. between two parallel tables with back-to-back seating

17 At least 36 in. between tables and wall or between a row of shelves and other  
18 furniture not involving seating or traffic

19

20 **END OF SECTION**

1  
2 SECTION 07000 - THERMAL & MOISTURE PROTECTION DESIGN  
3 **CONSIDERATIONS**

4  
5 **GENERAL**

- 6  Architectural firms **shall** be required to **use** a Registered Roof Consultant (RRC) if their  
7 contract involves any roofing at all. All roofing plans to be sealed by the registered roof  
8 consultant. The RRC is to pre-qualify bidders 30 days prior to bid dates.
- 9  **MEDIUM SLOPED ROOFS:** The Wake County Public School System strongly  
10 recommends high pitched roofs (slopes 3 in 12 or greater) be considered for use. Standing  
11 seam roofing is preferred. Dimensional, asphalt shingle roofing weighing 250 lbs./square  
12 or greater is acceptable.
- 13  **LOW SLOPE ROOFS:** Low slope roof systems (Built-Up and Modified Bitumen) are  
14 preferred but (Single Ply) is acceptable. Minimum slope to point of discharge **shall** be  
15 1/4 in.  
16 /foot. 4 Ply built-up roof is acceptable.
- 17  **CANOPIES AND COVERED WALKWAYS:** Provide overhead canopies at primary  
18 building entrances as per Section 02001. Sheet metal panel systems are recommended for  
19 soffit construction. Stucco and drywall soffits **shall not** be used. Gutters and downspouts  
20 may be used at covered walkways as long as run-off is directed away from walks or is  
21 discharged into underground storm drain lines.
- 22  **WALL AND ROOF INSULATION:** The maximum U-value **shall** be .10 for wall  
23 construction and .05 for roof construction. Designers are encouraged to consider lower  
24 U-values based on life-cycle cost analysis. In new construction, insulation **shall not** be  
25 used as the primary method to assure proper drainage, rather the use of sloped steel  
26 members is preferred.
- 27  **SKYLIGHTS:** Overhead sloping glazing **shall** be used only with the special consent of the  
28 Owner. Where day-lighting of interior spaces is desired, vertical clerestory glazing is  
29 recommended for use. Where practical the clerestory glazing **shall** face north or face  
30 south with vertical overhang solar protection.

31  
32 **PRODUCTS**

- 33  **ROOF INSULATION:** **shall** require certification that insulation meets Thermal  
34 Warranty. Warranty states that roof insulation's actual thermal resistance will not vary  
35 by more than 10% from the published R-Value for a period of fifteen (15) years.
- 36  All roof insulation **shall** be CFC free.
- 37  Registered Roof Consultant **shall** be responsible for review and acceptance of all shop  
38 drawings and submittals pertaining to roof construction.

39  
40 **EXECUTION**

- 41  Registered Roof Consultant **shall** be responsible for monitoring roof construction and  
42 final acceptance. Weekly inspection reports are required.

43  
44  
45 **END OF SECTION**

1  
2 **SECTION 07100 - WATERPROOFING**

3  
4 **GENERAL**

- 5  All below grade wall construction of interior spaces and elevated floor construction at  
6 toilet rooms and showers **shall** be waterproofed.

7  
8 **PRODUCTS**

- 9  **WATERPROOFING:** 3-Ply bituminous waterproofing using either coal-tar pitch or  
10 asphalt bitumen and felt is recommended for use. Sheet membrane and fluid-applied  
11 waterproofing **shall** be used only with the Owners approval.
- 12  **PROTECTION COURSE:** Where exposed to earth and crushed stone backfill, provide a  
13 protection course over completed waterproofing. For bituminous waterproofing this  
14 **shall** be 1/2 in. asphalt saturated and coated fiber insulation board or 1/8 in. premolded,  
15 asphaltic-laminated, semi-rigid composition board.

16  
17 **EXECUTION**

- 18  **BELOW GRADE WALL WATERPROOFING:** Drainage tile **shall** be installed with  
19 coarse crushed stone backfill at wall foundation. Connect tile drain lines to grade or  
20 storm drain lines.
- 21  **ELEVATED FLOOR WATERPROOFING:** Turn up membrane 4 in. at walls. Prior to  
22 installation of finish flooring, flood entire waterproofed area for 24 hours with water at  
23 least 2 in. deep at shallowest point. Repair any leaks and retest.

24  
25 **END OF SECTION**

1

2 **SECTION 07310- ASPHALT SHINGLE ROOFING**

3

4

**GENERAL**

5

- Where required by project budget constraints, asphalt shingle roofing is acceptable for use on medium pitched roofs, 4/12 minimum slope.

6

7

8

**PRODUCTS**

9

- ASPHALT SHINGLE ROOFING: **shall** be dimensional, laminated strip shingle of mineral surfaced, self sealing, laminated multi-ply overlay construction, bearing UL Class "A" external fire exposure label and UL "Wind Resistant" label, weighing not less than 250 lbs. per square.

10

11

12

13

- ROOFING FELT: **shall** be No. 15 asphalt-saturated unperforated organic roofing felt complying with ASTM D226, 36 in. wide, approximate weight 18 lbs. per square.

14

15

- ICE AND WATER BARRIER: recommended for use at roof eaves. Use polymer modified asphalt reinforced ice and water barrier with a fiberglass mat and self-adhesive backing for bonding to roof deck substrate.

16

17

18

- FLASHING AND SHEET METAL: See Section 07620.

19

20

**EXECUTION**

21

- ASPHALT SHINGLE ROOFING: **shall** be installed along with underlayment according to the recommendations of shingle manufacturer and details and recommendations of NRCA Steep Roofing Manual. Install valleys using a closed cut or closed woven valley.

22

23

24

- ROOFING FELT: **shall** be installed as noted above. Lap felt 6 in. over top edge of ice and water barrier at roof eaves.

25

26

- SNOW GUARDS: **shall** be installed at roof eaves over entrances and walkways.

27

- WARRANTY: Products **must** meet 25 year warranty requirements

28

29

**END OF SECTION**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36

**SECTION 07420 - SHEET METAL ROOFING**

**GENERAL**

- Standing seam roofing is the preferred roof system for medium pitched roofs.

**PRODUCTS**

- SHEET METAL ROOFING: **shall** be a pre-fabricated, pre-finished metal panel roofing system. The system **shall** include the metal panels, sliding clips and other attachments, flashing to adjacent construction and other accessories. The complete systems **shall** meet the requirements of FM I-90 and Class 1A and UL Class A. The complete system installation (flashing, deck, etc.), **shall** be warranted by the manufacturer for 20 years (20 year weathertight and 20 year finish). Finish of all roofing panels, trim and accessory elements **shall** be shop-applied, Kynar 500, Versacor PF or Fluruthane IV coating. Any exposed fasteners **shall** be minimal and of stainless steel construction and **shall** match color of roofing by means of plastic caps or factory-applied coating.
- Acceptable manufacturers include:
  - American Buildings
  - MM Systems Corp Series 300
  - Merchant & Owens Zip Rib
  - Moran 2-1/2 in. SSR
  - Steel Tite SRS
  - Steelox
- Other materials and types of metal panel roof systems **shall** be used only with the approval of the Owner.

**EXECUTION**

- SHEET METAL ROOFING: **shall** be installed by manufacturer authorized installers according to the recommendations of the manufacturer and the requirements of the above noted UL and FM designs. It is recommended that the roof panels be installed on 30 lb. asphalt felt or rubberized modified asphalt over a solid substrate. Provide rosin sized sheathing paper under asphalt felt where recommended by manufacturer or SMACNA.
- SNOW GUARDS: **shall** be installed at roof eaves over entrances and walkways.

**END OF SECTION**

1  
2 **SECTION 07500 - MEMBRANE ROOFING**

3  
4 **GENERAL**

- 5  Minimum slope to point of discharge **shall** be 1/4 in. per foot.

6  
7 **PRODUCTS**

- 8  **SINGLE PLY MEMBRANE ROOFING:** **shall** be either mechanically fastened or fully  
9 adhered type. Minimum thickness of the membrane **shall** be as required by manufacturer  
10 to achieve warranty. A 20 year, no dollar limit warranty is required. The complete  
11 roofing system including membrane, insulation and attachments **shall** meet requirements  
12 of FMI-90 and Class 1A and UL Class A. Owner **must** approve system manufacturer and  
13 type. Acceptable manufacturers include:

14 Carlisle Syntec Systems

15 Fibertite

16 Firestone

17 Manville

18 Stevens

- 19  **MODIFIED BITUMEN ROOFING:** **shall** be either self adhered or hot asphalt mopped  
20 type with a minimum of two plies and **shall** have a factory-applied surface. Modifiers  
21 and reinforcements **shall** be as recommended by the Design Consultant, however no  
22 organic products **shall** be specified. A 20 year, no dollar limit warranty is required.  
23 Acceptable manufacturers include:

24 Firestone

25 Siplast, Inc.

26 Soprema

27 Tamko Asphalt Products, Inc.

- 28  Use of any other Membrane systems or manufacturers must be approved by the Owner.

- 29  **ROOF INSULATION:** Provide insulation thickness as required to meet specified thermal  
30 resistance. Type of insulation must be approved for use by membrane manufacturer and  
31 also meet requirements of the above noted UL and FM designs.

- 32  **FLASHING:** Base flashing **shall** be type recommended by membrane manufacturer. See  
33 Section 07620 for cap and other sheet metal flashing.

34

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
**DESIGN GUIDELINES**  
March, 1999

1                   **EXECUTION**

- 2    **MEMBRANE ROOFING:** Install entire roof system according to recommendations of  
3    membrane manufacturer and requirements of the above noted UL and FM designs. Roof  
4    drain grates **shall** be metal and anchored.

5

6

**END OF SECTION**

1  
2 **SECTION 07600 - FLASHING AND SHEET METAL**

3  
4 **GENERAL**

- 5  Materials and details used for through-wall flashing, gravel stops, gutters and downspouts  
6 **shall** be permanent and require low maintenance. Details **shall** be in accordance with  
7 the NRCA Roofing Manual and the Architectural Sheet Metal Manual by SMACNA.
- 8  Where roofs discharge at eaves it is recommended gutters and perimeter downspouts be  
9 installed. Built-in gutters and downspouts **shall not** be used. Scuppers **shall not** be used  
10 for primary discharge.

11  
12 **PRODUCTS**

- 13  CONCEALED THRU-WALL MASONRY FLASHING: 3 oz./sq. ft. copper bonded with  
14 asphalt to waterproofed Kraft paper masonry flashing is recommended for use. (See  
15 Section 04200-1, Line 27)
- 16  EXPOSED THRU-WALL FLASHING: 16 oz. copper; 17 oz. lead-coated copper; 28  
17 gauge stainless steel; 20 gauge aluminum with anodized or paint "grip" finish; and 26  
18 gauge galvanized steel with Kynar 500 coating are recommended for use.
- 19  CAP FLASHING, PARAPET CAPS, DRIP EDGES, GUTTERS AND DOWNSPOUTS:  
20 Same materials as recommended above for exposed through-wall flashing. At copper and  
21 lead-coated copper valley installations, the minimum thickness **shall** be 20 oz. and 21  
22 oz. respectively. At sheet metal roof installations, it is recommended material and finish  
23 of gutters and downspouts match roof panels.

24  
25 **EXECUTION**

- 26  Downspouts shall be protected with heavy-duty covers (22 gauge minimum) or be  
27 schedule 10 steel or schedule 40 PVC between finished grade and 8 ft. above finished  
28 grade. Covers or pipes are to be painted to match adjacent surface.
- 29  Provide clean-out flush with finish grade within 10 ft. of building wall or downspout  
30 location at all underground storm drainage lines.

31  
32 **END OF SECTION**

1  
2 **SECTION 08100 - HOLLOW METAL DOORS AND FRAMES**

3  
4 **GENERAL**

- 5  Heavy-duty hollow metal door and frames are required for school usage especially at high  
6 traffic areas. Particular attention needs to be given to the preparation and reinforcement  
7 of doors and frames for finish hardware. Doors **shall** be 1-3/4 in. thick and 7 ft. in  
8 height. Generally door design will be full flush. Entrance doors **shall** have large vision  
9 panels or be hollow metal framed glass doors, INTERIOR stair/corridor doors **shall** have  
10 vision lights as allowed by the NC State Building Code. Swinging exterior and interior  
11 "A" label and "B" label double doors **shall** be hollow metal unless otherwise approved by  
12 Owner. All doors and sidelight frames **shall** be hollow metal unless otherwise approved  
13 by Owner.

14  
15 **PRODUCTS**

- 16  EXTERIOR HOLLOW METAL DOORS AND FRAMES: **shall** be SDI Grade III, extra  
17 heavy model 2A (seamless) which requires face sheets of 16 gauge minimum. Also,  
18 exterior doors and frames **shall** be of galvanized steel construction including  
19 reinforcement, louvers and other accessories. Top of exterior doors **shall** be closed flush  
20 and welded watertight. Frames **shall** be fabricated from 14 gauge cold rolled steel.

- 21  INTERIOR HOLLOW METAL DOORS AND FRAMES: **shall** be SDI Grade III, extra  
22 heavy duty, Model 2 (seamless) which requires face sheets of 16 gauge minimum. Interior  
23 frames **shall** be fabricated from 16 gauge cold rolled steel.

- 24  HOLLOW METAL GLAZING FRAMES: **Shall** be fabricated from 14 gauge cold rolled  
25 steel. Where used on the exterior both frame and glazing stops **shall** be made from  
26 galvanized sheet metal and glazing stops **shall** be prime coated prior to assembly.

- 27  FRAME ANCHORAGE: Jamb anchors at masonry wall openings **shall** be standard wire  
28 anchors. Frames at masonry walls **shall** be filled with grout. Jamb anchors for plaster  
29 and gypsum wallboard partition openings **shall** be a minimum of 18 gauge steel. Provide  
30 floor anchors at all frames.

- 31  FINISH HARDWARE REINFORCEMENT: Door reinforcement **shall** be a minimum of  
32 12 gauge for hinges and be a continuous channel for the full height of door, 12 gauge for  
33 closers and be a continuous channel for the full length of the header and 14 gauge for  
34 strikes and be a continuous channel for the full height of the door. 7 gauge  
35 reinforcements **shall** be used for hinges on frames. 26 gauge steel plaster guards or  
36 mortar boxes welded to the frame **shall** be provided at hardware cutouts where installed  
37 in concrete, masonry or plaster openings.

- 38  VISION LIGHTS: **shall** be provided at stairs/corridor doors, except at 3 hour labeled  
39 openings. Glaze with 1/4 in. UL labeled wire glass at fire rated doors and 1/4 in. tempered  
40 glass at other doors. Light size **shall** be 3 in. x 33 in. at fire-rated doors with light  
41 located 10 in. from strike side of door and bottom of light 3-4 ft. above finish floor.  
42 Glazing kits **shall** be (concealed type) flush with door surface.

- 1  LOUVERS: **shall** be sightproof louvers constructed of 24 gauge steel V or Y shaped  
2 blades set in 20 gauge frame. A galvanized wire mesh 1/2 in. x 1/2 in. screen **shall** be  
3 provided at the inside face of exterior door louvers.
- 4  FINISH PREPARATION: The exposed surfaces of door and frame units including  
5 galvanized surfaces **shall** be cleaned, bonderized and shop primed using manufacturer's  
6 standard baked-on rust inhibitive primer.

7 **EXECUTION**

- 8  DOOR AND FRAME LAYOUT: It is recommended for exterior, main entrance doors to  
9 be multiple single doors swinging in the same direction. **Do not** use double doors.
- 10  Frames **shall** be installed in compliance with DHI pamphlet "The Installation of  
11 Commercial Steel Doors and Steel Frames, Insulated Steel Doors in Wood Frames and  
12 Builder's Hardware". Particular attention **shall** be paid to Squareness, Plumbness and  
13 Spreaders. Caution: Angle iron braces shipped with frames at bottom does not qualify as a  
14 "spreader".
- 15  DOOR AND FRAME STORAGE: Contractor **shall** store doors and frames properly at  
16 job site off ground and protected from moisture.
- 17  BOILER ROOMS: **shall** have exterior doors only.
- 18  MAIN MECHANICAL EQUIPMENT ROOMS: **shall** have exterior doors where  
19 possible.

20

21

**END OF SECTION**

1

2 **SECTION 08200 - WOOD DOORS**

3

4

**GENERAL**

- 5  Solid staved core wood doors with transparent finish in hollow metal frames **shall** be used  
6 at most interior doors including 20 minute constructed fire doors. Fire Doors with ratings  
7 of 60 and 90 minutes (labeled) are preferred to be hollow metal. Wood "B" labeled doors  
8 may be used only with Owner's approval. Doors **shall** be pre-fitted and pre-machined at  
9 factory for finish hardware. Wood blocking reinforcement **shall** be provided at hinge,  
10 closer and strike locations. Doors **shall** be 1-3/4 in. thick and 7 ft. high. Generally, door  
11 design will be full flush.

12

13

**PRODUCTS**

- 14  **WOOD DOORS:** **shall** be solid core doors complying with requirements of NWWDA  
15 I.S.1 and Section 1300 of AWI "Architectural Woodwork Quality Standards". Cores  
16 **shall** be solid particle board except for fire-rated doors, which **shall** have solid core as  
17 required to meet rating requirements. Labeled wood doors over 20 minutes requiring flush  
18 bolts, surface bolts, and exit devices, are to receive proper blocking for attachment of  
19 hardware. At high traffic doorways in Middle and High Schools, **use** metal doors.
- 20  **INTERIOR WOOD DOORS WITH TRANSPARENT FINISH:** **shall** be AWI premium  
21 grade with hardwood veneer face, pre-finished at factory utilizing low VOC finishes.
- 22  Specify doors which **do not use** formaldehyde based glue in the manufacturing process.
- 23  Only domestic species of wood should be used.
- 24  Specify only those manufacturers who practice sustainable harvesting methods.
- 25  Two coat hooks **shall** be installed by contractor on the back of all office doors in new  
26 schools and renovated spaces.
- 27  **LOUVERS:** **shall** be metal, sight-proof louvers constructed of 24 gauge steel V or Y  
28 shaped blades in 20 gauge frame.
- 29  **VISION LIGHTS:** All doors at instructional areas **shall** have vision lights. Glaze with 1/4  
30 in. UL labeled wire glass at fire rated doors and 1/4 in. tempered glass at other doors. Set  
31 wire glass in steel frame. Light size **shall** be 3 in. x 33 in. at fire-rated doors and 6 in. x  
32 33 in. at other doors. Locate light 10 in. from strike side of door and bottom of light 3-4  
33 ft. above finish floor. Glazing kits **shall** be (concealed type) flush with door surface.

34

35

**EXECUTION**

- 36  **DOOR LAYOUT:** It is recommended for exterior, main entrance doors to be multiple  
37 single doors swinging in the same direction. **Do not** use double doors.

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
**DESIGN GUIDELINES**  
6 May 1992

- 1  WOOD DOORS: **Do not** hang doors until the building is enclosed, the permanent heating  
2 and cooling systems are in operation and residual moisture from plaster, concrete,  
3 masonry or terrazzo work has dissipated.

4

5

**END OF SECTION**

1

2 **SECTION 08300 - SPECIAL DOORS**

3

4 **GENERAL**

5  Overhead roll-up doors and grilles are acceptable to limit access to certain areas of the  
6 facility but **shall not** interfere with required egress from occupied spaces. All  
7 overhead doors and grilles **shall** be of metal construction.

8  Dish return at cafeterias **shall** be stainless steel overhead roll-up door.

9  Exterior sliding glass doors **shall not** be used.

10

11

**END OF SECTION**

1

2 **SECTION 08400 - ALUMINUM ENTRANCES**

3

4 **GENERAL**

5  Aluminum entrance systems **shall not** be used.

6

7

**END OF SECTION**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34

**SECTION 08500 - METAL WINDOWS**

**GENERAL**

- Exterior window and window-wall construction **shall** be insulating glass in aluminum frames with the exception of sidelights and transoms adjacent to entrance doors where hollow metal frames may be used. Windows at classrooms and other occupied spaces **shall** include operable sections. Single hung is the preferred operable window type. Sliding windows are acceptable. **Do not** use casement or projecting windows. Crank or gear driven operable sash windows **shall not** be used.
- Sill height and window size should consider size of students. Large sizes of glass are discouraged. There **shall not** be any special, complex glass designs.
- A horizontal frame approximately 30 in. above finish floor **shall** be provided at sidelights to guard students against walking into glass.
- Vandal resistant systems **shall** be used. (See Section 08800-1 line 8)

**PRODUCTS**

- WINDOWS:** **shall** be commercial grade type fabricated from aluminum extrusions of not less than 0.062 in. thickness for main frame and sash thickness. Thermal break construction **shall** be used. Single hung windows **shall** have tilt-in sash with cam latch lock. Use aluminum, non-magnetic stainless steel or epoxy adhesive fasteners. Frame finish **shall** be either natural satin anodized finish, color-anodized finish or fluoropolymer Kynar 500 color coating. Finish of flashing, trim and exposed fasteners **shall** match frame finish.
- GLAZING:** See Section 08800.
- STOOLS:** A non-absorbent, easily cleanable surface **shall** be provided at windowsills. Mechanically anchored slate and polymer stools are acceptable. Wood, plastic laminate, metal and concrete masonry unit stools **shall not** be used.

**EXECUTION**

- WINDOWS:** Use interior glazing stops.
- Install according to manufacturer's recommendations.

**END OF SECTION**



1  
2 **SECTION 08710 - FINISH HARDWARE**

3  
4 **GENERAL**

- 5  Occupant life safety and durable low maintenance product quality and installation are key  
6 considerations to be used in the design and selection of Finish Hardware. In this regard,  
7 Wake County Public School System has decided to require use of heavy-duty hardware  
8 such as mortise locksets, the installation of magnetic holders at interior high traffic fire  
9 doors and the use of multiple single doors in lieu of double exterior doors. Also, in order  
10 to standardize and better maintain installation on a school system basis, a single  
11 manufacturer is preferred for lock cylinders, panic devices, door closers and key cabinets.
- 12  An add alternate for single source manufacturers for Best Cylinders, LCN Door Closers,  
13 Lund Key Cabinets, and Von Duprin Exit Devices, **shall** be incorporated on the bid form  
14 for each project.
- 15  Hardware schedule must be prepared and included in the specifications. Hardware **shall**  
16 **not** be included in documents as an allowance. The specifications **shall** include a cross-  
17 index showing numerical listing of door numbers and the associated hardware sets. The  
18 contractor **shall** include a similar cross-index in their submittal.
- 19  Design Consultant to certify that the correct hardware is installed properly.
- 20  At wood doors, through bolts **shall** be used for attachment of closers, overhead holders  
21 and exit devices.
- 22  Hardware supplier **shall** have a permanent office staffed with permanent employees  
23 located within 120 miles of Wake County Public School's Rock Quarry Road Service  
24 Center  
25

26 **PRODUCTS**

- 27  **MATERIALS AND FINISHES:** Generally finish hardware **shall** be of non-ferrous  
28 construction with plated finish; interior door hinges **shall** be steel with plated finish  
29 except at areas subject to excessive moisture or chemical corrosion such as shower rooms  
30 or laboratories where stainless steel hinges are required. Exterior doors **shall** have  
31 stainless steel hinges (US32D). Standard finish for all hardware **shall** be US26D (dull  
32 chrome).
- 33  **PANIC DEVICES:** Preferred device **shall** be Von-Duprin #99 series rim. At exterior  
34 doors, devices **shall** be "dogged-in" for push-pull door operation during school hours with  
35 ANSI 03NL "night latch" operation for night time entrance doors and 02 lockset  
36 operation at night time "exit only" doors. Dogging device **shall** be operated by an Allen  
37 wrench not a key. Function of device at fire-rated doors **shall** be 08L with dogging  
38 feature omitted and supplied with break-away trim #994L. Fire rated double doors with  
39 smoke closers **shall** be equipped with concealed vertical rod exit devices. Preferred  
40 device is the Von Duprin #9948 series. Other acceptable bids from manufacturers are  
41 Sargent exit devices #19-HC8804 series and (labeled) 12-19-HC8843 series; and Precision  
42 exit devices #DL-1103 X 17 X 1123-38 X 810-84 and (labeled) DL1108 X V39L X  
43 1123-38 X 810-84.
- 44  At exterior doors to single classrooms, it is preferred that the Von Duprin #22NL series  
45 rim device be used in lieu of the #99 series.

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
March, 1999

- 1     The centercase on all exit devices must be through bolted to the outside trim (pull) and  
2    the hinge end **shall** be through bolted.
- 3     LOCK AND LATCH SETS: **shall** be heavy-duty mortise locksets at all areas  
4    predominantly used by students. Exposed screws in knobs and/or rose are not acceptable.
- 5     LOCK CYLINDERS: It is preferred that cylinders be manufactured by "Best" on new  
6    projects. Other acceptable manufacturers are "Falcon" and "Sargent". Match existing  
7    cylinders on renovation/addition projects. The same manufacturer **shall** supply both  
8    cores and cylinders.
- 9     DOOR KEYING: **shall** be grandmaster keyed. Key to existing system on  
10    renovation/addition projects. All keying must be approved by the Owner before  
11    cylinders/locks are ordered during a keying conference. The contractor **shall** furnish the  
12    Owner with final bitting list on all projects. **Use** only one keyway per school and each  
13    keyway must be exhausted before using another. On new projects, locksets **shall** be  
14    provided with construction keying. Owner **shall** install permanent cores at substantial  
15    completion. All keys **shall** be stamped with appropriate key symbols and "DO NOT  
16    DUPLICATE." No bitting numbers are to be stamped on the key.
- 17     KEY CABINET: It is preferred that cabinets be Lund. Other acceptable manufacturers  
18    are MMF Industries, Tel-Kee and P.O. Moore Company. Size of cabinet **shall** provide  
19    for 50% expansion capacity.
- 20     KEY BOX: Each facility **shall** have a Knox Series 4400RDL Key Lock Box installed on  
21    the exterior of the building near the main mechanical room. This box **shall** be keyed to  
22    the Wake County Public School System standard maintained by The Knox Company,  
23    17672 Armstrong, Irvine, California, 92714. Phone 1-800-552-5669. In addition, a  
24    "Lock Box" **shall** be provided at the front entrance as required by the various fire  
25    departments in the county.
- 26     SURFACE CLOSERS: At interior doors, **use** overhead surface mounted closers, LCN  
27    4040 Super Smoothee series are preferred. Closers **shall** be mounted on inside of  
28    building. Provide parallel arm, EDA type, and/or hold open type where use dictates.  
29    Where "stop" is part of arm bracket, **use** "spring cush" arm mounted at maximum  
30    possible swing. The only acceptable bid from another manufacturer is Sargent closer  
31    #250 X HD Forged Arm X SRI.
- 32     OVERHEAD CONCEALED CLOSERS: Where required to be concealed on main exterior  
33    doors, **use** heavy duty concealed LCN 2010 series closers. Attach arm to door with  
34    through-bolts.
- 35     SMOKE CLOSERS: At interior high-traffic fire doors such as stairwells, horizontal exit  
36    door and corridor smoke doors, **use** wall mounted magnetic hold open device which  
37    release upon detection of smoke. Chains or other extension devices **shall not** be used.
- 38     HINGES: **shall** be full mortise, 5-knuckle type with ball bearings. **Use** heavy-duty hinges  
39    with non-removable pins at exterior doors.
- 40     FLUSH BOLTS: are recommended for use at foot and head of inactive leaf of double  
41    doors to unoccupied areas such as storage and equipment rooms. Bolts **shall** be mortise  
42    type **not** surface mounted.
- 43     FLOOR AND WALL STOPS: **Use** concealed fasteners. Wall stops are preferred  
44    wherever feasible. Reinforce gypsum wallboard partitions with wood blocking at wall stop  
45    locations.
- 46     OVERHEAD HOLDERS: When necessary holders should be surface mounted type with  
47    shock absorber.
- 48     KICK PLATES: High pressure plastic laminate plates with beveled edges are  
49    recommended for the push sides of all high traffic doors with closers, except for plates at  
50    kitchen areas which **shall** be stainless steel and be extended to half door height. **Be sure**

1 door manufacturer specification is approved for use of armor plates over 16 in. high if  
2 labeled opening. Door must be tested for half door height plates.

- 3  DOOR SILENCERS: **shall** be gray rubber and suitable for wood or metal jamb.  
4

5 **EXECUTION**

- 6  LOCKSETS: Privacy locksets **shall** be provided at individual faculty and student toilet  
7 rooms. These locksets **shall** release upon turn of knob from inside and have an  
8 emergency release feature on outside, except doors opening into traffic corridors. These  
9 doors require hotel function with indicator button.

- 10  ROOM NUMBERING: For new school projects, the architect **shall** provide permanent  
11 room numbering system for door keying and signage. At renovation/addition projects the  
12 Owner **shall** provide the room numbering system.

- 13  CLOSERS: **shall** be provided at fire doors (unless otherwise excepted by code  
14 requirements), exterior doors, general office doors to lobby/corridor areas, and kitchen  
15 toilet doors.

- 16  MULLIONS: **Use** removable mullions where required to provide 6 ft. wide service access  
17 to a building's lobby corridor system.

- 18  STOPS: Detail doors and frames to swing doors maximum degree possible. Heavy duty  
19 wall stops and floor stops (where they are not a tripping hazard) are preferred. Where  
20 possible, set stops to provide a minimum 105 deg. door swing. The minimum door swing  
21 opening **shall** be 95 deg.. Floor and wall stops **shall** be located a minimum of 3/4 width  
22 of door from hinge side.

- 23  KICK PLATES: **shall** be installed only at push side of doors with closers. At cafeteria  
24 service doors the stainless steel kickplate **shall** be extended to half door height and  
25 installed at both sides. If labeled door, be sure door manufacturer is approved for half-  
26 door height armor plate.

- 27  DOOR SILENCERS: **shall** be provided at each door. Install three (3) at single doors up  
28 to  
29 7 ft.-2 in. high, four (4) at single doors over 7 ft.-2 in. and two (2) at each pair of doors.  
30

31 **END OF SECTION**

1

2 **SECTION 08800 - GLAZING**

3

4

**general**

- 5  Insulating glass **shall** be installed at exterior windows. It is recommended solar tinted or  
6 low "E" glass be used at exterior glass at east, west, and unprotected south facing windows.  
7 Tempered or wire glass **shall** be installed at and adjacent to doors as required by the NC  
8 State Building Code. It is recommended interior glazing 6 ft. or less above the finish floor  
9 and exterior glazing 6 ft. or less above walkway surfaces be tempered or wire glass. The use  
10 of polycarbonate in lieu of glass for the exterior pane should be explored.

11

12

**END OF SECTION**

1

2 **SECTION 09200 - GYPSUM PLASTER**

3

4 **GENERAL**

5  STANDARDS: Comply with ASTM C 841 and C 842.

6  **Do not** use exterior portland cement/plaster or stucco.

7  Toilet room ceilings **shall** be gypsum board or plaster, unless directed otherwise.

8

9 **EXECUTION**

10  PRECAUTIONS: Maintain a temperature of at least 55 deg. F. in all spaces to be  
11 plastered for seven (7) days before start of plastering and until the gypsum plaster is dry.

12

13

**END OF SECTION**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28

**SECTION 09250 - GYPSUM WALLBOARD**

**GENERAL**

- GYPSUM BOARD STANDARD: Comply with applicable requirements of ANSI/ASTM C 840 for application and finishing of gypsum board, unless otherwise indicated.
- STEEL FRAMING STANDARD: Comply with applicable requirements of ASTM C 754 for installation of steel framing for gypsum board.
- Confine use of gypsum board faced partitions to administration and Student Support areas. All gypsum board partitions in these areas **shall** be covered with a vinyl wallcovering (See Section 09720-1) Principals', Assistant Principals', Student Support Services' offices and all conference rooms **shall** be constructed to minimize sound transmission.

**PRODUCTS**

- STEEL FRAMING: Partitions and ceilings **shall** comply with ASTM C 754.
- GYPSUM BOARD: Provide gypsum board of types indicated in maximum lengths available to minimize end joints:

**EXECUTION**

- PRECAUTIONS: In cold weather and during gypsum wallboard joint finishing, maintain temperature within the range of 55 to 70 deg. F. Adequate ventilation **shall** be provided to carry off excess moisture.
- INSTALLATION: Install steel framing to comply with ASTM C 754 and ASTM C 840.
- GYPSUM BOARD INSTALLATION: Install and finish gypsum board to comply with ASTM C 840.

**END OF SECTION**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33

**SECTION 09300 - TILE WORK**

**GENERAL**

- STANDARDS: Comply with ANSI A13.1 Standard Specification for Ceramic Tile and ANSI 108 series of tile installation standards included under "American National Standard Specifications for the Installation of Ceramic Tile".

**PRODUCTS**

- GROUT: For ceramic and quarry tile flooring, dark color grout is required.
- MARBLE THRESHOLDS: **shall** be provided at doorways of toilet rooms.
- QUARRY TILE: Flashed color ranges are recommended. A medium color such as Putty or Sand is preferred over darker colors such as Red or Brick Slip resistance is of utmost importance in cafeteria kitchens. The use of tile with raised treads to achieve this slip resistance has been used in the past with minimal negative side effects. The Owner is willing to consider any product that will provide the necessary safety while providing for easy cleaning.
- VCT: **Do not** use solid colors nor very light or dark colors for floor installations.
- Metal transition strips that are mechanically fastened to the sub-floor are required at all tile/VCT transitions to carpet except where there is a marble threshold. Glue down transition strips **shall not** be allowed.

**EXECUTION**

- COLD WEATHER PROTECTION: Maintain a minimum temperature of 50 degrees F. in all spaces where tile will be installed for 7 days before beginning installation of setting bed or tile and until at least a week after setting tile.
- Comply with ANSI A108.1 and A108.4 through A108.10.
- Locate expansion, control, contraction, and isolation joints to comply with recommendations of TCA "Handbook for Ceramic Tile Installation".
- Cover tile flooring until final inspection with heavy Kraft paper or other heavy protective covering to prevent surface damage.

**END OF SECTION**

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
March, 1999

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33

**SECTION 09510 - ACOUSTICAL PANEL CEILINGS**

**GENERAL**

- STANDARDS: Acoustical Ceiling Units: ASTM E 1264. Acoustical Suspension System: ASTM C 635 for materials.
- SURFACE BURNING CHARACTERISTICS: 25 or less for flame spread and 50 or less for smoke developed, per ASTM E 84.
- MAINTENANCE STOCK: At time of completing installation, deliver stock of maintenance material to Owner. Furnish amount equal to 2% of acoustical units installed.

**PRODUCTS**

- ACOUSTICAL PANELS: Provide manufacturer's standard lay-in panels, 24 in. x 24 in. grid-size panels, with white finish. 24 in. x 48 in. panels **shall not** be used.
- HUMIDITY RESISTANT PANELS: Provide for high humidity areas such as Kitchens, Dishwashing areas, etc.
- ABUSE RESISTANT PANELS: Provide (along with hold down clips) at areas where damage might be expected, such as Elementary School Multi-Purpose Rooms.
- PANELS: 3/4 in. thickness cane or wood fiber panels are acceptable in corridors and multi-purpose rooms. **Do not** use soft acoustical panels at low ceiling installations.
- Specify 65% recycled materials in ceiling panels where possible.
- Specify products free of formaldehyde in binders.

**EXECUTION**

- PRECAUTIONS: **Do not** install acoustical tile or panels until the building is enclosed, the permanent heating and cooling equipment is in operation and residual moisture from plaster, concrete, or terrazzo work has dissipated.
- INSTALLATION: Install acoustical ceiling systems in accordance with CISCA "Ceiling Systems Handbook".
- Do not** support fixtures or equipment such as exit lights, speakers, etc. from the ceiling system.

**END OF SECTION**

1  
2 **SECTION 09550 - WOOD FLOORING**

3  
4 **PRODUCTS**

- 5  
6  **STAGE FLOORING:** Manufacturer's standard straight edge, tongue and groove and end-  
7 matched solid wood flooring, 1 in. thick x 2-1/8 in. or 2-1/4 in. strips in standard random  
8 lengths. At high and middle schools **use** Southern Pine, C and Better Flooring, near-rift  
9 grain with flat black, exterior grade latex paint finish. At elementary schools **use** plain  
10 sawn No. 1 common Red Oak or plain sawn, MFMA certified second and better grade,  
11 Northern Hard Maple with transparent polyurethane finish.
- 12  **ATHLETIC FLOORING:** At high and middle schools **use** manufacturer's standard  
13 straight edge tongue and groove end matched solid wood flooring. The strips should  
14 measure 25/32 in. thick x 2-1/4 in. wide x 2 ft. minimum length and averaging 4 ft.-6 in.  
15 long. Specify either double channeled base, plain sawn No. 1 common Red Oak, or plain  
16 sawn, MFMA certified second and better grade, Northern Hard Maple with transparent  
17 polyurethane finish. Floor to be DIN approved.
- 18  **TRANSPARENT POLYURETHANE FINISH:** **shall** be a polyurethane co-polymer with  
19 the following characteristics:  
20 Solids 42%  
21 Volatile Contents 58%  
22 Carrier: De-sulferized Aliphatic solvent  
23 Application rate: 350 - 400 square feet per gallon.

24  
25 **EXECUTION**

- 26  **PRECAUTIONS:** **Do not** install wood flooring until the building is enclosed, the  
27 permanent heating and cooling system is in operation, and residual moisture from plaster,  
28 concrete, masonry or terrazzo has dissipated.
- 29  **PROTECTION:** Protect completed wood flooring during remainder of construction  
30 period with heavy Kraft paper or other suitable covering, so that flooring and finish will  
31 be without damage or deterioration at time of acceptance.
- 32  **TRANSPARENT POLYURETHANE FINISH:** **shall** be installed in the following  
33 manner:  
34 .1. Prepare floor  
35 2. Apply one (1) coat floor seal  
36 3. Paint all lines using oil base quick dry enamel (2 coats)  
37 4. Apply one (1) coat floor seal  
38 5. Cut floor w/#3 steel wool  
39 6. Apply one (1) coat floor seal  
40 7. Cut floor w/#3 steel wool  
41 8. Buff

42  
43 **END OF SECTION**

1  
2 **SECTION 09650 - RESILIENT FLOORING**  
3

4 **GENERAL**

- 5  This section includes information for specifying resilient tile flooring and wall base.  
6  Preferred type of tile flooring is Vinyl Composition Tile (VCT). Other acceptable types  
7 of tile flooring are Asphalt Tile, Rubber Tile and Vinyl Tile.  
8  Acceptable types of wall base are Rubber Cove or Straight Base or Vinyl Cove or Straight  
9 Base. Cove base is to be used with resilient tile flooring and straight base is to be used  
10 with carpet. Installer **shall use** maximum lengths available to minimize joints and **shall**  
11 install preformed or molded corner units at 90 deg. intersections.  
12  For each type of product required, including adhesives, cleaning compounds, and other  
13 accessories, provide the same product by one manufacturer throughout the project and  
14 specify that all products have low VOC's.

15  
16 **PRODUCTS**

- 17  For vinyl composition tile, premium product lines of the following manufacturers,  
18 provided they comply with requirements of the contract documents and have a low VOC,  
19 **will be considered acceptable:**  
20 1. Armstrong World Industries, Inc.  
21 2. Mannington Commercial  
22 3. Tarkett  
23 4. Equal as approved by Architect.  
24  Any tile specified **shall** be free of asbestos and 1/8 in. gage.  
25  For wall base, products of the following manufacturers, provided they comply with  
26 requirements of the contract documents and have a low VOC, **will be considered**  
27 **acceptable:**  
28 1. Burke Industries, Inc.  
29 2. Flexco Company  
30 3. Johnsonite, Inc.  
31 4. The R.C. Musson Rubber Company  
32 5. Roppe Corporation  
33 6. Equal as approved by Architect.

34  
35 **EXECUTION**

- 36  A manufacturer's recommended moisture test **shall** be performed prior to installation of  
37 resilient flooring, to verify that concrete surfaces have cured sufficiently for proper  
38 adhesive bond to be achieved between the sub floor and the resilient tile.  
39  Ventilate areas thoroughly during and after installation prior to occupancy.  
40  Resilient edge strips **shall** be used in locations shown on drawings, or where otherwise  
41 required, to protect edge of resilient flooring. Install resilient edge strips securely with  
42 recommended adhesive to achieve a tightly butted joint.  
43  When an edge strip is needed at a transition between carpet and tile flooring, it **shall** be  
44 specified as a metal edge strip and installed per manufacturers specification, securing it to  
45 the sub floor using mechanical fasteners and not adhesives.  
46  
47  When using floor tile on a ramp within a building, a non-skid tile should be used and **shall**  
48 meet all handicap codes.  
49

50 **END OF SECTION**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39

## SECTION 09680 - CARPET

### GENERAL

- Manufacturer's Certification: Carpet materials **shall** comply with "Use of Materials Bulletin UM-44C" published by US Department of Housing and Urban Development (HUD) and are currently listed in HUD "Certified Products Directory" and so identified by imprint on back of carpet.
- A seaming diagram for carpet installation should be submitted for approval by Wake County Public System when finishes are submitted.

### PRODUCTS

- CARPET: Class III, tufted, commercial carpet, type 6.6 nylon, face weight: 28 oz./yd., minimum total weight: 61 oz./yd., unitary backing, 20 pound tuft bind, multi-level loop pile, permanent anti-static control, solution dyed, tweed pattern and bacteria protection preferred. Use of "pattern match" should be avoided.
- ATHLETIC CARPET: **shall** be Collins & Aikman "PROGYM" or equal and used for athletic flooring at elementary schools.
- WALL BASE-RUBBER: Acceptable manufacturer's list in Section 09650
- COMPOUNDS AND ADHESIVES: Formulated specifically for the application of the specified floor covering and **shall** be applied according to manufacturer's recommendations. Environmentally safe, low odor adhesives required.
- Metal reducer strips that are mechanically fastened to the sub floor are required at all tile/VCT transitions to carpet except where there is a marble threshold. Glue down reducer strips **shall not** be allowed.

### EXECUTION

- PRECAUTIONS: **Do not** install carpet until the building is enclosed, permanent heating and cooling systems are in operation and residual moisture from plaster, concrete, or terrazzo work has dissipated.
- Specifications **shall** require moisture test prior to installation of adhesives and reference manufacturer's recommendations regarding moisture content.
- Require submittal and approval of seaming diagram by Wake County Public School System when finishes are submitted.
- Seam sealer is required at all seams.
- No saddle or T-seams **shall** be allowed in doorways or high traffic areas.
- Ventilate thoroughly all areas during and after installation, prior to occupancy.

END OF SECTION

1  
2 **SECTION 09720 – WALLCOVERING**  
3

4 **GENERAL**

- 5  Wall covering **shall** be treated with mildew inhibitor and germicide, with minimum total  
6 weight and minimum coating weight specified in FS CCC-W-408A for vinyl wall covering  
7 type indicated, and complying with FS CCC-W-408C for other requirements. It **shall**  
8 also be required to carry a Class A fire rating. Provide materials bearing UL label and  
9 marking, indicating compliance with fire hazard classification requirements.
- 10  Type II wall-covering which has a total weight of not less than 13 oz./sq. yd. and a vinyl  
11 coating of not less than 7 oz./sq. yd. **shall** be specified where wall covering is required.
- 12  Provide 54 in. wide material with Onasburg backing.
- 13  Colors and patterns for wall coverings **will** be selected from manufacturers' standards  
14 after contract award.
- 15  An installer specializing in wall covering work with not less than 5 years of experience in  
16 installing wall coverings similar to those specified on project **shall** be required.  
17

18 **PRODUCTS**

- 19  The following manufacturers, provided they comply with requirements of the contract  
20 documents and manufacture using low VOC's, **will** be among those considered acceptable:  
21 1. Koroseal Wall Covering Division/RFG International  
22 2. The Arton Group  
23 3. Genon Wallcovering Division  
24 4. Equal as approved by Architect.
- 25  Provide low VOC adhesives and sealers recommended specifically by manufacturer of wall  
26 covering specified for use on scheduled substrates and certified to be mildew resistant and  
27 nonstaining to wall covering.
- 28  Surface sealer for gypsum wallboard substrates, formulated to permit removal of wall  
29 covering without damage to wallboard, **shall** be used on all gypsum wallboard substrates  
30 scheduled to receive vinyl wall covering. Specify only those products that emit low  
31 VOC's.  
32

33 **EXECUTION**

- 34  Materials **shall** be stored under cover in original undamaged packages or containers. **Do**  
35 **not** store rolled goods in upright position. Maintain temperature in storage area above  
36 40 deg. F. and below 90 deg. F. It **shall** be required that wall-covering materials be  
37 removed from packaging and placed in area of installation not less than 24 hours before  
38 commencing installation to climatize product to the environment in which it is to be  
39 installed.
- 40  Electrical cover plates and other surface-mounted fixtures in areas to receive wall  
41 coverings **shall** be removed temporarily during wall covering and reinstalled when wall  
42 covering is complete.
- 43  Nicks, scratches, and other surface irregularities **shall** be patched in gypsum wallboard  
44 substrates with latex filler before wall covering is installed. Sand filler smooth and flush  
45 with substrate and wipe with tack cloth.
- 46  Require substrates to be primed and sealed in accordance with wall covering  
47 manufacturer's recommendations and apply release coat.
- 48  Substrates **shall** be tested with electronic moisture meter to verify that moisture content  
49 does not exceed limits recommended by manufacturer of wall covering.

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
**DESIGN GUIDELINES**  
6 May 1992

- 1  Wall covering **shall** be installed in accordance with manufacturer's instructions, except
- 2 where more stringent requirements are shown or specified, and except where project
- 3 conditions require extra precautions or provisions to ensure satisfactory performance of
- 4 work.
- 5  Seams **shall not** occur within 4 in. of corners or major openings. Trim wall covering
- 6 carefully at electrical boxes and other interruptions to avoid gaps and necessity for
- 7 patches.
- 8  Outside corners of wall covering **shall** be designed with protective trim moldings where
- 9 exposed to medium or heavy traffic patterns.

10  
11 **END OF SCHEDULE**

12 **SECTION 09900 - PAINTING**

13  
14 **GENERAL**

- 15  **SINGLE SOURCE RESPONSIBILITY:** Provide primers and undercoat paint produced by
- 16 the same manufacturer as the finish coats.

17  
18 **PRODUCTS**

- 19  **PAINT:** **shall** have a reflective value of 60-80%. At wall surfaces **use** semi-gloss paint.
- 20 Provide finish in high traffic areas that can be scrubbed.
- 21  Except in toilet areas, specify waterbased solvent and mercury free paint with low or zero
- 22 VOC's.
- 23  Provide epoxy finishes in toilet areas.
- 24  Limit number of paint colors to available standards. Avoid blends and coordinate colors
- 25 to enhance school spirit.
- 26  **BLOCK FILLER:** **shall** be applied to all exposed masonry block. Specify products with
- 27 low or zero VOC's.
- 28  Filler in Kitchen and Dishwasher areas **shall** completely fill block pours to eliminate
- 29 pinholes in painted finish and **shall** be approved by Health Department inspector before
- 30 application of finish paint.

31  
32 **EXECUTION**

- 33  **COLOR SCHEMES:** Avoid sophisticated color schemes. Limit paint colors to two (2)
- 34 per wall surface.
- 35  **STORAGE:** Store unused materials in tightly covered containers in a well-ventilated area
- 36 at a minimum ambient temperature of 45 deg. F. Protect from freezing.
- 37  **PROJECT CONDITIONS:** **Do not** apply paint in snow, rain, fog or mist, nor if air,
- 38 surface, or paint material temperatures are below 50 deg. F. nor when relative humidity
- 39 exceeds 85% nor when temperature is less than 5 deg. F. above the dew point. **Do not**
- 40 apply paint to damp or wet surfaces. Maintain a temperature of 50 deg. F. for a period of
- 41 24 hours before beginning interior painting and for at least 24 hours after last
- 42 application.

43  
44 **END OF SCHEDULE'**

45 **SECTION 10110 - DRY ERASE BOARDS & TACKBOARDS**

46  
47 **GENERAL**

- 48  Dry erase boards and tackboards **shall** be provided in accordance with the building
- 49 program for each specific project. Attention to the constraints of applicable codes
- 50 governing the use of combustible materials is required. Please see Appendix 10110-A.

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
March, 1999

1 **PRODUCTS**

- 2  **DRY ERASE BOARDS:** shall have 24 gauge porcelain enamel steel face with backer  
3 board in extruded aluminum frame with marker tray and head tackstrip. Finish shall be  
4 manufacturer's standard glossy white. Core shall be at least 7/16 in. thick particleboard  
5 material backed by either foil or aluminum for moisture seal.
- 6  **TACKBOARDS:** shall be 1/4 in. thick composition cork mounted to 1/4 in. hardboard in  
7 extruded aluminum frame. The composition corkboard shall be made of pure cork  
8 material compounded with linseed oil and pigment on a burlap back.
- 9  **TACKSTRIPS:** shall be 1/4 in. thick composition cork in extruded aluminum frame.  
10 Width of tackstrip shall be 1 in. at dry erase board installations and 2 in. elsewhere. Map  
11 hooks and flag holders shall be provided at all tackstrip installations including at head of  
12 dry erase boards. Provide two (2) flag holders per room. At art rooms, hooks shall also  
13 be provided.
- 14  **PEGBOARDS:** shall be 1/4 in. hardboard with 9/32 in. diameter holes on 1 in. centers in  
15 extruded aluminum frame.
- 16  **ACCESSORIES:** Furnish standard continuous box-type aluminum markertray with slanted  
17 front and cast aluminum end closures for each dry erase board. Where specified in  
18 program, furnish map rail complete with 1 in. to 2 in. wide display rail, end stops, and 2  
19 map hooks for each 4 feet of rail.
- 20  All products shall have a 50 year warranty.

21  
22 **EXECUTION**

- 23  All dry erase board, tackboard, tackstrip and pegboard units shall be factory assembled.
- 24  Size, location and mounting height of dry erase boards, tackboards and tackstrips shall be  
25 according to building program requirements. Bottom of boards shall be no more than 34  
26 in. from finished floor.
- 27  At physical activity spaces such as dance studios, gyms, and multi-purpose rooms, do not  
28 provide protruding chalk trays at dry erase board installations. Instead, provide recessed  
29 holders for markers and erasers.

30  
31 **END OF SECTION**

1  
2                   **ATTACHMENT 10110-A - DRY ERASE BOARD AND TACKBOARD**  
3

4                   **PRODUCTS**

- 5                    Porcelain Steel Dry Erase Board  
6                    Tackboard  
7

8                   **ACCEPTABLE MANUFACTURERS**

- 9                   1. American Chalkboard Co.  
10                  2. Best Rite  
11                  3. Claridge  
12                  4. Lemco, Inc.  
13                  5. Nelson/Adams (NACO)  
14

15                  **WARRANTY**

- 16                   Lifetime Guarantee under conditions of normal use. Should not exhibit excessive fading  
17                      of color, crazing, cracking or flaking.  
18

19                  **MATERIALS**

- 20                   Porcelain Steel Dry Erase Board: Provide balanced, high pressure-laminated porcelain  
21                      enamel dry erase boards of 3-ply construction consisting of face sheet, core material and  
22                      backing.  
23

- 24                  1. Face sheet: **shall** be 24 or 28 gauge porcelain, enamel steel with magnetic, non-  
25                      porous surface. Should wipe clean with an eraser or dry cloth.

26                      Also:

- 27                      ▪ Deposition coat of 2.0 to 2.5 mils on front of steel.  
28                      ▪ Deposition coat of 1.5 to 2.0 mils on back of steel.  
29                      ▪ Porcelain enamel steel writing and erasing coat system, totaling 3.5 to 4.5 mils  
30                      over front surface.  
31                      ▪ Firing temperature must be no less than 1500 deg. F.  
32                      ▪ Hardness of writing surface **shall** be uniform in color and texture.  
33                      ▪ Reflectance factor **shall** be no more than 20% or less than 15%, nor vary as a  
34                      result of wear.  
35                      ▪ Writing surface **shall** be no less than 6.5 MOH's scale.  
36                      ▪ Color: White  
37

- 38                  2. Core: Provide 1/2 in. thick, industrial grade, particle-board or fiberboard core material  
39                      with zero VOC's. (Fiberboard is lighter in weight and preferable.)  
40

- 41                  3. Backing Sheet: (.015 in. aluminum sheet vapor barrier.) Moisture retardant,  
42                      laminated with suitable, low VOC emitting adhesive to prevent delamination.  
43                      Lamination of all materials to be factory type only, with special formulated  
44                      adhesives. Hand lamination is **not** acceptable  
45

- 46                   Tackboard: Seamless sheet, 1/4 in. thick ground natural cork compressed with linseed oil  
47                      and integral color throughout, laminated to burlap backing. Factory laminate cork face  
48                      sheet under pressure to 1/4 in. thick hardboard in extruded aluminum frame.  
49

49                  **ACCESSORIES**

- 50                   Metal Trim and Accessories: Fabricate frames and trim of not less than 0.062 in. thick  
51                      aluminum alloy, size and shape as indicated, to suite type of installation. Provide straight

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
**DESIGN GUIDELINES**  
March, 1999

- 1 factory-applied trim, single-length units whenever possible. Keep joints to a minimum.  
2 Miter corners to a neat, hairline closure.  
3  
4 1. Markertray: Furnish manufacturer's standard snap-on, continuous box-type, extruded  
5 aluminum chalktray with end caps and angled bottom support. 1-3/4 in. to 2 in.  
6 frame.  
7  
8 2. Map Rail: Where specified on drawings furnish map rail at top of each unit, complete  
9 with the following accessories:  
10 a. Display Rail: Provide continuous cork display rail approximately 1 to 2 in.  
11 wide, integral with map rail at top of board.  
12 b. End Stops: Provide one end stop at each end of map rail.  
13 c. Map Hooks: Provide two (2) map hooks with flexible metal clips for each 4  
14 ft. of map rail or fraction thereof.  
15 d. Flag Holders: Provide two (2) per room.

16 **END OF SECTION**  
17

1  
2 **SECTION 10155 - TOILET PARTITIONS**  
3

4 **GENERAL**

- 5  Durable, low maintenance product quality and installation is the primary consideration in  
6 the design of toilet room partitions. In this regard, the Wake County Public School has  
7 decided to require the use of floor mounted, overhead braced compartments with heavy  
8 duty, institutional hardware.  
9

10 **PRODUCTS**

- 11  TOILET PARTITIONS: **shall** be of floor mounted, overhead braced, solid polymer resin  
12 partitions at all group toilet installations. Doors **shall** match compartment  
13 construction. Use light, not dark colors. Small patterned finish is preferred. Metal toilet  
14 partitions **shall not** be used.  
15  HARDWARE AND FITTINGS: **shall** be heavy-duty extruded aluminum construction  
16 with bright finish. Door hinges **shall** be self closing (integral) at all locations.  
17 Continuous wall brackets **shall** be used at group toilets. Use "through-bolts" (threaded  
18 insert with vandal resistant bolt at both sides) to secure hinges, brackets, stops and latches  
19 to doors and partitions. Provide vinyl bumper strip to absorb impact at doorstops and  
20 latch. Use of polymer hinges, wall brackets, and base at solid polymer resin partitions are  
21 acceptable.  
22

23 **INSTALLATION**

- 24  TOILET PARTITIONS: **shall** be secured with vandal resistant stainless steel machine  
25 screws with expansion anchors at masonry and tile walls and with toggle bolts at hollow  
26 walls and expansion anchors at other walls. Pilasters **shall** be secured to floor with a  
27 minimum of two #14-1.5 in. Stainless Steel screws with expansion anchors. Provide  
28 stainless steel or polymer resin base trim to conceal floor anchorage and leveling devices.  
29  COMPARTMENT DOORS: **shall** be provided at all compartments.  
30  URINAL SCREENS: If required, **shall** be provided between adjacent urinals and where  
31 located next to lavatories. These screens **shall** be of the same construction as the toilet  
32 partitions and be attached to the wall with solid polymer resin brackets.  
33

34 **END OF SECTION**

1  
2 **SECTION 10426 - IDENTIFYING DEVICES**  
3

4 **GENERAL**

- 5  An exterior sign **shall** be required at main site entrance and main building entrance.  
6 Interior signs **shall** be required at all doors and spaces. Final room names and numbers  
7 will be furnished by the Owner.  
8

9 **PRODUCTS**

- 10  INTERIOR SIGNS: **shall** be manufactured from 1/16 in. clear matte acrylic that is sub-  
11 surface printed with a background color and laminated to a 1/16 in. opaque white or black  
12 acrylic base and has 1/16 in. raised acrylic letters, Andco Series 850-16 or equal. All  
13 signage **shall** comply with Section 4.11, "Signage and Identification" of the NC State  
14 Building Code for Handicapped Accessibility & ADA Standards.  
15

16 **EXECUTION**

- 17  INTERIOR SIGNS: Signage **shall** be sized to accommodate copy. No abbreviations **shall**  
18 be permitted at elementary schools. Abbreviations are strongly discouraged at middle and  
19 high schools.  
20

21 **END OF SECTION**

1  
2 **SECTION 10500 - LOCKERS**  
3

4 **GENERAL**

- 5  Lockers **shall** be recessed in wall construction or have sloping tops and masonry end  
6 walls. Bases **shall** be provided by manufacturer. Use closed "kitchen style" base unless  
7 noted otherwise.  
8

9 **PRODUCTS**

- 10  **STUDENT LOCKERS:** **shall** be of steel construction with baked enamel finish. Doors  
11 **shall** be louvered. Hinges **shall** be steel, full loop, 5 knuckle, tight pin, welded to frame,  
12 screwed to door. Provide a minimum of 3 hinges per door over 42 in. high and 2 hinges  
13 for doors 42 in. high and less. Minimum size for student locker compartments **shall** be  
14 12 in. x 36 in.
- 15  **ATHLETIC LOCKERS:** Similar to student lockers except provide perforated doors at  
16 compartments for gym and athletic clothes.
- 17  **STAFF LOCKERS:** Similar to student lockers except minimum size **shall** be 12 in. x 60  
18 in.
- 19  Provide one (1) master-keyed combination padlock for each locker. Also provide 5%  
20 spare locks.  
21  
22

23 **END OF SECTION**

1  
2 **SECTION 10520 - FIRE EXTINGUISHERS AND CABINETS**

3  
4 **GENERAL**

- 5  Fire Extinguishers **shall** be located as per Project Building Program, as required by local  
6 code officials, and in accordance with the recommendations of NFPA 10, "Standard for  
7 Portable Fire Extinguishers". In areas accessible to students where Fire Extinguishers are  
8 required, cabinets **shall** be provided.  
9

10 **PRODUCTS**

- 11  CABINETS: **shall** be 12 in. x 27 in. x 8 in. for semi-recessed or recessed installation.  
12 Breakable transparent glazing **shall** be scored Plexiglas.  
13  Specify recessed cabinets for all corridor locations. Maintain integrity of all rated walls.  
14  FIRE EXTINGUISHERS: **shall** be supplied by the Owner.  
15

16 **EXECUTION**

- 17  Install cabinets at the heights required by local code officials.  
18  
19

**END OF SECTION**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27

**SECTION 10650 - OPERABLE PARTITIONS**

**GENERAL**

Avoid use of operable partitions wherever possible.

**PRODUCTS**

PARTITIONS: **shall** be manually operated type, 20-lb. maximum pull, where size permits.

SOUND SEAL: **shall** be provided, with an STC rating of 38 or greater.

Avoid the use of sound insulation or coverings that emit VOC's or use formaldehydes in the manufacturing process.

For operable partitions, premium product lines of the following manufacturers, provided they comply with requirements of the contract documents and have a low VOC, **will** be considered acceptable:

1. Hufcore
2. Panelfold
3. Curtition
4. Modernfold

**EXECUTION**

Partitions **shall** be suspended from the structure overhead. Coordinate with structure and partition manufacturer. **Do not** use floor tracks.

Comply with "Standard Recommended Practice for Architectural Application and Installation of Operable Partitions".

**END OF SECTION**



WAKE COUNTY PUBLIC SCHOOL SYSTEM  
**DESIGN GUIDELINES**  
March, 1999

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12

**SECTION 10700 - WINDOW TREATMENTS, STAGE CURTAINS, AND BANNERS**

**GENERAL**

- Window treatments **shall** be provided by the Owner. Allow adequate space at window heads for installation of blinds.
- Curtains/Draperies must be tested in accordance with the large scale tests of NFPA701. Banners, signs, and other decorative items must be tested in accordance with the small scale tests of NFPA701. In addition to a written certificate, all items must have a label permanently attached noting the certification.

**END OF SECTION**

1  
2 **SECTION 10800 -TOILET ACCESSORIES**  
3

4 **GENERAL**

- 5  TOILET ACCESSORIES **will** be surface mounted type unless noted otherwise. Most  
6 accessories will be supplied by the Owner to the Contractor for installation.  
7

8 **PRODUCTS**

- 9  PAPER TOWEL DISPENSERS: **shall** be supplied by the Owner and installed by the  
10 Contractor.  
11  SOAP DISPENSERS: **shall** be supplied by the Owner and installed by the Contractor.  
12  TOILET PAPER HOLDERS: For non-handicapped accessible toilets and stalls **shall** be  
13 supplied by the Owner and installed by the Contractor. These units are "Scott" Model  
14 09672 Jumbo.  
15  TOILET PAPER HOLDERS: For handicapped accessible toilets and stalls **shall** be 2-roll,  
16 heavy duty, controlled delivery type and **shall** be furnished and installed by the  
17 Contractor.  
18  WASTE RECEPTACLE: **shall** be free standing units provided by the Owner.  
19  MIRRORS: **shall** be polished stainless steel at middle & high school student toilet rooms  
20 and framed mirror glass elsewhere.  
21  ROBE HOOK: **shall** be stainless steel with #4 satin finish and concealed attachment.  
22  SANITARY NAPKIN DISPOSAL: **shall** be of stainless steel construction with #4 satin  
23 finish. Provide type for mounting into toilet partitions and for recessed wall mounting.  
24 Contractor to furnish and install.  
25

26 **EXECUTION**

- 27  PAPER TOWEL DISPENSERS: Install one (1) dispenser for every two (2) lavatories;  
28 locate immediately adjacent to lavatories for ease of use.  
29  SOAP DISPENSERS: Locate directly over lavatories.  
30  MIRRORS: Size of mirrors at student toilet rooms to be approximately 18 in. wide x 24  
31 in. high at elementary student toilet rooms and 18 in. wide x 30 in. high elsewhere.  
32 Mirrors **shall** be located on walls away from lavatories. Mirrors at staff toilets may be  
33 located over lavatories. It is desirable to have one 20 in. x 60 in. full-length mirror at  
34 the women's staff toilet rooms.  
35  SANITARY NAPKIN DISPOSAL: **shall** be provided at all women's staff and girl's  
36 middle and high school toilet rooms. Install at each compartment of gang toilet rooms.  
37  ROBE HOOKS: **shall** be provided at individual toilet rooms and at door of all toilet  
38 partition compartments.  
39  Contractor to mechanically fasten paper towel, toilet paper and soap dispensers in place.  
40  Locate all toilet paper dispensers so that toilet stall doors **will not** hit dispensers when  
41 door is opened.  
42  
43

**END OF SECTION**

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
March, 1999

1  
2 **SECTION 11000 - MISCELLANEOUS EQUIPMENT**  
3

4 **GENERAL**

- 5  TV BRACKETS: Brackets **shall** be wall-mounted type. Electrical power and cable to TV  
6 **shall** be extended and connected to nearby outlets mounted in the ceiling tile by the  
7 Electrical Contractor. Cable and connectors to be furnished by Contractor.
- 8  TELEVISIONS: are furnished and installed by the Owner.
- 9  INCINERATORS: **shall not** be used without approval from owner.
- 10  DUST COLLECTOR: **shall** be provided for woodworking shop.
- 11  SOLID WASTE HANDLING EQUIPMENT with discharge into sewage system **shall not**  
12 be used.
- 13  KILN: Kiln room **shall** have one (1) hour rated walls. Locate room adjacent to exterior  
14 wall. Provide kiln hood and roof mounted exhaust fan. Provide 6 in. deep stationary  
15 drainable aluminum louver with motorized damper for make-up air source. Louver to  
16 have 1/2 in. x 1/2 in. screen. Fan and damper to be controlled by wall mounted  
17 thermostat.

18  
19 **END OF SECTION**

1  
2 **SECTION 11400 - FOOD-SERVICE EQUIPMENT**  
3

4 **GENERAL**

- 5  Food-service equipment **shall** be designed to be bid as a part of the prime general  
6 construction contract.  
7  **INSPECTIONS:** Pressure vessels for cooking **shall** be inspected by the N.C. Boiler  
8 Bureau. Refrigeration and air conditioning equipment **shall** be inspected by qualified  
9 inspectors. Contractors **shall** provide certificates of the above inspections.

10  
11 **PRODUCTS**

- 12  **WALK-IN COOLERS AND FREEZERS:** Floors **shall** be approximately the same level as  
13 the Kitchen floor for food cart operation. Provide floor drains near and outside the  
14 cooler and freezer door(s) and run copper drain from evaporator unit to this floor drain.  
15 Locate temperature controls and thermometers on the outside near the cooler and freezer  
16 doors. Temperature setting for the cooler **shall** be 35 deg. F. and temperature for  
17 freezer **shall** be 10 deg. F.  
18  Provide electrical heat strip around freezer door to prevent freeze up of door.  
19  Architect **shall** specify proper shelving, additional lighting and non-slip floor strips to be  
20 provided for all walk-in coolers and freezers.  
21  **FLY FAN:** Provide at all exterior doors from Kitchen area with automatic operation  
22 controlled by a jamb mounted switch.  
23  **FUEL SHUT-OFF:** Provide automatic type, as required by code. Locate valve a  
24 maximum of 6 ft. above finish floor.  
25  **FIRE EXTINGUISHING SYSTEM:** Provide under hood system, as required by code.  
26 Coordinate with mechanical for shutdown of HVAC systems when hood system is  
27 activated and with electrical for notification of fire alarm when hood system is activated.  
28 Locate remote ansul pull station near exterior egress from kitchen. Show location of pull  
29 station on plans.  
30

31 **END OF SECTION**

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
March, 1999

1  
2 **SECTION 11480 - ATHLETIC EQUIPMENT**  
3

4 **GENERAL**

- 5  **GYMNASIUMS:** shall be sized according to the building program. Ceiling heights shall  
6 be 25 ft. clear inside to the bottom of any and all obstructions at high schools and middle  
7 schools.
- 8  **BASKETBALL COURTS:** shall be the following size:
- |                  |                 |                 |
|------------------|-----------------|-----------------|
|                  | Main Courts     | Cross Courts    |
| 9 Middle Schools | 42 ft. x 84 ft. | 42 ft. x 74 ft. |
| 10 High Schools  | 50 ft. x 94 ft. | 50 ft. x 94 ft. |
- 11 Provide 10 ft. overrun on all sides of main court.  
12  
13

14 **PRODUCTS**

- 15  **ACOUSTICAL TREATMENT:** Provide suitable wall and/or ceiling acoustical treatment  
16 at gymnasiums.
- 17  **BASKETBALL BACKSTOPS:** shall be glass for main court, solid for cross-courts. Rims  
18 shall be "breakaway" type. Backstops shall be electrically operated.
- 19  **CEILING CONSTRUCTION:** Exposed structure ceiling is recommended for use.
- 20  **SCOREBOARD:** Wall mounted electronic type, with time-clock, team scores, period,  
21 bonus, jump ball, next possession, and possession. Time clock shall be bi-directional  
22 with ability to directly set any number of minutes and seconds.
- 23  **SOCCER AND FOOTBALL GOAL POSTS:** shall be supplied and installed by  
24 Contractor.
- 25  **VOLLEYBALL AND BADMINTON FLOOR SLEEVES:** Provide floor sleeves for  
26 volleyball at high school and middle school gymnasiums. Sleeves shall be recessed steel  
27 with hinged floor plate. Top of floor plate must be completely encapsulated and shall be  
28 flush with wood floor. Floor plates shall be either solid brass or steel with chrome plated  
29 finish.
- 30  **WALL PADS:** 2 in. thick, polyurethane foam, mounted on 3/8 in. plywood and covered  
31 with heavy duty vinyl covering. Permanently mounted at end walls of basketball courts.  
32 In Auxiliary Gyms, end walls of side courts should also be padded.  
33  
34

**END OF SECTION**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21

**SECTION 11600 - LABORATORY EQUIPMENT AND CASEWORK**

**GENERAL**

(Refer to Section 06410, "Interior Architectural Woodwork" for detailed construction requirements.)

- Contractors **shall** be required to submit samples of transparent wood casework finishes which indicate range of color variation to be expected in finishes.

**PRODUCTS**

- Both built-in and portable casework **shall** work together as a system and **shall** be by the same manufacturer.
- CASEWORK: **shall** be Oak hardwood.
- COUNTERTOPS: **shall** be acid resistant phenolic material similar to lab grade "Trespa." Sinks **shall** be of the same material.
- STUDENT TABLES: Science room two-student desks **shall** have a 1 in. thick top composed of acid resistant phenolic material similar to lab grade "Trespa."
- FITTINGS: **shall** be vandal-resistant.
- HARDWARE: **shall** be heavy-duty, stainless steel.

**END OF SECTION**

1  
2 **SECTION 11970 - STAGE EQUIPMENT**  
3

4 **GENERAL**

- 5  Pipe grid system for lighting **shall** be furnished and installed by the General Contractor.  
6  Maintain adequate clearances between pipe grid and ductwork.  
7

8 **PRODUCTS**

- 9  See Attachment 11970-A for Elementary School stage curtain requirements.  
10  See Attachment 11970-B for Middle School stage curtain requirements.  
11  See Attachment 11970-C for High School stage curtain requirements.  
12  PIPE BATTENS: **shall** be 1-1/2 in. dia., schedule 40 pipe. Provide in Educational  
13 Theaters and in Video Studios.  
14  CURTAINS: In the theater **shall** be "dead hung" from the structure. All curtain fabric  
15 **shall** be 25/50 flame/smoke rated..  
16

17 **END OF SECTION**

1  
2 **ATTACHMENT 11970-A - STAGE EQUIPMENT**  
3 **GUIDE SPECIFICATIONS FOR ELEMENTARY SCHOOLS**  
4

- 5  FRONT STAGE CURTAIN AND VALANCE: Flame resistant 25 oz. Velour (color to be  
6 selected). Curtains to be manufactured with 50% fullness. Panel headings **shall** be box-  
7 pleated and constructed with 2 in. heavy jute webbing with a pleat control system  
8 consisting of 16 gauge flame resistant virgin vinyl pleat control strips with 4 in. brass  
9 grommets placed every 12 in. on center.
- 10  Front curtain panels **shall** have 12 in. leading and 2 in. trailing hems. Bottom hems of  
11 the front curtain panel **shall** be 6 in. Valance hems **shall** be 2 in. on the sides and 3 in.  
12 on the bottom.
- 13  Valance **shall** be constructed with hidden vertical seams i.e. the seams are to fall behind  
14 the pleats.
- 15  CYCLORAMA SYSTEM: **shall** consist of two (2) rear curtain panels, four (4) side  
16 curtain panels and two (2), three (3) or four (4) overhead borders, depending on stage  
17 depth and sight line situation. Curtains **shall** be manufactured with 50% fullness from  
18 flame retardant Atlas Oxford fabric (color to be selected)
- 19  Panel headings **shall** be box-pleated and constructed with 2 in. heavy jute webbing with a  
20 pleat control system as noted in specification for Front Stage Curtain above.
- 21  Side and rear panels **shall** have 2 in. side hems and 4 in. bottom hems. Overhead borders  
22 **shall** have 2 in. side hems and 3 in. bottom hems.
- 23  Borders **shall** be constructed with hidden vertical seams as noted in specification for  
24 valance above.
- 25  FRONT CURTAIN TRACK: ADC 170, or approved equal.
- 26  SIDE CURTAIN TRACKS: Sturdi-Bilt 390 (Walk-Draw), or approved equal.
- 27  VALANCE PIPE: If required, **shall** be 3/4 in. I.D. black steel TC pipe.
- 28  OVERHEAD BORDER PIPES: **shall** be 3/4 in. I.D. black steel TC pipe.
- 29  TRACK AND PIPE HARDWARE: **shall** be supported from structure and of adequate  
30 design and strength to support curtains. All track and pipe hardware **shall** be installed by  
31 the General Contractor.  
32

33 **END OF SECTION**

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
March, 1999

1  
2 **ATTACHMENT 11970-B - STAGE EQUIPMENT**  
3 **GUIDE SPECIFICATIONS FOR MIDDLE SCHOOLS**  
4

- 5  FRONT STAGE CURTAIN AND VALANCE: Flame resistant 25 oz. Velour (color to be  
6 selected). Curtains to be manufactured with 60% fullness. Panel headings **shall** be box-  
7 pleated and constructed with 2 in. heavy jute webbing with a pleat control system  
8 consisting of 16 gauge flame resistant virgin vinyl pleat control strips with 4 in. brass  
9 grommets placed every 12 in. on center.
- 10  Front curtain panels **shall** have 12 in. leading and 2 in. trailing hems. Only full widths  
11 **shall** be allowed. Bottom hems of the front curtain panels **shall** be 6 in., with #8 jack  
12 chain encased in flame resistant Repp chain pockets. Valance hems **shall** be 2 in. on the  
13 sides and 3 in. on the bottom, with Kirsch #1602 weighted tape in the bottom hem.
- 14  Valance **shall** be constructed with hidden vertical seams i.e. the seams are to fall behind  
15 the pleats.
- 16  STAGE CURTAIN SYSTEM: **shall** consist of back traveler, two (2) rear curtain panels,  
17 two (2), four (4) or six (6) side leg panels and two (2), three (3) or four (4) overhead  
18 borders, depending on stage depth and sight-line situation. Curtains **shall** be  
19 manufactured with 60% fullness from flame-retardant, black Atlas Oxford fabric or  
20 similar fabric by another approved manufacturer.
- 21  Borders **shall** be box-pleated and constructed with 2 in. heavy jute webbing with a pleat  
22 control system as noted in specification for Front Stage Curtain above.
- 23  Side legs and rear curtain panels **shall** have 2 in. side hems and 4 in. bottom hems with  
24 #8 jack chain encased in flame resistant Repp chain pockets.
- 25  Overhead borders **shall** be constructed with hidden vertical seams as noted in  
26 specification for valance above.
- 27  MID-STAGE CURTAIN: **shall** consist of two (2) panels manufactured with 60%  
28 fullness from flame retardant, black Atlas Oxford fabric or similar fabric by another  
29 approved manufacturer.
- 30  Panel headings **shall** be box-pleated and constructed with 2 in. heavy jute webbing with a  
31 pleat control system as noted in specification for Front Stage Curtain above.
- 32  Side legs and rear curtain panels **shall** have 2 in. side hems and 4 in. bottom hems with  
33 #8 jack chain encased in flame resistant Repp chain pockets.
- 34  FRONT CURTAIN TRACK: ADC 170, or approved equal.
- 35  SIDE LEG TRACKS: Rotodrapier Pivot Arms #17 with #400 clamp, or approved equal.
- 36  REAR CURTAIN TRACK: Sturdi-Bilt 390 (Walk-Draw), or ADC 170 (Rope-Operated),  
37 or approved equal.
- 38  MID-STAGE CURTAIN TRACK: ADC 170, or approved equal.
- 39  VALANCE PIPE: If required, **shall** be 3/4 in. I.D. black steel TC pipe.
- 40  OVERHEAD BORDER PIPES: **shall** be 3/4 in. I.D. black steel TC pipe.
- 41  TRACK AND PIPE HARDWARE: **shall** be supported from structure and of adequate  
42 design and strength to support curtains. All track and pipe hardware **shall** be installed by  
43 the General Contractor,  
44

45 **END OF SECTION**

1  
2 **ATTACHMENT 11970-C - STAGE EQUIPMENT**  
3 **GUIDE SPECIFICATIONS FOR HIGH SCHOOLS**  
4

5 *Size, design and use of High School stage prevents provision of specifics as to quantity of any*  
6 *type of curtain to be used. Therefore, these guide specifications provide for each type of*  
7 *curtain that might be used.*  
8

- 9  **FRONT STAGE CURTAIN AND VALANCE:** Flame resistant 25 oz. Velour (color to be  
10 selected). Curtains to be manufactured with 60% fullness. Panel headings **shall** be box-  
11 pleated and constructed with 2 in. heavy jute webbing with a pleat control system  
12 consisting of 16 gauge flame resistant virgin vinyl pleat control strips with 4 in. brass  
13 grommets placed every 12 in. on center.
- 14  Front curtain panels **shall** have 12 in. leading and 2 in. trailing hems. Only full widths  
15 **shall** be allowed. Bottom hems of the front curtain panels **shall** be 6 in., with #8 jack  
16 chain encased in flame resistant Repp chain pockets. Valance hems **shall** be 2 in. on the  
17 sides and 3 in. on the bottom, with Kirsch #1602 weighted tape in the bottom hem.
- 18  Valance **shall** be constructed with hidden vertical seams i.e. the seams are to fall behind  
19 the pleats.
- 20  **STAGE CURTAIN SYSTEM:** **shall** consist of back traveler, midstage traveler, two (2)  
21 rear curtain panels two (2), four (4) or six (6) side leg panels and two (2), three (3) or  
22 four (4) overhead borders, depending on stage depth and sight-line situation. Curtains  
23 **shall** be manufactured with 60% fullness from flame retardent, black Atlas Oxford fabric  
24 or similar fabric by another approved manufacturer.
- 25  Borders **shall** be box-pleated and constructed with 2 in. heavy jute webbing with a pleat  
26 control system as noted in specification for Front Stage Curtain above.
- 27  Legs and panels **shall** have 2 in. side hems and 4 in. bottom hems with #8 jack chain  
28 encased in flame resistant Repp chain pockets. Overhead borders **shall** have 2 in. side  
29 hems. Bottom hems **shall** be 3 in. with Kirsch #1602 weighted tape inside the hems.
- 30  Overhead borders **shall** be constructed with hidden vertical seams as noted in  
31 specification for valance above.
- 32  Back and midstage travelers **shall** consist of two (2) panels manufactured with 60%  
33 fullness from flame retardent, black color Atlas Oxford fabric or similar fabric by  
34 another approved manufacturer.
- 35  Panel headings **shall** be box-pleated and constructed with 2 in. heavy jute webbing with a  
36 pleat control system as noted in specification for Front Stage Curtain above.
- 37  Panels **shall** have 2 in. side hems and 4 in. bottom hems with #8 jack chain encased in  
38 flame resistant Repp chain pockets.
- 39  **CYCLORAMA:** **shall** be manufactured from flame resistant seamless Muslin fabric  
40 (color to be white or gray). There shall be no fullness to this curtain.
- 41  Panels **shall** have a heading constructed with 2 in. heavy jute webbing with 16 gauge  
42 flame resistant virgin vinyl control strips with #2 brass grommets placed every 12 in. on  
43 center. The side hems **shall** be 2 in. and the bottom hem **shall** be 4 in. with 2 in. heavy  
44 jute webbing attached at the top of this hem on the back side of the panel. This webbing  
45 to have #2 brass grommets and tie lines at approximately every 12 in. on center used to  
46 fasten a 3/4 in. I.D. black steel TC pipe to the bottom of the panel.
- 47  **FRONT CURTAIN TRACK:** ADC 280A, or approved equal.
- 48  **BACK AND MID-STAGE TRAVELER TRACKS:** ADC 170 or ADC 280A, depending on  
49 width and height of panels, or approved equal.
- 50  **LEG TRACKS:** Rotordraper pivot arm #17 with #400C clamp or approved equal.

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
**DESIGN GUIDELINES**  
March, 1999

- 1  LEGS: Install on 3/4 in. I.D. black TC pipe.
- 2  VALANCE AND OVERHEAD BORDERS: Install on 3/4 in. I.D. black steel TC pipe.
- 3  CYCLORAMA: Install on 3/4 in. I.D. black TC pipe.
- 4  TRACK AND PIPE HARDWARE: **Shall** be supported from structure, and installed by
- 5 the General Contractor, of adequate design and strength to support curtains.
- 6

7

**END OF SECTION**

o

1  
2 **SECTION 12304 - LAMINATE CLAD CASEWORK**  
3

4 **GENERAL**

5  Manufacturers products **shall** be publicly cataloged. Manufacturer **shall** show evidence  
6 of a minimum of five (5) years experience in providing manufactured casework systems  
7 for similar types of projects, produce evidence of financial stability, bonding capacity,  
8 and adequate facilities and personnel required to perform on this project.

9  Samples:

- 10 1. Submit samples of casework manufacturer's standard decorative laminate colors,  
11 patterns and textures for exposed and semi-exposed materials for architect's  
12 selection. Samples of other materials or hardware **shall** be made available if  
13 requested.  
14 2. Architect may request representative full-size samples for evaluation prior to  
15 approval. Samples may be impounded by architect/owner until completion of project  
16 to ensure compliance with specifications.

17  Production Drawings:

- 18 1. Submit CAD production drawings for casework systems and countertops showing plan  
19 view layout of units with relation to surrounding walls, doors, windows, and other  
20 building components, elevations, ends, cross-sections, service run spaces and location  
21 of services.  
22 2. Coordinate production drawings with other work involved. Casework manufacturer to  
23 provide shop drawings for all trades involved in installation of casework.

24  Deliver completed laminate clad casework and countertops only after wet operations in  
25 building are completed, store in a ventilated place, protected from the weather, with relative humidity  
26 range of 20% to 50%

27  Protect finished surfaces from soiling and damage during handling and installation with a  
28 protective covering.

29  Humidity and Temperature Controls:

- 30 1. Advise contractor of requirements for maintaining heating, cooling, and ventilation  
31 in installation areas as required to reach relative humidity necessary to maintain  
32 optimum moisture content. (See Product Handling).

33  All materials and workmanship covered by this section **shall** carry a three (3) year  
34 warranty from date of substantial completion. This warranty is a warranty of  
35 replacement and repair only, whereby the manufacturer **will** correct defects in material  
36 and or workmanship without charge. It does not warrant any products that have been  
37 abused, exposed to excessive loads or left in unconditioned air after occupancy.

38  Work in this section **shall** be performed by a manufacturer certified by the Architectural  
39 Woodwork Institute(AWI) Quality Certification Program. The owner or architect **shall**  
40 have the option to require AWI certification on casework at the manufacturers expense.

41  See Attachment 12304-A for Laminate Casework Features.  
42

43 **PRODUCTS**

44  Manufacturer and Product Type:

- 45 1. For purpose of determining minimum performance and quality standards this  
46 specification is based upon TMI fixed modular casework as manufactured by **TMI**  
47 **SYSTEMS DESIGN CORPORATION**, 50 South Third Avenue West, Dickinson,  
48 North Dakota, 58601, a member of the Architectural Woodwork Institute  
49 (membership #8913) and Approved Quality Certification Program.  
50 2. Casework Manufacturers listed below are acceptable subject to compliance with  
51 requirements:

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
March, 1999

1 Interior Wood Specialties, NC  
2 Stevens Cabinet Company, Teutopolis, IL.

3  Substitutions:

- 4 1. Where specific materials, finish options, construction details, modularity, hardware  
5 and test data are specified herein, the casework **will** be held in strict compliance.  
6 Substitutions **will** be considered prior to bid date provided request is submitted to the  
7 architect, in writing, no later than ten (10) days prior to bid date; substitution request  
8 **shall** list any and all deviations from the specified product. **Acceptable**  
9 **substitutions are to be identified in addenda before bid date.** Any  
10 manufacturer bidding without prior approval can be rejected solely for this reason.  
11

12 **DEFINITIONS AND MATERIALS**

- 13  Listed are definitions and materials commonly used in defining decorative laminate clad  
14 casework. Refer to FABRICATION section for those items selected for use on this  
15 project.

16  Definitions: Identification of casework components by surface visibility.

- 17 1. Open Interiors: Any open storage unit without solid door or drawer fronts and  
18 units with full glass insert doors and/or acrylic doors.  
19 2. Closed Interiors: Any closed storage unit behind solid door or drawer fronts,  
20 sliding solid doors.  
21 3. Exposed Ends: Any storage unit exterior side surface that is visible after  
22 installation.  
23 4. Other Exposed Surfaces: Faces of doors and drawers when closed, tops of cabinets  
24 less than 72 in. above finish floor.  
25 5. Semi-Exposed Surfaces: Interior surfaces which are visible, bottoms of wall  
26 cabinets and tops of cabinets 72 in. or more above finish floor.  
27 6. Concealed Surfaces: Any surface not visible after installation.

28  Core Materials:

- 29 1. Particleboard: Medium density 45-50 pound industrial grade particleboard of fir  
30 or pine meeting or exceeding ANSI A 208.1-1993, M-3 requirements.  
31 Thicknesses used are 1/4 in., 1/2 in., 3/4 in., and 1 in..  
32 2. Hardboard: Prefinished hardboard in 1/4 in. thickness meeting or exceeding  
33 commercial standards CS-251.

34  Decorative Laminates/Veneer Where Applicable:

- 35 1. High pressure decorative laminate GP28 (.028), NEMA Test LD-3-1995.  
36 2. High pressure decorative laminate GP50 (.050), NEMA Test LD-3-1995.  
37 3. High pressure cabinet liner CL20 (.020), NEMA Test LD-3-1995.  
38 4. Thermally Fused Melamine laminate tested to meet NEMA Test LD-3-  
39 1995.  
40 5. High pressure backer BK20 (.020).

41  Edging Materials / Colors:

- 42 1. 1mm PVC banding, machine applied with waterproof hot melt adhesive.  
43 2. 3mm PVC banding, machine applied with waterproof hot melt adhesive with  
44 external edges and outside corners of door and drawer fronts, and countertops,  
45 machine profiled to 1/8 in. radius for safety.  
46 3. PVC banding **shall** be available in standard current solid colors. All selections  
47 color matched to Wilsonart, Nevemar, Formica and Pionite laminates of the  
48 same name.  
49 4. Barbed T-edging or laminate self edge on cabinet components **will not** be  
50 acceptable.

51  Glass:

- 1 1. Full sliding glass doors **shall** be 1/4 at plate glass.
- 2 2. Glass insert doors - hinged or sliding wall cabinets **shall** be 1/8 at D.S. Glass.
- 3 3. Glass insert doors - hinged or sliding tall or base cabinets **shall** be 1/4 at laminate
- 4 safety glass. Sliding doors mounted in aluminum track.
- 5 4. Provide extruded rigid PVC of design to hold and trim glass inserts in framed
- 6 doors. Available in dove grey, frosty white or light beige to match basic cabinet
- 7 body, or in contrasting slate grey or black color.
- 8 5. All glass **shall** be tempered.
- 9

#### 10 SPECIALTY ITEMS

- 11  Countertop support brackets, undercounter support frames, legs and miscellaneous metal
- 12 parts **shall** be furniture steel, welded, degreased, cleaned, treated and epoxy powder
- 13 painted.
- 14  Structural assembly **will** provide for mounting of closure panels, removable access panels,
- 15 and field connection of services within.
- 16  Tote trays **shall** be heavy-duty vacuum formed polypropylene plastic with full top rim
- 17 and pull. Trays **shall** be ivory color, equipped with a label holder.
- 18  Tote tray/supply cabinets equipped with injection molded polycarbonate, continuous side
- 19 rail support glide. Clear color to blend with selected interior finish. Each side rail support
- 20 glide **shall** have integral support pins to interface 32mm (approximately 1-1/4@) pre-
- 21 drilled holes, making the supports readily adjustable.
- 22

#### 23 CABINET HARDWARE

- 24  Hinges **shall** be five knuckle, institutional grade, 2-3/4@ overlay type with hospital tip.
- 25 Steel **shall** be minimum .095@ thick and have minimum of nine (9) edge and leaf
- 26 fastenings. Hinges **shall** pass ANSI-BHMA standard A156.9, Grade 1 requirement for
- 27 both vertical and horizontal set and sag (pair of hinges **will** hold minimum of 310
- 28 pounds); copy of test result **shall** be provided upon request. Casework manufacturer
- 29 **shall use** specifically engineered screws for attachment of hinges; wood screws **shall**
- 30 **not** be permitted. Doors 48@ and over in height **shall** have three (3) hinges per door.
- 31 Provide magnetic door catch with minimum seven (7) pound pull, attached with screws
- 32 and slotted for adjustment. Color to be brushed chrome.
- 33  Door and drawer front pulls **shall** be epoxy finished metal wire style, 96mm spacing on
- 34 fasteners. Pull design **shall** be compatible with Americans with Disability Act (ADA),
- 35 Federal Register Volume 56, No. 144, specifically paragraph 4.27.4. Other pulls may be
- 36 acceptable pending architect approval. Color to be brushed chrome.
- 37  Drawer Slides: Standard use and kneespace drawers **shall** be Blum Style No. BS230M with
- 38 epoxy finish. Slides **will** have a 100 pound load rating at full extension and a built-in,
- 39 positive stop both directions, with self closing feature. Slides **shall** have a lifetime
- 40 warranty as offered by the slide manufacturer.
- 41  File drawer slides **shall** be full extension. Slides **shall** have a lifetime warranty as offered
- 42 by the slide manufacturer.
- 43  Pencil drawers **shall** be equipped with Blum No. 320 for undercounter or support frame
- 44 mounting.
- 45  Adjustable Shelf Supports: **shall** be injection molded polycarbonate, clear color to blend
- 46 with selected interior finish, friction fit into cabinet end panels and vertical dividers,
- 47 readily adjustable on 32mm (approximately 1-1/4 in.) centers. Each shelf support **shall**
- 48 have two (2) integral support pins, 5mm diameter, to interface pre-drilled holes, and to
- 49 prevent accidental rotation of support. The supports **shall** be automatically adaptable to
- 50 3/4 in. or 1 in. thick shelving and **shall** provide non-tip feature for shelving. Supports

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
March, 1999

- 1 are designed to readily permit field fixing of shelf if desired. Structural load testing **shall**  
2 show loading to 1,040 pounds (260 pounds per support) without failure.
- 3  Locks: for doors and drawers as shown on drawings **shall** be National Lock #M4-7054C,  
4 removable core, disc tumbler, cam style lock with strike. Each lock **shall** be furnished  
5 with two (2)keys.
  - 6  Chain bolts **shall** be 3 in. long, **shall** have a 18 in. pull and an angle strike to secure  
7 inactive door on cabinets over 72 in. in height. Elbow catches **shall** be used on inactive  
8 doors up to and including 72 in. in height.
  - 9  All locks in individual rooms to be keyed alike.
  - 10  Sliding Door Track: for both glass and wood sliding doors **shall** be anodized aluminum  
11 double channel.
  - 12  Coat Rods: **shall** be 1-1/4 in. diameter, 14 gauge chrome plated steel installed in captive  
13 mounting hardware.
  - 14  Hanging File Suspension Rails: All file drawers **shall** include a pair of 14 gauge steel  
15 hanging file suspension rails, epoxy coated. File followers, or other split bottom  
16 hardware, **shall not** be acceptable.
  - 17  Mirrors: **shall** be 1/4 in. thick polished mirror plate.
  - 18  Undercounter Support Frame: Welded steel countertop support frames **shall** be provided  
19 at all kneespaces where indicated on drawings. Frames **shall** be available in 3 in.  
20 increments to clear span 24 in. to 60 in. width. Frames **shall** readily accept pencil and  
21 kneespace drawers, and **shall** be designed to interface undercounter support brackets.

22  
23 **FABRICATION**

- 24  Fabricate casework to dimensions, profiles, and details shown.
- 25  Cabinet Body Construction: Tops and bottoms **shall** be joined to cabinet ends and  
26 internal cabinet components such as fixed horizontals, rails and verticals using 10mm  
27 diameter industrial grade hardwood dowels, laterally fluted with chamfered ends, securely  
28 glued and clamped under pressure during assembly to secure joints and cabinet squareness.  
29 Use minimum of six (6) dowels at each joint for 24 in. deep cabinets and minimum of  
30 four (4) dowels at each joint for 12 in. deep cabinets.
- 31  Core **shall** be 3/4 in. thick particleboard.
- 32  Unit backs **shall** be 1/4 in. thick prefinished hardboard or 1/2 in. thermoset melamine  
33 particleboard inset, color matched to cabinet interior. Exposed back on fixed or movable  
34 cabinets to be 3/4 in. particleboard, color matched to cabinet interior, exterior surface  
35 GP28 laminate as selected.
- 36  All fixed undercounter and tall units **shall** have a separate plywood base. This base  
37 should be 96mm or approximately 4 in. high.
- 38  All undercounter units except sink base units, **shall** be provided with full sub-top. Sink  
39 base units **shall** be provided with open top, front welded steel/epoxy painted sink rail full  
40 width at top front edge concealed behind face rail/doors, split back removable access  
41 panels and bottom panel to have CL20 high pressure cabinet liner both faces, color to  
42 match interior color. Exceptions **will not** be permitted.
- 43  All end panels and vertical dividers, except sink base units, **shall** be prepared to receive  
44 adjustable shelf hardware at 32mm (approximately 1-1/4 in.) centers. Door hinges,  
45 drawer slides and pull-out shelves **shall** mount on line boring to maintain vertical  
46 alignment of components and provide for future relocation of doors, drawers, shelves  
47 and/or pull-out shelves.
- 48  All exposed and semi exposed edges of basic cabinet components are factory edged with  
49 PVC banding, machine applied with waterproof hot melt adhesive.  
50 1. Edging **shall** be 3mm PVC available in a minimum of 10 standard colors.

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
6 May 1992

- 1  Adjustable shelf core **shall** be 3/4 in. thick particleboard up to 30 in. wide, 1 in. thick  
2 particleboard over 30 in. wide.  
3 1. Front edge **shall** have factory applied 3mm PVC, color to match shelf color.  
4 2. Any shelving over 30 in. wide **shall** have a mid shelf support or steel shelf  
5 stiffener.
- 6  Interior Finish, Units with Open Interiors:  
7 1. Sides, top, bottom, horizontal, and vertical members, and adjustable shelving  
8 faced with thermally fused melamine laminate with matching prefinished back.
- 9  Interior Finish, Units with Closed Interiors:  
10 1. Sides, top, bottom, horizontal, and vertical members, and adjustable shelving  
11 faced with thermally fused melamine laminate, from manufacturers standard color  
12 options, with matching prefinished back.
- 13  Exposed Ends:  
14 1. **Shall** be faced with high pressure decorative laminate GP28 (.028) color from  
15 casework manufacturer's full range offering of at least 120 colors.
- 16  Wall Unit Bottom:  
17 1. **Shall** be faced with thermally fused melamine laminate.
- 18  Wall and Tall Unit Tops:  
19 1. Top surface **will** be laminated with thermally fused melamine.
- 20  Balanced construction of all laminated panels is mandatory. Unfinished core stock  
21 surfaces, even on concealed surfaces (excluding edges), **will not** be permitted. No  
22 exceptions.
- 23  Drawers: Sides, back and sub front **shall** be particleboard, 1/2 in. thick, laminated with  
24 thermally fused melamine. The back and sub front are doweled and glued into the sides.  
25 Dowels **shall** be fluted, with chamfered ends and a minimum diameter of 8mm. Top edge  
26 is banded with 1mm PVC edging in a matching color.
- 27  Drawer bottom **shall** be particleboard, 1/2 in. thick, laminated with thermally fused  
28 melamine. The bottom **shall** be screwed directly to the bottom edges of the drawer box.  
29 Drawer bottom less than 1/2 in. thick.
- 30  Paper storage drawers are constructed similar except retaining hood **shall** be included at  
31 the rear of each drawer.
- 32  Painted finishes on drawer sides and/or bottom **will not** be permitted.
- 33  Bottoms constructed of minimum 1/4 in. tempered hardboard, surfaced to match drawer  
34 sides, inset and glued to four sides is also acceptable.
- 35  Door/Drawer Fronts: Core for all doors and applied drawer fronts **shall** be 3/4 in. thick  
36 particleboard. All edges **shall** be finished as indicated herein.
- 37  Double doors **shall** be used on all cabinets in excess of 24 in. wide.
- 38  Exterior faces **shall** be laminated with high pressure decorative laminate GP28, color as  
39 selected. Interior face **shall** be high pressure cabinet liner CL20.
- 40  All edges **shall** be finished with 3mm PVC available in standard offerings from  
41 manufacturer. A minimum of 50 solid colors available. External edges and outside  
42 corners **shall** be machine profiled to 1/8 in. radius.
- 43  DECORATIVE LAMINATE COUNTERTOPS: All nominal 1 in. thick laminate clad  
44 countertops shown on drawings **shall** be constructed with 1 in. particleboard core  
45 laminated top face with GP50 (.050) high pressure decorative laminate, with BK20  
46 backer or GP28 laminate underside for balanced construction. Provide tight joint  
47 fasteners where needed. All exposed edges, including edges of backsplash where used,  
48 **shall** have 3mm PVC banding, machine applied with waterproof hot melt adhesive.  
49 Exposed edges and corners **shall** be machine profiled to 1/8 in. radius for safety. All tops  
50 in wet areas to have MR board or plywood cores.  
51

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
March, 1999

1 **EXECUTION**

- 2  **INSPECTION:** The installer must examine the job site and the conditions under which  
3 the work under this section is to be performed, and notify the contractor in writing of  
4 unsatisfactory conditions. **Do not** proceed with work under this section until  
5 unsatisfactory conditions have been corrected in a manner acceptable to the installer.
- 6  Condition casework to average prevailing humidity conditions in installation areas prior  
7 to installing.
- 8  Install casework with factory-trained supervision authorized by manufacturer. Erect  
9 casework; plumb, level, true and straight with no distortions. Shim as required. Where  
10 laminate clad casework abuts other finished work, scribe and cut to accurate fit.
- 11  Adjust casework and hardware so that doors and drawers operate smoothly without warp  
12 or bind. Lubricate operating hardware as recommended by manufacturer. Use filler as  
13 necessary for ease of operation.
- 14  Repair or remove and replace defective work as directed upon completion of installation.
- 15  Clean plastic surfaces, repair minor damage per plastic laminate manufacturer's  
16 recommendations. Replace other damaged parts or units.
- 17  Advise contractor of procedures and precautions for protection of casework and tops  
18 from damage by other trades until acceptance of the work by the owner.

19  
20 **END OF SECTION**

1  
 2  
 3

**ATTACHMENT 12304-A - LAMINATE CASEWORK FEATURES**

	<b>CORE</b>	<b>SURFACE</b>	<b>EDGE</b>
<b>Cabinet Boxes - Base &amp; Wall</b> (Maximum width: 36")			
•Exposed vertical surfaces	All front & sides: 3/4" Base bottom: 3/4"	GP28	Finish all exposed edges (including wall cabinet top and bottom). 3mm PVC.
•Semi-exposed parts (interior of open cabinets, not including drawer bodies)	Wall top & bottom: 1" Back: entrapped - 1/4" Back: onset - 1/2"	CL20 or melamine	
•Concealed surfaces	Full sub-top	CL20 or melamine	
•Panel ends		GP28	
<b>Countertops &amp; Backsplash (wet areas)</b>	1" exterior grade veneer core plywood or phenolic resin particleboard	GP50 balanced with backing sheet	3mm PVC
<b>Countertops &amp; Backsplash</b>	1" particleboard	GP50 balanced with backing sheet	3mm PVC
<b>Cabinet Doors</b>	3/4" particleboard	GP28 with CL20 liner on back.	3mm PVC
<b>Drawer Fronts</b>	3/4" particleboard	GP28 with CL20 liner on back.	3mm PVC
<b>Drawer Sides and Backs</b>	1/2" particleboard or 5/8" medium density fiberboard	Melamine on all visible surfaces with drawer in normal open position.	
<b>Drawer Bottoms</b>	Fully captured construction - minimum thickness: 1/4". Platform construction - minimum thickness: 1/2".	Melamine panel product or particleboard.	
<b>Shelves</b> (Maximum span: 36", except for 48" span above K-5 cubby units). (Any span over 30" should have additional support).	3/4" particleboard ≤ 30"W. 1" particleboard > 30"W.	GP28 or melamine	3mm PVC

4  
 5  
 6  
 7  
 8  
 9  
 10  
 11  
 12

**NOTES:**

- 1 - Dimensions given are minimum and actual (not nominal).
- 2 - Balanced construction is required on all components.
- 3 - All hardware (latches, hinges and pulls) must be ADA compliant.
- 4 - All PVC edges must be machine applied with hot melt adhesive. All PVC edges must be machine radiused.
- 5 - Toe kick should be separate, and of plywood construction.
- 6 - Warranty should be 3 years.

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
**DESIGN GUIDELINES**  
March, 1999

- 1 7 – At the owner/architect’s request, AWI certification may be required, paid for by the manufacturer.  
2 8 – Reference AWI 7<sup>th</sup> edition, Section 1600 as guide for engineered product. **Do not** reference  
3 Section 400.  
4 9 – Pre-approved manufacturers are: TMI, Interior Wood Specialties and Stevens. All others must be  
5 approved by addenda.  
6 10 – All particleboard is to be medium density, 45 – 50 lb. industrial grade fir or pine, meeting or  
7 exceeding ANSI A 208.1-1993, M-3 requirements.

8 **SECTION 15000 – GENERAL PLUMBING & MECHANICAL REQUIREMENTS**  
9

10 **GENERAL**

- 11  The following Design Criteria are general items that **shall** apply to the design of all  
12 Plumbing and HVAC Systems in the buildings.  
13

14 **DESIGN REQUIREMENTS**

- 15  In any building where future expansion is definitely planned, as conveyed by the WCPSS,  
16 the Engineer **shall** provide adequate additional capacity and connection points in the  
17 Mechanical Systems as directed by the WCPSS. The additional capacity **shall** be clearly  
18 noted on the front sheet of the drawings.  
19  Show on drawings and specify that all water piping **shall** be located a minimum of 10 ft.  
20 from electrical switchboards and panel boards.  
21  The electrical contractor **shall** provide all power wiring to each piece of mechanical  
22 equipment. The mechanical contractors **shall** be required to furnish all starters and  
23 disconnects and turn over to the electrical contractor for installation and also to make  
24 final connections from slack wire left by electrical contractor to each piece of  
25 equipment. Show detail on drawing to avoid confusion. See attachment 16142-A.  
26  All points for future connections **shall** also be clearly shown and labeled on the drawings  
27 with the capacity (GPM, Tons, kW, etc.) that is available for future at each connection  
28 point.  
29  **Do not** locate pumps, motors, or other equipment requiring routine maintenance  
30 overhead.  
31  **Do not** use in-line exhaust fans located above ceiling.  
32  See section 15500-4, Lines 4 & 5 for location of fresh air intakes.  
33

34 **ENERGY CONSERVATION** – See Section 01000-General Data  
35

36 **DRAWING REQUIREMENTS**

- 37  All text and numbers **shall** be a minimum of 3/32 in. high to allow for a 1/2 reduction of  
38 the drawing size and still be readable.  
39  Provide key plan for all sheets.  
40  Provide Volume 10 Building Energy Data on cover sheet to drawings.  
41  Show details of all pipe, duct, conduit and wiring penetration details on the drawings for  
42 all fire rated walls to meet UL and Local Code Requirements.  
43  Show all fire rated walls on all drawings for all trades with the rating spelled out or show  
44 different wall symbol for each rating (1HR, 2HR, or 4HR).  
45  Show location of all supply air, return air, outdoor air and exhaust air balancing devices on  
46 plans.  
47  All air handling equipment, pumps, motors, valves etc., **shall** be mounted in areas easily  
48 accessible for routine maintenance. Provide 3 ft. clearance, minimum, around equipment  
49 for access to motors, compressors, bearings, controls, filters, valves, etc. Provide filter  
50 change space and coil pull space. The access door for the filters should be one that does  
51 not require maintenance personnel to use tools to open. (See Section 15500-5, Line 18)

- 1 Locate relative equipment together, i.e. in the same room and on the same floor. **Do not**  
2 layout equipment rooms such that equipment, piping and/or duct work must be removed  
3 to perform maintenance. **Do not** locate equipment overhead.
- 4  Provide permanently fixed access to ceiling mounted air handling units for auditoriums,  
5 gymnasiums or other large volume areas, i.e. catwalk, stairs etc. Maintenance on these  
6 units **shall not** require a boom, lift or extension ladder.
  - 7  Engineer **shall** provide standard electrical connection detail (see Attachment 16142-A)  
8 on plumbing and mechanical plans.
  - 9  Show dotted lines on floor plans of all mechanical rooms and all other heavily  
10 concentrated areas to designate pull spaces for equipment, (coils, motors, etc.) and  
11 maintenance space for equipment (filter change out, lubrication, belt replacement,  
12 bearing replacement, compressor replacement, valve maintenance, etc.). Also show  
13 minimum of three (3) ft. of clearance around all mechanical and electrical equipment  
14 including wall clearances. Show greater clearance where recommended by manufacturer.
  - 15  Show a complete legend and symbol list on the first sheet for all trades (Plumbing, HVAC,  
16 Electrical, etc.).
  - 17  Where terminal units and/or piping is to be installed exposed in classrooms, media  
18 centers, cafeterias, kitchens, administrative areas or other finished areas of the building, a  
19 detailed isometric scaled typical detail **shall** be shown of the equipment and/or piping and  
20 the walls, ceiling and floor of the room.
  - 21  Show complete piping schematic drawings for all piping systems.
  - 22  Isometric piping diagrams **shall** be shown for all mechanical equipment used in the  
23 building showing all fittings, valves, thermometers, gauges, and other devices required for  
24 proper operations and isolation.
  - 25  All mechanical and boiler rooms **shall** be blown up to a scale of a minimum of 1/4 in. = 1  
26 ft. and all equipment in the room including piping **shall** be drawn to scale with all  
27 clearances shown. Show all trades on the blow up drawings. Show a minimum of two (2)  
28 sections through the rooms or show the room in a full isometric drawing. Show all door  
29 swings. **Do not** block access for any item of equipment with another.
  - 30  Access to mezzanine mechanical rooms **shall** be stairwell (not a ships ladder) leading up  
31 to the mezzanine mechanical room with a minimum width of 4 ft. Design insulated walls  
32 around the mezzanine mechanical rooms with a waterproof membrane and floor drains in  
33 the floor. Provide hoist where necessary to install and service equipment. Coordinate  
34 this between Architect/Engineer.
  - 35  All building heating loads (MBH), cooling loads (tons), domestic hot and cold water  
36 demand (GPM), waste load (fixture units), connected electrical loads (kW), gas loads  
37 (cfh), list of "U" valves and estimated maximum electrical demand (kW) **shall** be clearly  
38 shown in tabular form on the front sheet of the P/M/E drawings for all trades.
  - 39  All capacities provided for future building additions **shall** also be shown in this table.
  - 40  Show all mechanical and electrical equipment to scale including panelboards, fire alarm  
41 panels, sound panels, water heaters etc.

#### SPECIFICATIONS

- 44  Show a list of acceptable manufacturers for all items of equipment specified. Refer to this  
45 document or if uncertain, consult with the WCPSS.
- 46  Specify maximum noise levels for each type of equipment specified. Note: **Do not** locate  
47 noisy equipment near noise sensitive areas of the building. Room noise levels **shall not**  
48 exceed NC level 35. Equipment decibel levels inside building **shall not** exceed 50 dB.
- 49  Engineer **shall not** locate noisy outdoor equipment (i.e. chillers, cooling towers, etc.) in  
50 locations that will result in complaints from adjacent property owners.

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
March, 1999

- 1  Specify minimum energy efficiency for each item of mechanical and electrical equipment  
2 based on its operating conditions. For a water chiller specify the minimum efficiency at  
3 the 25, 50, 75 and 100% operating conditions.
- 4  Specify that the Mechanical Contractor **shall** balance all air and water systems. Once  
5 the Contractor certifies to the Owner that the systems are balanced, and the Engineer has  
6 approved the report, the Owner **will** have an AABC or NEEB Certified Test and  
7 Balancing Contractor confirm that the systems are balanced. If the Owner's Test and  
8 Balancing Contractor discovers discrepancies of more than 10% than the values called for  
9 on the construction documents, the Mechanical Contractor **will** rebalance the system  
10 and the Owner's Test and Balancing Contractor **will** re-test the system. The  
11 specifications **shall** further state that any re-test by the Owner's Test and Balancing  
12 Contractor **will** be paid for by the Mechanical Contractor.
- 13  Specify five (5)-year warranty for all compressors.
- 14  Specify all filters for AHU's to be pre-cut type and that the Mechanical Contractor **shall**  
15 be responsible for a complete change of filters at final completion and leaving an  
16 additional set of pre-cut filters at the school for the next change.
- 17  Specify that all belt driven equipment **shall** be provided with a spare belt to be turned  
18 over to the Maintenance Department.
- 19  Specify that all warranties **shall** commence from the date of Substantial Completion, not  
20 from the start-up date of the equipment.

21  
22 **OPERATING AND MAINTENANCE MANUALS** (See Section 01000-General Data)

- 23  Specify that four (4) complete sets of operation and maintenance manuals **shall** be  
24 delivered to the owner through the A/E two (2) weeks before the pre-final inspection is  
25 held.
- 26  The O&M manuals **shall** be installed in 3 ring heavy back note books with the name of  
27 the building and the words "Operations and Maintenance Manuals" permanently affixed  
28 to the cover and spine.
- 29  The manuals **shall** contain the following items as a minimum:
- 30  Index and page numbers
  - 31  Certificate of substantial completion
  - 32  A summary sheet of warranties with the dates noted and a copy of all warranties
  - 33  List of all subcontractors and suppliers with names, addresses and phone numbers
  - 34  Certified testing and balancing report
  - 35  Complete start-up operation, and shut-down procedures for each system including  
36 sequence of events, locations of switches, emergency procedures and any other  
37 critical items
  - 38  Lubrication schedules and types of lubricants
  - 39  Complete set of current shop drawings and equipment description showing all  
40 capacities and other operation conditions
  - 41  Equipment summary showing all capacities and ratings (HP, Tons, kW, Filter size,  
42 etc.)
  - 43  All submittal data and shop drawings

44  
45 **FINAL INSPECTIONS** (See Section 01000-General Data)

46  
47 **POST INSPECTION** (See Section 01000-General Data)

48  
49 **END OF SECTION**

1  
2 **SECTION 15050 - PLUMBING SYSTEM, GENERAL**  
3

4 **GENERAL**

- 5  All provisions of the "General Plumbing & Mechanical Requirements Section 15000" shall  
6 apply to this section.  
7  All water consuming devices shall be the water saving type.  
8  Provide positive freeze protection on all water lines subject to freezing conditions.  
9  Provide a ball valve in branch piping to all exterior hose bibbs. Where suitable, locate  
10 hose bibbs adjacent to exterior mechanical rooms, dropping branch piping exposed in  
11 mechanical room and locating ball valve a maximum of 6 ft. above finish floor.  
12  Contractor shall be required to completely rod and flush out all sanitary waste lines both new and  
13 existing after a building is completed.  
14  Tempered water shall be provided at all locations.  
15  Specify copper fin tube water heater with a separate lined storage tank for domestic water  
16 heaters.  
17  Provide chrome escutcheon rings at all exposed ceiling and wall penetrations.  
18  Provide isolation valves in cold water and hot water piping so that water can be shut off to each  
19 classroom wing, administration area, group toilets and science classrooms.  
20  Engineer shall specify plaster type P-traps for all art room sinks.  
21  Provide floor drain with deep seal P-trap and indirect type trap primer at science eye  
22 wash station.  
23  
24

**END OF SECTION**

1  
2 **SECTION 15100 - PLUMBING VALVES**  
3

4 **GENERAL**

- 5  Use one valve manufacturer throughout job.  
6

7 **PRODUCTS**

- 8  Where insulation is required, provide extended valve stems.  
9  Domestic hot water and cold water - Ball valves, 2 in. and smaller - class 125, 200 WOG cast  
10 bronze, soldered ends. 2-1/2 in. and larger - class 125 iron body.  
11  Compressed air - ball valves, 400 WOG, two-piece construction, full size port.  
12  Natural gas - plug valves 2 in. and smaller, 150 WOG bronze body, square head, threaded ends,  
13 2-1/2 in. and larger, 175 WOG lubricated plug type, semi steel body, flanged ends.  
14  Globe valves (bypass only) 2 in. and smaller, class 125 cast bronze solder ends, 2-1/2 in. and  
15 larger, class 125 iron body, flanged ends.  
16  Swing check valves, 2 in. and smaller, class 125 cast bronze, threaded ends, 2-1/2 in. and larger,  
17 class 125, cast iron body, flanged ends.  
18

19 **END OF SECTION**

1  
2                   **SECTION 15110 - POTABLE WATER & FIRE WATER SYSTEMS**  
3

4 **PRIVATE WATER SUPPLY**

- 5  Well (6 in. minimum) **will** be located and bored by WCPSS.  
6  Plumbing contractor **shall** provide submersible pump, hydropneumatic storage tank,  
7 chlorinator & filters.  
8  Pump house by general contractor.  
9  No meters required.

10  
11 **PRODUCTS**

- 12  Locate meter at property line and/or right of way line in non-traffic area.  
13  Provide second water only meter for irrigation, cooling tower, and other non-sewer  
14 services. This **will** be on separate water line from main building service.  
15  Water tap, meter & vault costs provided by plumbing contractor.  
16  Meter deposit paid by WCPSS.  
17  WCPSS is exempt from paying acreage fees.  
18  Underground water service; 2-1/2 in. and less - type "K" copper w/silver solder joints; 3 in.  
19 and above; cement lined ductile iron ASTM C151 with mechanical joints except straight  
20 sections may be push - on joints.  
21  Minimum 18 in. cover to top of pipe for 2-1/2 in. and smaller.  
22  Minimum 48 in. cover to top of pipe for 3 in. and larger.  
23  Backflow preventer (Watts 909 DDC) for fire line.  
24  Backflow preventer (Watts 909S) for irrigation.  
25  Backflow preventer for fire loop or irrigation **shall** be located above ground in a vault or  
26 insulated cover.  
27  Fire loop around building **shall** be 8 in. minimum with fire hydrants spaced no greater  
28 than 300 ft. and no parts of the building no more than 300 ft. from a hydrant.  
29  Fire hydrants and valves **shall** be approved by local inspectors.  
30  Provide profile of water distribution lines to site from nearest source of municipal water  
31 with all interferenceis.  
32  Engineer **shall** require contractor to dimension actual location of all underground water  
33 lines on as-built drawings. A minimum of two (2) dimensions from building reference  
34 points **shall** be provided and a bury depth indicated.

35  
36                   **END OF SECTION**

1  
2 **SECTION 15120 - SEWAGE DISPOSAL**  
3

4 **PUBLIC SANITARY SEWER LINES**

- 5  Manholes spaced no more than 300 ft.  
6  Provide manhole to make tie-in to 6 in. and larger sewer.  
7  Use 4 ft. diameter precast eccentric manholes with steps 15 in. on center.  
8  Minimum cover in non-traffic areas 3 ft.  
9  Minimum cover in traffic area – 5 ft. for pvc, 3 ft. for ductile iron on Class I bedding.  
10  Materials:  
11     a. Ductile iron class 50 with push on joints - ASTM C-150 (8 in. and larger)  
12     b. PVC ASTM D-3034 SDR 35 on Class I bedding (8 in. and larger)  
13     c. PVC schedule 40 ASTM, D2665 (4 in. and 6 in.)  
14     d. Cast iron ASTM A74 hub and spigot service weight (4 in. and 6 in.)  
15  Provide profiles of sanitary sewer lines between manholes.  
16  Use laser instrument to install all exterior sanitary sewer lines.  
17  Use drop manhole if elevation of sewer line exceeds 24 in. above manhole invert.  
18  Minimum slope of sewer lines:  
19     4 in. - 1.00%  
20     6 in. - .60%  
21     8 in. - .50%  
22     10 in. - .28%  
23     12 in. - .22%  
24     Minimum flow velocity - 2 FPS  
25  Sewer lines **shall** be straight with uniform slope between manholes.  
26  Maximum slope is 10%.  
27  Show new and existing grade contours on plan.  
28  Install metal identification tapes over PVC sewer lines.  
29  Engineer **shall** require contractor to dimension actual location of all sewer lines on as-  
30 built drawings. A minimum of two (2) dimensions from building reference points **shall** be  
31 provided and a bury depth indicated at a maximum spacing of 100 ft.  
32  Provide a minimum of a 6 inch sewer waste line from all group toilet restrooms.  
33

34 **END OF SECTION**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19

**SECTION 15125 - IRRIGATION SYSTEM**

**GENERAL**

- Use backflow preventer - Watts No. 909S.
- Use metered water supply so the amount of water used for irrigation can be subtracted from main meter to save sewage charges. (See Section 15110)
- Use Toro heads and control panel as an add alternate if not used for base bid.
- Use triple elbow swing joints at all heads.
- Use hydraulic valve in head gear driven rotor pop-up adjustable nozzle Toro heads.
- Irrigation supply line - PVC SDR 21/PR200 type 1, grade 1 with PVC schedule 40 solvent weld fittings.
- Install metal identification tapes over PVC lines.
- Minimum 24 in. cover to top of irrigation piping.
- Engineer **shall** require contractor to dimension actual location of all irrigation lines on as built drawings. A minimum of two (2) dimensions from building reference point **shall** be provided and a bury depth indicated.

**END OF SECTION**

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
March, 1999

1  
2 **SECTION 15131 - KITCHEN PLUMBING**  
3

- 4  Use stainless steel 12 in. x 12 in. x 10 in. ZURN Z-1752-KC-Y-2 floor sink for indirect  
5 waste from prep and pot sinks & steamer.
- 6  Use 7 in. round recessed strainer floor drain for indirect waste from ice machine, serving  
7 line equipment and cooler/freezer.
- 8  Use stainless steel floor troughs for wastes from cutter mixer, tilting skillet, and area in  
9 front of steamer and steam kettle. Use stainless steel strainers built-in as a component  
10 of trough.
- 11  Use hand sinks with wrist blade handles.
- 12  Supply 120 deg. F. water to hand sink.
- 13  Use cleaning faucet - American Standard or similar and mount under hand sink 12 in.  
14 above finish floor.
- 15  Use floor drain under cleaning faucet.
- 16  Add adequate quantity of general area floor drains to kitchen so entire floor can be hosed  
17 down.
- 18  Use utility raceway to serve equipment under hood. Use flexible hoses to serve  
19 equipment. Length of hoses **shall** be adjusted or shortened to prevent hoses from lying  
20 on floor.
- 21  Kitchen equipment **shall** utilize natural gas where available. **Do not use** LP gas.
- 22  Hood manufacturer **shall** furnish solenoid gas shut off valve to Plumbing Contractor for  
23 installation.
- 24  Add electric water cooler in kitchen area.
- 25  Supply 140 deg. F. to dishwasher, prep and pot sinks, can wash and mop receptor.
- 26  Circulate hot water for 140 deg. F. and 120 deg. F. loops.
- 27  Use American Standard freezeproof mixing faucet for can wash.
- 28  Use non-clog floor drain for can wash.
- 29  Use manual hose reel in dishwashing area for wash down.
- 30  **Do not** connect disposals to grease interceptor.
- 31  Use fill faucet for cutter mixer.
- 32  Use copper pipe for prep and pot sink continuous waste.
- 33  Use backflow preventer - Watts No. 909 for cold water and hot water Kitchen supply.
- 34  Use shock absorbers for all solenoid operated equipment.
- 35  Use Wake County Health Dept. water heater sizing chart to check for adequate kitchen  
36 hot water.
- 37  All final connections to kitchen equipment **shall** be done by Plumbing Contractor except  
38 items connected to utility raceway.
- 39  Kitchen equipment contractor **shall** furnish and install faucets for prep and pot sinks.
- 40  Kitchen equipment contractor **shall** furnish to Plumbing Contractor for installation in  
41 water piping items such as solenoid valves, thermometers, etc.
- 42  Provide water filter at kitchen icemaker connection.
- 43
- 44

**END OF SECTION**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18

**SECTION 15140 - PLUMBING SUPPORTS AND ANCHORS**

**GENERAL**

- Use one hanger manufacturer throughout job.

**PRODUCTS**

- Horizontal piping hangers - insulated piping **shall** have hanger around insulation with rigid insulation above shield. Use adjustable steel clevis hangers.
- Vertical piping clamps - size to fit bare pipe, copper plated for copper piping.
- Building attachments - use beam clamp with retaining strap or concrete inserts.

**EXECUTION**

- Use trapeze hangers where possible to rack piping together.
- Do not** support piping from bar joist bridging and/or roof deck.
- Support all piping so as to prevent excessive movement.

**END OF SECTION**

1  
2 **SECTION 15190 - PLUMBING IDENTIFICATION**  
3

4 **GENERAL**

- 5  Use same identification system throughout project.  
6

7 **PRODUCTS**

- 8  Pipe markers and flow arrows: Stencil paint type  
9  Underground plastic pipe marker: 6 in. wide x 4 mils thick multi-ply tape, solid aluminum  
10 foil core between two (2) layers of plastic tape.  
11  Valve tags: 19 gauge polished brass valve tags. Contractor to furnish valve schedule  
12 mounted behind glass in a frame located in main mechanical room.  
13  Above ceiling valve markers: 1/2 in. dia. self-adhesive color coded circle. Color code as  
14 noted below.  
15  Engraved plastic-laminate sign: 1/16 in. thick, fastened with self-tapping stainless steel  
16 screws  
17

18 **EXECUTION**

- 19  Locate pipe markers and flow arrows as follows:  
20 -maximum of 25 ft. and closer if congested  
21 -near each valve  
22 -near each branch  
23 -near equipment  
24 -near origination & termination points  
25 -near where pipe passes through walls (both sides of wall)  
26 -near access doors  
27  Paint and color code all exposed piping in mechanical and boiler rooms. Piping **shall**  
28 have flow arrows and labels located at 10 ft. intervals, at all turns and at each floor or  
29 wall penetration and be color coded as follows:  
30 Cold Water - Dark Blue  
31 Hot Water - Dark Red  
32 Gas Lines - Yellow  
33  Provide brass valve tag on all valves.  
34  Provide ceiling valve marker for valves located above lay-in ceilings. Attach valve  
35 marker to adjacent ceiling grid.  
36  Provide plastic laminated signs on all equipment. Include equipment identification,  
37 capacity, substantial completion date and warranty information.  
38

39 **END OF SECTION**

1  
2 **SECTION 15250 - PLUMBING INSULATION**  
3

4 **GENERAL**

- 5  Flame/smoke ratings: flame-spread index of 25 or less and smoke-developed index of 50  
6 or less, as tested by ASTM E84 (NFPA 255) method.  
7

8 **PRODUCTS**

- 9  Fiberglass insulation: ASTM C 547 Class I with Type I all service jacket.  
10  Exposed insulation - 8 oz. canvas rosin sized cloth jacket.  
11  Fittings: one-piece pre-molded PVC fitting covers.  
12

13 **EXECUTION**

- 14  Insulate all domestic water piping with 1 in. thick minimum insulation except for re-  
15 circulation hot water which needs to be insulated with 1-1/2 in. thick insulation. Insulate  
16 roof leader horizontal piping with 1 in. thick insulation to include roof drain pan and  
17 vertical piping from roof drain.  
18  Install 20 gauge galvanized metal jackets on all exposed insulated lines within 8 ft. above  
19 floor in occupied spaces. Prime metal jacket with paint grip finish.  
20  Provide sheet metal saddle at all pipe hangers.  
21  Provide rigid insulation at pipe hangers for all insulated piping 2 in. and larger.  
22  
23

**END OF SECTION**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19

**SECTION 15411 - DOMESTIC WATER PIPING**

**GENERAL**

- Covers domestic hot water and cold water piping within building to a point 5 ft. outside building.

**PRODUCTS**

- Underground piping: type "K" copper with silver soldered joints. **Do not** locate joints below slab of building.
- Above ground piping: type "L" copper with silver soldered joints.
- Backflow preventer located in building - reduced pressure principle assembly with strainer, Watts No. 909S. Locate between 12 in. and 60 in. above finish floor. Pipe discharge around room to floor drains. Provide pressure gauges on entering and leaving sides of assembly.
- Pressure regulating valve: Provide for all installations. Include strainer, bypass and pressure gauge.

**END OF SECTION**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48

## SECTION 15420 - DRAINAGE AND VENT SYSTEMS

### GENERAL

- Includes sanitary, acid and storm drainage and vent piping systems inside building to a point 5 ft. outside building. Roof drains are to be furnished and installed by General Contractor. Plumbing Contractor connects to roof drain outlet.

### PRODUCTS

- Underground Sanitary and Storm Drainage and Vent Piping:
  - 1. Schedule 40 PVC.
- Aboveground Sanitary and Storm Drainage Piping:
  - 1. Schedule 40 PVC.
- Aboveground Sanitary Vent Piping:
  - 1. Schedule 40 PVC.
- Joints:
  - 1. Cemented Joints.
- Underground Acid Waste and Vent Piping:
  - 1. Acid resistant Polypropylene pipe schedule 40 flameretardant with socket fittings. Electrical fusion or heat fusion joints.
- Aboveground Acid Waste and Vent Piping:
  - 1. Acid resistant polypropylene pipe, schedule 40, flame retardant with socket fittings. Electrical fusion or heat fusion joints.
- Cleanouts - Josam:
  - 1. **Do not** install cleanouts in carpet or gym floors
  - 2. Floor cleanouts:
    - a. Exposed rim type, with recess to receive 1/8 in. thick resilient floor finish.
    - b. Exposed flush type, standard non-slip scored or abrasive finish
  - 3. Wall cleanouts: Cast iron body with cast-bronze cleanout plug, stainless steel cover.
  - 4. Cleanouts at finish grade: Cast brass plug with recessed slot in fitting or in caulked cast iron ferrule. Set in center of 24 in. x 24 in. x 8 in. thick concrete pad flush with grade.
- Flashing Materials:
  - 1. Vent flashing - 16 oz per square ft. sheet copper or 4 lbs./square ft. sheet lead shop fabricated into one-piece base flashing and separate counter (cap) flashing.
  - 2. Single ply (rubber roof) flashing will be furnished and installed by General Contractor.
- Use PVC piping with proper flame/smoke rating in return air plenums or wrap with insulation to provide proper protection.

### EXECUTION

- Install underground drainage mains with the laser beam alignment system.
- Pipe sleeves - schedule 40 black steel.
- Install all V.T.R. a minimum of 15 ft. from fresh air intake.
- Depress floor drains below room perimeter minimum of 1/2 in.
- Route waste piping from science classrooms to acid dilution tank and tie into sanitary sewer.

END OF SECTION

1  
2 **SECTION 15440 - PLUMBING FIXTURES**  
3

4 **GENERAL**

- 5  Specify all vandal-proof options for all fixtures used by students. This includes handle  
6 screws, aerators and showerheads.
- 7  American Standard, Eljer or Kohler are acceptable manufacturers for cast-iron and  
8 vitreous china fixtures. All fixtures **shall** be white.
- 9  Elkay and Just are acceptable manufacturers for stainless steel sinks. Sinks **shall** be 18  
10 gauge.
- 11  Specify Carriers for all wall hung fixtures including urinals and lavatories.
- 12  Specify all water closets to be floor mounted.
- 13  Specify chrome plated rigid supplies with angle I.P.S. loose key stops for all gang toilet  
14 lavatories - such as McQuire No. 158 LK. Wheel handle stops may be used for K-5  
15 School and all administration areas.
- 16  Specify chrome plated cast brass p-trap and wall nipple for all lavatories - such as  
17 McQuire No. 8090 with No. 2127 nipple.
- 18  Specify chrome plated semi-cast 17 gage brass p-traps for all sinks and water coolers -  
19 such as McQuire No. 8902 or 8912.
- 20  Specify separate stops for all fixtures unless integral stops.
- 21  Sloan or Delany are acceptable manufacturers of flush valves with solid ring supports.
- 22  Specify chase for multiple lavatory installations (minimum 6 in. clear).
- 23  A walk-in plumbing chase **shall not** be specified at group toilets.
- 24  Specify plaster p-trap for all art room sinks.
- 25  Specify primer valves and/or deep seal p-traps for floor drains in mechanical rooms.  
26 Locate primer valve inside mechanical room.
- 27  Specify floor drain with indirect style trap primer at emergency eye wash stations (new  
28 construction only).
- 29  Connect circulating pumps to DDC system.
- 30  Specify separate flue for water heater.
- 31  Specify separate fuel oil lines from fuel oil tank for water heater.
- 32  Use gas water heaters for kitchens and gym areas. Use small tank type electric water  
33 heaters for remote uses. **Do not use** instantaneous water heaters.
- 34  Specify key operated chrome plated box type hose bibb flush with wall for group toilets-  
35 such as Woodford No. B24.
- 36  Specify key operated box type automatic draining non-freeze wall hydrants around  
37 exterior of building so that 100 feet of hose **will** reach all windows - such as Woodford  
38 No. B65, Josam or Zurn. Provide ball valve in branch piping for isolation purposes.
- 39  Dimension all floor drain locations on drawings.
- 40  Specify washer box for all residential type washing machines with cold water, hot water  
41 and drain for both commercial and residential use.
- 42  Specify tempered water to student group showers - single handle control. Locate  
43 thermostatic mixing valve in lockable cabinet in coach's office.
- 44  Specify cast-iron wall hung lavatories, 4 in. centers, 20 in. x 18 in. grid drain - such as  
45 American Standard "Regalyn" 4869.020 for lavatories served by both hot and cold water.
- 46  Provide both cold and hot water to all lavatories.
- 47  Specify single lever centerset lavatory fitting for administrative toilets.
- 48  Branch piping to custodial closets: Provide check valves in cold and hot water piping.
- 49  Specify metered faucets (laser is preferred) on lavatories at group toilet rooms. Ease of  
50 operation is a must for small children (no push buttons). **Note:** Engineer **shall** check

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
**DESIGN GUIDELINES**  
 6 May 1992

- 1 with local code officials to see if this requirement can be omitted on elementary campuses  
 2 for the K-1 wing.
- 3  Specify single bowl sinks for classrooms and workrooms. Provide double bowl sinks for
  - 4 teacher's lounge and Exceptional Children areas.
  - 5  Specify pre-cast mop receptor with stainless steel wall protector.
  - 6  Specify cold water for all refrigerator icemakers.
  - 7  Specify floor mounted elongated bowl water closets
  - 8  Specify institutional grade water closet seats with self - sustaining check hinge. Church
  - 9 No. 9500.NSSC.
  - 10  Specify flush valve for all water closets with handle 39 in. above finish floor. Coordinate
  - 11 water closet flush valve height with grab bars.
  - 12  Specify thermostatic mixing valves to provide 120 °F hot water temperature from water
  - 13 heater that serves kitchen with 140°F water.
  - 14  Specify wall-mounted drinking fountain - enameled cast iron - Haws Model 1310. Use
  - 15 for K-1 classroom not supplied with lavatories and 6-12 locker rooms.
  - 16  Specify wall mounted wheel chair type electric water cooler, electric push button on front
  - 17 colored vinyl covered steel skirt, flexible safety bubbler spout, Oasis or Halsy-Taylor.
  - 18 Use for all K-12 applications.
  - 19  Specify ASME expansion tanks for water heaters larger than 80 gallons.
  - 20  **Do not** connect oil/gas water heaters to DDC system due to thermal shock of tank.
  - 21  Provide key operated solenoid water valves for each science lab. **Do not** allow fork type
  - 22 keys to be used. Key switch to be labeled "CW" for cold water and "HW" for hot water
  - 23 and show "ON" and "OFF" position. Label to be engraved plastic laminate. Valve to be
  - 24 normally closed.

25  
 26  PLUMBING FIXTURES MOUNTING HEIGHTS

27  
 28 WATER CLOSETS

29 <u>FIXTURE</u>	<u>REGULAR</u>	<u>HANDICAPPED</u>	<u>REMARKS</u>
30 Pre K	10 in.	10 in.	Top of Seat
31 K-5	15 in.	15 in.	Top of Seat
32 6-8	15 in.	16-1/2 in.-19-1/2 in.	Top of Seat
33 9-12	15 in.	16-1/2 in.-19-1/2 in.	Top of Seat
34 Adult	15 in.	16-1/2 in.-19-1/2 in.	Top of Seat

36  
 37 URINALS

38 K-5	20 in.	14 in.	To Rim
39 6-8	20 in.	17 in.	To Rim
40 9-12	24 in.	17 in.	To Rim
41 Adult	24 in.	17 in.	To Rim

42  
 43 LAVATORIES

44 Pre K	23 in.	23 in.	To Rim
45 K-5	27 in.	30 in.	To Rim
46 6-8	31 in.	34 in.	To Rim
47 9-12	31 in.	34 in.	To Rim
48 Adult	31 in.	34 in.	To Rim

49  
 50 WATER COOLERS

51 Pre K-3	24 in.	30 in.	To Rim
------------	--------	--------	--------

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
March, 1999

1	4-5	28 in.	30 in.	To Rim
2	6-8	34 in.	34 in.	To Rim
3	9-12	34 in.	34 in.	To Rim
4	Adult	34 in.	34 in.	To Rim
5				
6	SHOWERS			
7	6-8 boys	72 in.	see note 2	Bottom of Showerhead
8	6-8 girls	66 in.	see note 2	Bottom of Showerhead
9	9-12 boys	72 in.	see note 2	Bottom of Showerhead
10	9-12 girls	66 in.	see note 2	Bottom of Showerhead
11	Adult	72 in.	see note 2	Bottom of Showerhead

12  
13  
14  
15  
16  
17

**NOTES:**

1. Handicapped heights **shall** comply with the NC Building Code and all ADA requirements.
2. Top of shower controls not more than 48 in.

**END OF SECTION**



1  
2 **SECTION 15500 - HEATING, VENTILATING AND AIR CONDITIONING, GENERAL**  
3

4 **GENERAL**

- 5  The selection of all HVAC systems and other systems **shall** be approved by the  
6 responsible WCPSS authority at the schematic phase of design.  
7  The **use** of Lockinvar Boilers is prohibited.  
8  A computerized 30 year Life-cycle-cost analysis **shall** be made for all school buildings  
9 over 20,000 SF and submitted to the Wake County Public School Systems, Energy  
10 Management Department at the schematic stage of design with a final recommendation  
11 of type of HVAC system to be used.  
12  Such an analysis **shall** include at least three (3) alternates along with integrated studies of  
13 construction costs, the effects of building construction materials, building orientation,  
14 lighting, usage schedules, fuels, HVAC equipment, maintenance costs, and other factors  
15 that relate to the initial capital cost of the building versus the annual operating costs.  
16 Contact responsible WCPSS authority for which three (3) alternates are to be studied.  
17  The life cycle costs study **shall** include (but not necessarily be limited to) the following  
18 estimates for each alternate study.  
19 1. The initial cost of the mechanical system, including electrical work and miscellaneous  
20 building costs related to the mechanical system.  
21 2. First year utility costs for the following:

22  
23 Heating Energy  
24 Cooling Energy  
25 Interior Building Lighting  
26 Domestic Hot Water  
27 All other energy sources  
28

29 *The requirements for balancing have been modified and moved to Section 15000 for greater*  
30 *clarity.*

- 31  
32  Air side economizer cycles **shall** be used where possible, for the energy savings and the  
33 effect on health through the reduction of airborne bacteria count. Contact the  
34 responsible WCPSS authority when a water side economizer is being considered.  
35  Low-leakage type outdoor air dampers **shall** be used to minimize air infiltration during  
36 off hours. Max. leakage of 1/2 of 1% at pressure differentials under 4 in. WG.  
37  Electric resistance heaters should **only** be used for comfort heating where indicated by a  
38 life cycle cost study to be most economical. However, electric heaters **shall** be used in  
39 all exterior mechanical rooms, which have hydronic piping.  
40  Engineer **shall** specify engraved plastic laminated labels on all equipment. Labels **shall**  
41 include equipment number, area(s) served (**use** actual room numbers used at the facility-  
42 not architectural room numbers), substantial completion date (S.C.), extended warranty  
43 period, number and size of filters and capacity.

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
6 May 1992

- 1  The following are examples of labeling to be used:  
2     Air Handling Units:     AHU #1 (Classrooms 10 & 12)  
3                                     S.C.: 11/16/94  
4                                     Filters: 2 @ 24 in. x 24 in. x 1 in.  
5                                     Capacity: 2000 CFM @ 0.5" ESP  
6  
7     Boilers:                     Boiler #1 (Buildings 100 & 200)  
8                                     S.C.: 11/16/94  
9                                     Input: 1,000 MBH  
10                                    Output: 900 MBH  
11  
12     Chillers:                    Chiller #1 (Buildings 100 & 200)  
13                                    S.C.: 11/16/94 ( 5 year Comp. Warranty)  
14                                    Capacity: 190 Tons  
15  
16     Condensing Units:         CU #1 (Classrooms 10 &12)  
17                                    S.C.: 11/16/94 (5 Year Warranty)  
18                                    Capacity: 5 Tons  
19  
20     Cooling Towers                CT #1 (Chiller #1)  
21                                    S.C.: 11/16/94  
22                                    Capacity: 190 Tons  
23  
24     Fans:                         EF #1 (Toilets 110 & 112)  
25                                    S.C.: 11/16/94  
26                                    Capacity: 500 CFM @ 0.3" ESP  
27  
28     Pumps:                        BP #1 (Boiler #1)  
29                                    S.C.: 11/16/94  
30                                    Capacity: 200 GPM @ 50 FT.  
31  
32     Water Source  
33     Heat Pumps:                   WSHP #1 (Classrooms 10 & 12)  
34                                    S.C.: 11/16/94 (5 year Comp. Warranty)  
35                                    Filters: 1 @ 24 in. x 24 in. x 1 in.  
36                                    Capacity: 5 Tons

37 **TYPE OF HVAC SYSTEMS**

38 **NOTE: The requirement of a unit for every two classrooms has been changed.**  
39 **WCPSS will now permit similar spaces with like exposures to be grouped into one**  
40 **zone served by one unit. A maximum of four (4) classrooms per zone will be**  
41 **permitted. All designers shall be required to meet with the responsible WCPSS**  
42 **authority prior to the Schematic Design Submittal to discuss and approve the**  
43 **zoning for each project.**  
44

- 45  There are seven (7) approved systems for school buildings:  
46     1. Four (4) pipe constant speed pumping system with chiller/boiler and single-zone  
47        central station air handling units.  
48     2. Four (4) pipe variable speed pumping system with chiller/boiler and single-zone  
49        central station air handling units.  
50     3. Closed loop water source heat pump system.  
51     4. Two (2) pipe, dual temperature, constant speed pump system with chiller/boiler and  
52        single-zone central station air handling units.

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
March, 1999

- 1 5. Two (2) pipe, dual temperature, variable speed pump system with chiller/boiler and  
2 single-zone central station air handling units.  
3 6. Split system heat pump systems with a central station AHU in building and heat pump  
4 unit outdoors. This system should only be used for a small isolated building or for  
5 special zones, such as administrative area, or media center.  
6 7. Geothermal heat pump system.  
7  Packaged air cooled chillers are preferred.  
8  Engineers are encouraged to investigate the use of thermal storage and alternative cooling  
9 sources as a means to reduce building energy consumption.  
10  **Do not use** roof top units  
11  **Do not use** variable air volume systems.  
12  Designate areas as 10 and 12 month for zoning purposes. 12 month areas **shall** be  
13 served by separate HVAC Systems not requiring central plant operation unless their  
14 combined loads indicate efficient and economical operating of central plant during  
15 normally unoccupied periods. Administrative Areas and Media Centers are normally 12  
16 month areas.  
17

18 **FUEL SOURCES**

- 19  Cooling  
20 1. Electricity **shall** be used for all cooling equipment and heat pumps.  
21  Heating  
22 1. Natural gas **shall** be used in all cases where available.  
23 2. LP gas **shall** be used when natural gas is not available.  
24

25 **DESIGN CONDITIONS AND ENERGY USAGE**

26 SUMMER DESIGN CONDITIONS

- 27  
28 Indoor 75° F, 50% RH  
29 Outdoor 92° F dB, 75°F WB  
30 Load Calculation Safety Factor = 0%  
31 Note: Locker rooms **shall** be designed for an indoor summer space temperature of 80° F  
32 and 60% relative humidity.  
33

34 WINTER DESIGN CONDITIONS

- 35 Indoor 72° F  
36 Outdoor 10° F  
37 Load Calculation Safety Factor = 10%  
38  
39  Engineer **shall** design the HVAC system so as to provide building relative humidity levels  
40 less than 60% during all occupied periods, except for Media Centers which should keep  
41 the relative humidity at less than 60% at all times.  
42  HVAC system **shall** be designed so as to pretreat classroom outdoor ventilation air to  
43 prevent humidity problems.  
44  Provide a copy of all load and energy calculations to WCPSS at each design phase  
45 submittal.  
46  All new work **shall** comply with Volume X of the NC State Building Code. For new  
47 buildings, provide estimates of monthly energy use in BTU per SF and cost per SF by fuel  
48 type, using current unit fuel cost, at the design development and working drawing phases  
49 of the design to the WCPSS Energy Management Department.  
50

1 **VENTILATION**

- 2  Each building or portion thereof **shall** be provided with the capability to provide  
3 ventilation in accordance with ASHRAE 62, based on building classification and occupant  
4 load.
- 5  Fresh air intakes **shall** be located a minimum of 15 ft. away from sanitary sewer vent  
6 outlets, exhaust outlets and truck and bus loading areas.
- 7  Thermostatically controlled ventilation should be provided in main electrical room to  
8 prevent excessively high temperatures.
- 9  All spaces, which produce dust (cabinetry labs, etc.), **shall** be negatively pressurized to  
10 assist in reducing the infiltration of dust to adjacent spaces. Also, the mechanical systems  
11 for these spaces should have easily replaceable filtration systems. In addition, for those  
12 spaces programmed to have a dust collection system, the controls **shall** be designed to  
13 halt air conditioning when the dust collection system is engaged.
- 14  The heating of make-up air for welding shops is not recommended from an economical  
15 standpoint.
- 16  Work areas for internal combustion engines **shall** have provisions so that exhaust gases  
17 can be exhausted directly to the outside by a carbon monoxide exhaust system.
- 18  Paint spray rooms **shall** have special treatment with respect to ventilation and safety  
19 requirements. Paint spray booths, commercial type, are recommended. If the booth is  
20 not to be used and a paint spray room is desired, the engineer and the architect **shall**  
21 investigate thoroughly with respect to codes and standards. See Standard Building Code,  
22 Section 407, Standard Fire Prevention Code, Chapter 19.
- 23  The storage of flammable or combustible liquids **shall** be in UL-labeled cabinets with  
24 mechanical ventilation, or in storage rooms designed for the purpose. If a flammable or  
25 chemical storage room is needed, the engineer and the architect **shall** investigate  
26 thoroughly with respect to codes and standards. For flammable or combustible storage,  
27 see SBC, Section 407; Standard Fire Prevention Code, Chapter 20; NFPA 30; and NFPA  
28 70. For hazardous chemical data and reactions, see NFPA 49 and NFPA 491M.
- 29  A separate exhaust fan **shall** be provided for each chemistry or physics science  
30 laboratory and be of such capacity as to be able to quickly remove objectionable odors.  
31 Specify number of air changes on drawings. A fan is also desirable in a biology lab, but  
32 not needed as critically as in the former two areas; a fan would not be needed in a separate  
33 physics lab. A roof mounted exhaust fan with a hood and fresh air intake lover with  
34 motorized damper **shall** be provided at all KILN locations. Provide interlock switch  
35 between KILN and exhaust fan. Damper to open when fan operates. In addition to this,  
36 provide a 4 in. dia. metal dryer vent to exterior.
- 37  A separate HVAC System **shall** be provided for all gymnasium locker/dressing rooms.  
38 The system should provide 100% outside air during occupied hours. **Use** exhaust fans to  
39 remove make-up air. Air **shall** be re-circulated during unoccupied hours. Room  
40 temperature **shall** be controlled by the room sensor. The system **shall** be controlled by  
41 the BAS.
- 42  Mechanical ventilation **shall** be provided for all toilet rooms, janitor's closets, and  
43 storage rooms where odors could become a problem. Group toilets **shall** have 2 CFM per  
44 square foot minimum ventilation.
- 45  Provision **shall** be made to prevent sound transmission through any common duct  
46 system serving more than one area, such as between adjoining classrooms and toilet  
47 rooms.

48 **KITCHEN**

- 49  Automatic dry-type fire-extinguishing systems **shall** be installed in all hoods. Ansul is an  
50 acceptable system. Upon activation of the extinguishing system, all fuel **shall** be shut  
51

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
March, 1999

- 1 off, whether gas or electric, and **will** include fuel to all equipment under the hood,  
2 including fryers, broilers, griddles, and ranges. Make-up air **shall** be shut off, but exhaust  
3 fans **shall** continue exhausting. Exhaust fans **shall** have an adjustable high limit  
4 shutdown switch  
5 normally set at 350°. The fire-extinguishing system **shall** be designed in accordance  
6 with the Standard Mechanical Code, Section 307, NFPA 96 and NFPA 17. Connect into  
7 the Central Fire Alarm System. Locate a manual pull station at nearest exit.  
8  Range hood roof exhaust fans **shall** be designed to prevent air from being discharged  
9 down toward the roof.  
10  All kitchen hoods **shall** have 80% minimum outside make up air delivered at perimeter  
11 of hoods. **Do not** heat make up air.  
12  Exterior entrances to kitchens **shall** be equipped with a fly fan with automatic switch  
13 geared to opening and closing of door. Location of fan on interior of building with air  
14 directed down and outward is preferred.

15  
16 **MISCELLANEOUS HVAC ITEMS**

- 17  Install one-shot chemical feed system in all closed loop water systems.  
18  Install a "Ernest Gauge Co." visual site flow indicator in all closed loop systems in line  
19 with the one-shot chemical feed systems.  
20  Electric unit heaters with built-in thermostats **shall** be installed in all exterior mechanical  
21 rooms in lieu of hot water unit heaters.  
22  Provide dehumidification control in all media centers.  
23  All chilled water coils **shall** be selected based on a chilled water temperature of 2° F  
24 higher than that leaving the chiller. Show all selection data in a coil schedule on  
25 drawings.  
26  All HVAC equipment **shall** be selected for low noise levels that **do not** interfere with  
27 instructional activity. The noise levels in classrooms **shall not** exceed NC Level 35.  
28  The HVAC systems **shall** be provided with a complete labeling systems for all  
29 equipment, starters, piping, valves, control panels and devices, dampers rotation , valve  
30 movements, and any other system components. The equipment labels **shall** be screwed  
31 on laminated plastic with the name, (hot water pump no. 1, etc.), number, model number,  
32 capacity and any sequence of operation that is applicable.  
33  Specify fencing around all outdoor air cooled chillers, cooling towers and condensing  
34 units. Gates **shall** be large enough for service vehicles to remove equipment if necessary.  
35 Specify drains for all cooling tower locations. Area inside fence **shall** be concrete  
36 properly sloped, with fence posts located within perimeter of pad.  
37  Specify that all refrigeration compressors have five (5) years material warranties.  
38  Locate all cooler and freezer condensers outside building on reinforced concrete pad on  
39 ground, protected and for maximum ventilation. (Condensers **shall not** be located on  
40 roof)  
41  All heat pumps **shall** be factory wired down with 24 VAC control interface, NOT 24  
42 VDC.  
43  There **shall** be no open-flame heaters, open-coil electric heaters, or spark-producing  
44 electric components in areas likely to be used for spray painting or where there will be  
45 open containers of gasoline or other explosive vapors or dust.  
46  Boilers and pressure vessels **shall** be ASME-labeled and installed in accordance with the  
47 American Society of Mechanical Engineers "ASME Boiler and Pressure Vessel Code."  
48 Boiler rooms and installation of boilers **shall** conform to Section 806 of Standard  
49 Building Code.

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
**DESIGN GUIDELINES**  
6 May 1992

- 1    Each hot water boiler **shall** have a low-water cutoff and each steam boiler **shall** have an  
2   extra-low-water cutoff. Low-water cutoff should be manually reset type.
- 3    Combustion controls **shall** meet the requirements of improved Risk Mutual Insurance  
4   Corporation, IRM Spec. 205.
- 5    Equipment **shall** be ASME Code-stamped, AGA-labeled, or UL-labeled as and when  
6   applicable.
- 7    Hot water relief valves, refrigerant relief devices, and steam pop-off safety valves **must**  
8   be piped to location to minimize danger to personnel or students upon relief. Hot water  
9   relief valves should be piped to exterior or to funnel-type floor drains located near the  
10   equipment.
- 11    Filters for all air handling equipment **shall** be mounted in 2 in. thick permanent metal  
12   frames with 1 in. thick polyester media. Filter access **must** be readily accessible and  
13   require no tools to change. Specify that any questionable means of access **shall** be  
14   replaced at no additional cost to owner.
- 15    All major items of mechanical equipment that employ any solid state electronic  
16   components **shall** be fully protected from electrical surges and lighting.
- 17    For all hydronic heating/cooling systems, provide manual shut off valves at point where  
18   main supply and return lines leave the central mechanical room, where piping leaves  
19   and/or enters a building and in mains such that classroom wings can be isolated.
- 20    Use of pneumatic controls is not acceptable.
- 21    **Do not** locate AHU's in same room as boilers.
- 22    Provide permanently fixed access to ceiling mounted air handling units in Gyms and  
23   Auditoriums for maintenance use. Maintenance on these units **shall not** require a boom,  
24   lift or extension ladder.
- 25    The **use** of outdoor boilers **shall** be prohibited.
- 26
- 27   END OF SECTION

1  
2 **SECTION 15550 - HVAC PIPING SYSTEMS**  
3

4 **GENERAL**

- 5  All piping systems for HVAC systems in buildings **shall** be schedule 40, black steel with  
6 either welded, screwed or victaulic joints except as follows in Products below.  
7

8 **PRODUCT**

- 9  Condensate drains from AHU's and fan coil units **shall** be type "L" copper. PVC drain  
10 lines **shall not** be permitted.  
11  Insulate all drain lines.  
12  Provide unions on both sides of p-trap.  
13  Cold water lines and chilled water/hot water run outs (1 in. and smaller) may be type "K"  
14 copper with soldered joints. Use 95-5 solder.  
15  Use "Ric-Wil" or similar conduit system for all underground hot water piping system.  
16

17 **EXECUTION**

- 18  Engineer **shall** specify and show on plans expansion loops on all hot water piping runs  
19 over 200 feet in length.  
20  Support piping as recommended in ASME Handbook. **Do not** support piping from bar  
21 joist bridging.  
22  Paint and color-code all exposed piping system.  
23 a. All exposed piping, both insulated and uninsulated **shall** be painted and labeled.  
24 b. Piping **shall** be color coded as follows with flow arrows and labels located at 10  
25 foot intervals at all turns and at each floor or wall partition:  
26 Chilled water - Light Blue  
27 Hot water - Light Red  
28 Dual Temperature - Orange  
29 Make up water - Dark Blue  
30 Condenser water - Green  
31 Gas Lines - Yellow  
32 c. All underground lines **shall** be marked with a bright colored continuous - printed  
33 plastic tape on top of the line.  
34  Provide positive freeze protection for all water systems subject to freezing conditions  
35 such as air-cooled outdoor chillers, cooling towers, outdoor piping (above ground) etc.  
36  All piping systems **shall** be thoroughly flushed out before placing in operation. This is  
37 especially critical for all hydronic systems. Hydronic systems **shall** be connected so as  
38 to by-pass the units before flushing begins and then flushed and the filters cleaned out at  
39 least three (3) times before the units are connected to the system and placed in  
40 operation. All cooling towers **shall** be completely cleaned and flushed after all systems  
41 are in operation and the site work has been completed. (Engineer to be present).  
42  Provide additional bulb wells in central plant piping for electronic sensors. Coordinate  
43 with the Energy Management Department for locations of additional wells. Show detail  
44 of wells on drawings.  
45  Provide shut-off valves for all hydronic mains at all take-offs to mechanical rooms and  
46 pump rooms.  
47  Also provide shut-off valves at the supply and return side of all equipment to provide for  
48 removal and repair.  
49  Provide Pete's Plugs at each hydronic heat pump and/or fan-coil units and 2 test kits  
50 containing thermometers and pressure gauges for each building. Have test kits turned  
51 over to Energy Management Department.

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
**DESIGN GUIDELINES**  
6 May 1992

- 1  All chilled water piping **shall** have 2 in. thick fiberglass insulation all with a vapor-proof
- 2 jacket.
- 3  Specify canvas jacket lagged in place for painting on all exposed piping in occupied
- 4 spaces and mechanical rooms.
- 5  Provide section on pressure testing of all piping systems.
- 6  Insulate all hot water and domestic hot and cold water with 1 in. thick fiberglass
- 7 insulation.
- 8  All water make-up assemblies **shall** be provided with a backflow preventer.
- 9  Specify an aluminum jacket on all outdoor piping.
- 10  Provide automatic chemical feed systems to all "open" systems such as cooling towers.
- 11 Coordinate with the WCPSS Physical Plant Department concerning the type system, the
- 12 water test, chemicals and water management program.
- 13  Pipes venting gas from appliances or other devices **shall** terminate outside the building 2
- 14 ft. above any roof line within 10 ft.. Keep away from louvers and overhangs.
- 15  Specify all pipe supports to have saddles and blocking and all exposed piping, hangers,
- 16 saddles and supports to be painted with two (2) coats.
- 17  Specify all exposed piping in occupied spaces below eight feet to be covered with a 20
- 18 gauge metal jacket.
- 19  Provide chrome escutcheon rings at all exposed ceiling and wall pipe penetrations.
- 20  Show by-pass piping for all heat exchangers.
- 21  Show why strainers in inlet piping to heat exchanger and cooling tower outlet (unless
- 22 strainer is built-in basin).
- 23  Specify all damper operators, control and service valves to be installed such that they can
- 24 be serviced by personnel standing on the floor of the Mechanical Room.
- 25  Engineer **shall** require contractor to dimension actual location of all underground piping
- 26 on as-built drawings. A minimum of two (2) dimensions from building reference points
- 27 **shall** be provided and a bury depth indicated.

28  
29

**END OF SECTION**

1  
2 **SECTION 15760 - COOLING TOWERS**  
3

4 **GENERAL**

- 5  Wake County Public School System standardized on induced-draft propeller fan cooling  
6 towers for all school buildings using centrifugal chillers or hydronic heat pump systems.  
7 This decision was based on the maintenance requirements of these towers.  
8

9 **PRODUCTS**

- 10  The cooling tower **shall** be factory fabricated Baltimore Air Coil Co., Inc. Series 3000 or  
11 equal by Marley and Evapco.  
12  All steel components **shall** be provided with a corrosion protection system G-210.  
13  The tower **shall** be equipped with an electric basin heater sized to maintain 40 deg. F.  
14 pan water with a 10 deg. F. outdoor air temperature. Basin heater **shall** have built-in  
15 thermostatic control and low water cut-off.  
16  The tower **shall** have a water level control utilizing a large diameter plastic float with  
17 brass shut-off valve. Provide additional pressure reducing valve on cold water feed.  
18  The tower **shall** be selected on 79 deg. F. entering air wet bulb temperature.  
19  The cold water basin **shall** be constructed stainless steel.  
20  Tower accessories **shall** include: hinged access doors on the tower end walls, large area  
21 lift-out steel strainers with perforated openings sized smaller than water distribution  
22 nozzle orifices, integral anti-vortexing hood, 3 in. flush connection, internal walkway,  
23 and exterior access ladder.  
24  Inlet louvers **shall** be Waved Form Fiberglass Reinforced Polyester (FRP).  
25  Hot water distribution basins **shall** be open gravity type with corrosion protection  
26 system G-210 and pan covers. Distribution weirs and plastic metering orifices **shall** be  
27 provided to insure even distribution of water over the wet deck surface.  
28  Integral flow balancing valves **shall** be factory-installed in the hot water basin to  
29 distribute flow evenly between the basins.  
30  The wet deck surface and integral drift eliminator **shall** be formed from Polyvinyl  
31 Chloride.  
32  Fans **shall** be fixed pitch, heavy duty, cast aluminum, axial flow. Fan and shaft **shall** be  
33 supported by heavy duty, re-lubricated ball bearings with special moisture-proof seals,  
34 grease packed, self-aligning and integral slinger rings. All bearings **shall** be designed for a  
35 minimum life of 40,000 hours. Fan sheave **shall** be cast nylon and motor sheave **shall**  
36 be protected from moist discharge air by a vented enclosure.  
37  Fan motor **shall** be totally enclosed air-over (TEAO), 1800 rpm, reversible, squirrel  
38 cage, ball bearing type. Motor **shall** be furnished with special moisture protection on  
39 windings, shafts and bearings. A heavy gauge, hot-dip galvanized wire fan guard **shall** be  
40 provided over each fan cylinder.  
41

42  
43 **EXECUTION**  
44

- 45  The tower **shall** be installed on two (2) reinforced concrete piers with the suction outlet  
46 located above the centerline of the condenser water pump of sufficient height to provide  
47 proper NPSH to the pump.  
48  The overflow/drain **shall** be piped full size to the storm drainage system or sewage  
49 system as code or municipal rules dictated.  
50  Proper clearance **shall** be provided around the tower for proper air flow and service  
51 requirements.

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
**DESIGN GUIDELINES**  
6 May 1992

- 1  Cooling Towers **shall** be completely flushed and cleaned before system is placed in  
2 operation and every (4) four weeks until all site work is completed.

3  
4

**END OF SECTION**

1  
2 **SECTION 15855 - AIR HANDLING UNITS AND FAN COIL UNITS**  
3

4 **GENERAL**

- 5  All air handling units and fan-coil units **shall** be equipped with a heavy metal casing, (18  
6 gauge min.) fans, heating and/or cooling coils and a disposable media type filters.  
7

8 **PRODUCTS**

- 9  Approved air handling units **shall** be Trane, Carrier, or McQuay, Central Station  
10 Equipment.  
11  Carrier Model 39L is permitted only when unit airflow requirement is less than 2,000  
12 cfm.  
13  Approved fan-coil units **shall** be American Air Filter, Air Therm, Carrier and Trane  
14 when required for renovation projects only. All control valves, speed switches **shall** be  
15 factory supplied and installed inside the units. Thermostats **shall** be wall mounted. Use  
16 direct drive models only.  
17  All air handling units and fan coils **shall** have factory-fabricated filter access assemblies  
18 complete with metal frames and disposable media. Tools **shall not** be required to access  
19 and change filters on air handling units (**use** hinged access doors with cam locks).  
20 Mechanical contractor **shall** submit, upon final walk-through, a summary of all HVAC  
21 equipment indicating filter media size and numbers of filters (this **shall** also be part of  
22 the Operation & Maintenance manual). The following is an example of this information  
23 which is to be provided on all projects:  
24

25 WAKE COUNTY PUBLIC SCHOOL SYSTEM  
26 NEW SCHOOLS/RENOVATIONS  
27 FILTER LIST FOR  
28 ENERGY AND PHYSICAL PLANT  
29

30 SCHOOL NAME: \_\_\_\_\_  
31  
32 MECH. ROOM #: \_\_\_\_\_ FILTER SIZE: \_\_\_\_\_  
33 AIR HANDLER #: \_\_\_\_\_ QUANTITY: \_\_\_\_\_  
34  
35 MECH. ROOM #: \_\_\_\_\_ FILTER SIZE: \_\_\_\_\_  
36 AIR HANDLER #: \_\_\_\_\_ QUANTITY: \_\_\_\_\_  
37  
38 MECH. ROOM #: \_\_\_\_\_ FILTER SIZE: \_\_\_\_\_  
39 AIR HANDLER #: \_\_\_\_\_ QUANTITY: \_\_\_\_\_  
40

- 41  Contractor **shall** also be required to provide an engraved plastic laminated label on the  
42 exterior of each AHU. See Section 15500 for further information on label.  
43  Contractor **shall** install new set of filters before final inspection and provide spare set of  
44 filters to the Owner.  
45  Use low-leakage, outside air intake dampers for all air handling units and fan coil units.  
46 Maximum leakage of 1/2 of 1% at pressure differentials under 4 in. WG.  
47  Provide spare belt for each belt driven piece of equipment.  
48

49 **END OF SECTION**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30

**SECTION 15860 - DUCTWORK**

**GENERAL**

All ductwork, supply, return and outside air **shall** be constructed in accordance with SMACNA standards.

**PRODUCTS**

- All ductwork except kitchen hood and certain other hood exhaust **shall** be galvanized sheet metal with zinc coating complying with ASTM A527 and SMACNA standards.
- Exposed ductwork **shall** be mill phosphatized for painting.
- Use stainless steel ductwork with welded, water tight joints for kitchen dish washer hood.
- Low-pressure ductwork **shall** be rectangular. Medium and high-pressure ductwork **shall** be spiral round duct.
- Insulate all ductwork, except exhaust ductwork, by wrapping with minimum 2 in. thick fiberglass insulation with vapor proof jacket.
- Exposed ductwork **shall** be double wall insulated spiral duct with paint grip finish. Discuss with WCPSS the use of exposed ductwork prior to incorporating it into any design.
- Flexible ducts may be used for above ceiling lay-in system. Flexible ducts to be UL Class 1 insulated type with foil wrapper.

**EXECUTION**

- Seal all ductwork joints, seams and take-offs airtight with non-hardening mastic or liquid elastic sealant. Engineer to witness ducts have been sealed before ducts can be insulated.
- Do not** support ductwork from bar joist bridging.
- Support all flexible ducts a maximum of 5 ft. on center and at all changes in direction so as to prevent sagging and crimping from occurring. Note: All flex duct to receive a minimum of one (1) duct hanger.

**END OF SECTION**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22

**SECTION 15865 - DIFFUSERS AND GRILLES**

**GENERAL**

- A complete system of ceiling and sidewall diffusers and grilles for supply, return and exhaust air **shall** be provided throughout the building.
- Perforated diffusers **shall not** be permitted.

**PRODUCTS**

- The diffusers and grilles **shall** be constructed of steel with painted surfaces.
- Aluminum diffusers and grilles **shall** be specified for moist and humid locations (ie: Locker rooms, showers and training rooms).
- In general provide 4-way adjustable stamped louver faced diffusers and double deflection registers
- Provide heavy duty steel return air grilles located in gymnasiums, multi-purpose rooms and in all locations where the grille is within 8 ft. of the floor. Grilles **shall** be all welded construction with 1/8 in. thick grille blades, 14 gauge blade mullions on 6 in. centers with 18 gauge frame reinforced at the corners.
- Engineer **shall** show location of all balancing dampers on plans.
- Engineer shall select air distribution so as to insure heat can be delivered to floor level.

**END OF SECTION**

1  
2 **SECTION 15900 - BUILDING AUTOMATION AND CONTROL SYSTEM (BAS)**  
3

4 **PRODUCTS**

- 5  The Building Control and Automation System **shall** be a Direct Digital Control System  
6 and **shall** be a completely compatible system in all respects to the Barber-Colman  
7 Network 8000 System currently in use by the Energy Management Department of the  
8 WCPSS. See Attachment 15900-A for detailed specifications. Contact the Energy  
9 Management Department of WCPSS for guidance and questions.

10  
11 **EXECUTION**

- 12  All control sequences **shall** be discussed with Energy Management and agreeable to both  
13 the Engineer and Energy Management. A clear written sequence of operation **shall** be  
14 an integral part of the specification. Sequence of operation **shall** follow equipment  
15 manufacturer's recommendations.
- 16  Engineer to show a complete control sequence and a control diagram on the drawings.
- 17  All sensor and EMS panel locations **shall** be discussed with Energy Management and  
18 clearly shown on drawing. Any field modifications must be approved by Engineer and  
19 Energy Management. Acceptable height of GCM's, LCM's and GCS's is 60 in. above  
20 finish floor.
- 21  Specify lightning and surge protection on all building automation system panels and  
22 telephone modems associated with these systems.
- 23  Specify momentary contact push button for night override in a flush mounted panel  
24 located in the administrative area corresponding to zones in plans and specifications.
- 25  All temperature sensors **shall** be flush mount, stainless steel PreCon 10k thermistor or  
26 equivalent.
- 27  Eliminate any reference to time clocks. Perform all time of day control functions  
28 through the Building Automation (DDC) system.
- 29  Provide space for owner provided cabinet in main mechanical room for placement of  
30 reduced sized drawings, specifications, Operations and Maintenance manuals etc.  
31 Coordinate between Architect/Engineer.
- 32  Mechanical Contractor **shall** provide input from each walk-in cooler and freezer to  
33 building automation system for system alarm.
- 34  Engineer **shall** be responsible for completely testing Control System for proper  
35 operations including each control device and also running system through the entire  
36 control sequence. An Owner Representative should also be present.
- 37  Electrical Contractor to provide conduit from demand meter to main Mechanical Room.  
38 Electrical contractor **shall** be responsible for all costs associated with demand meter.
- 39  Send complete copies of each design phase submittal plans and specifications to  
40 Diversified Control Systems, Inc., 5400 S. Miami Blvd., Suite 140, Creekstone Crossings,  
41 Morrisville, NC 27560.

42  
43 **END OF SECTION**

1  
2 **ATTACHMENT 15900-A - BUILDING LEVEL DIRECT DIGITAL CONTROL SYSTEM**  
3

4 **RELATED DOCUMENTS**

- 5  Drawings and general provisions of Contract, including General and Supplementary  
6 Conditions and Division-1 Specifications sections, apply to the work of this section.  
7

8 **DEFINITIONS**

- 9  Algorithm: A logical procedure for solving a recurrent mathematical problem. A  
10 prescribed set of well-defined rules or processes for the solution of a problem in a finite  
11 number of steps.
- 12  Analog: A continuously varying signal value (e.g. temperature, current, velocity).
- 13  Auxiliary Control Units (ACU): The ACU's **shall** be functionally a part of an RCU, but  
14 may be located remotely from the RCU, and **shall** communicate over a dedicated  
15 communication circuit (RS232 or equivalent bus). ACU's **shall** be used to connect  
16 remote inputs and outputs to a supervisory RCU and **shall** contain all necessary I/O  
17 functions to connect to field sensors and control devices. ACU operation **shall** be fully  
18 supervised by the connected RCU.
- 19  Baud: A Baud is a signal change in a communication link. One signal change can represent  
20 one or more bits of information depending on type of transmission scheme. Simple  
21 peripheral communication is normally one bit per Baud. (e.g., Baud Rate = 1200 Baud/sec  
22 is 1200 bits/sec if one signal change = 1 bit).
- 23  Binary: A two-state system where an "on" condition is represented by a high signal level  
24 and an "off" condition is represented by a low signal level.
- 25  Control Unit (CU): The CU is the microprocessor-based device(s) by which the direct  
26 digital control algorithms are processed. The CU may also include the input and output  
27 data processing function.
- 28  Control Wiring: Includes conduit, wire and wiring devices to install complete HVAC  
29 control systems including motor control circuits, interlocks, thermostats, PE and EP  
30 switches and like devices. Includes all wiring from a DDC cabinet to all sensors and points  
31 defined and/or required to execute the sequence of operation.
- 32  DCP (Distributed Control Panel): Panels which house the CU, input and output functions,  
33 power supplies, relays, transducers and other required hardware.
- 34  DDC (Direct Digital Control): A control loop in which a digital controller periodically  
35 updates the process as a function of a set of measured control variables and a given set of  
36 control algorithms.
- 37  Deadband: A temperature range over which no heating or cooling is supplied (i.e., 72-78  
38 deg. F., as opposed to single point changeover or overlap).
- 39  Diagnostic Program: Machine-executable instructions used to detect and isolate system  
40 and component malfunctions.
- 41  Distributed Control System: A system whereby control processing is decentralized and  
42 independent of a central computer. Operational control, processing and data are  
43 distributed to computers throughout the system. Little functionality is lost in any  
44 processor on the network if communication is lost with other processors. Distributed  
45 control implies distributed processing and distributed data.
- 46
- 47
- 48  Downline Load: The electronic transfer of programs and data files from the Global  
49 Control Supervisory Station to the building level DDC system or building operator  
50 workstation with secondary memory devices, to remote, distributed CU's.
- 51  Input/Output (I/O): Input and output functions of the DDC control unit (CU).

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
6 May 1992

- 1  Man-Machine Interface (MMI): The proprietary hardware/software system (Siebe "Ulti  
2 Vist"), located at the WCPSS central office, for providing a method for an operator to  
3 communicate with any building DDC system in any school. The MMI allows the  
4 operator to command, monitor, and program any DDC system in any school.
- 5  Network: A data communications system connecting information-processing equipment.
- 6  Operator Workstation: Personal Computer (PC) based Terminal and Cathode Ray Tube  
7 (CRT), which performs the primary man-machine functions of the building ECC.
- 8  Operating System (OS): Software which controls the execution of computer programs and  
9 which proves scheduling, debugging, input/output controls, accounting, compilation,  
10 storage assignment, data management, and related services.
- 11  Peripheral: Input/output equipment used to communicate with the computer and make  
12 copies of system outputs. Peripherals include CRT, printer, tape deck, and diskette.
- 13  Remote Control Units (RCU): As "master" level CU's, the RCU's **shall** communicate  
14 with other RCU's (and with the ECC) over a peer-to-peer local area network or over the  
15 EMCS Ethernet 10BaseT LAN, and **shall** provide general purpose control functions,  
16 global control functions, and history recording functions.
- 17  Unitary Control Units (UCU): The UCU's **shall** be microprocessor based, dedicated  
18 purpose devices, designed and programmed to accomplish a specific purpose.

19  
20 **GENERAL REQUIREMENTS**

- 21  Control Sub-Contractor: The Mechanical Contractor **shall** employ the services of a  
22 control subcontractor to furnish and install a complete DDC control system for  
23 automatic environmental control and energy management.
- 24  Network Interface Module: The control subcontractor **shall** be responsible for providing  
25 a Network Interface Module (NIM), including hardware and/or software, to provide a  
26 100% complete and 100% compatible interface between the Owner's MMI and this DDC  
27 system in order for all functions to be performed and defined at the MMI and downline  
28 loaded to the building level system via a telephone link at a baud rate of not less than  
29 9600 bps. The NIM **shall** interface to the building level DDC system through a building  
30 level RCU. If additional interface "gateways" are required, they **shall** be provided by the  
31 control subcontractor. The cost to provide this interface **shall** be part of the system bid  
32 price.
- 33  Interface Demonstration: The control subcontractor **shall** contact the Owner, at least  
34 fourteen (14) working days prior to bidding, and provide complete documentation of the  
35 entire specification herein and a demonstration of the following operational interfaces  
36 and requirements between the Owner's MMI and the proposed system:
  - 37 1. Graphic screen monitoring
  - 38 2. Alarm reporting
  - 39 3. Full programmability (on-line and off-line)
  - 40 4. Trend reporting
  - 41 5. Energy usage and monitoring
  - 42 6. Maintenance Management
  - 43 7. Dynamic run time monitoring
  - 44 8. Programming all building level controllers via modem and the MMI
  - 45 9. "Terminal" mode programming of all building level controllers via modem
  - 46 10. Database uploads/downloads to building controllers to and from the MMI
  - 47 11. Automated reporting to the MMI of system diagnostics/status diagnostics
  - 48 12. Ability to modify all point configuration data via the MMI and in terminal mode
- 49  Configuration: The control subcontractor **shall** provide an IBM OS/2-compatible version  
50 of the RCU's operating system so that the building system database can be configured/  
51 reconfigured through the MMI and then downloaded to the building level system.

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
March, 1999

1 Likewise, the RCU **shall** upload its database to the MMI upon command or at operator-  
2 defined intervals for archiving and backup. Database changes made at the building level  
3 **shall** automatically modify the MMI master level database during the next dial-up  
4 session or automatically after log off occurs on site, as selected by the operator.  
5

6 **QUALITY ASSURANCE**

- 7  Control subcontractor **shall** meet the following criteria:
- 8 1. Be a factory branch or authorized representative of a national firm having a minimum of  
9 five years experience in the design and installation of computerized building systems  
10 similar in performance to that specified. Provide evidence of experience by submitting  
11 resumes of the project manager, the local manager, project engineer, the application  
12 engineering staff, and the electronic technicians to be involved with the supervision, the  
13 engineering, and the installation of the system. Information concerning the amount of  
14 training and experience **shall** be included in each resume.
  - 15 2. Be in compliance with ISO-9001 (Model for Quality Assurance in Design/ Development,  
16 Production, Installation and Servicing) as issued by the International Organization for  
17 Standardization.
  - 18 3. Use only factory trained and certified personnel to perform programming, final DCP  
19 connections, system start-up, diagnostics and warranty service. Maintain a 24-hour per  
20 day service organization within two hours auto travel time from the project.
- 21  Codes and Standards: The components of the DDC system **shall** comply with the latest  
22 editions of the following codes and standards, as applicable:
- 23 1. Instrument Society of America (ISA):  
24 57.3 Quality Standard for Instrument Air (R1981)
  - 25 2. National Fire Protection Association (NFPA):  
26 70 National Electrical Code
  - 27 3. Federal Communications Commission (FCC):  
28 Rules and Regulations Volume II (July 1986) Part 15, Subpart J, Class A,  
29 Radio Frequency Devices
  - 30 4. Underwriters Laboratories (UL):  
31 UL 864 Sub-categories UUKL, UOXX, UDTZ; Fire Signaling and Smoke  
32 Control Systems  
33 UL 873 Temperature Indication and Regulating Equipment  
34 UL 916 Energy Management Systems
  - 35 5. For electrical equipment and products, comply with applicable NEMA standards, and refer  
36 to NEMA standards for definitions of terminology herein. Comply with National  
37 Electrical Code (NFPA 70) for workmanship and installation requirements.
  - 38 6. Labeling: All products **shall** be labeled with the appropriate approval markings.
- 39  Performance Tests:
- 40 1. Demonstrate that all controls are installed, adjusted, and can perform all functions  
41 required by the drawings and specifications. When coordinated with the Owner, this  
42 demonstration may be performed in conjunction with instructions to the Owner's  
43 operations personnel.
  - 44 2. Individual Building Final Operational Tests:
    - 45 a. Performance Test Period: Not less than 336 consecutive hours to demonstrate  
46 proper functioning of the complete system. Continue test on a day to day basis until  
47 the performance standard is met.
    - 48 b. Acceptance Performance Standard: Operation at an average effectiveness level  
49 (AEL) of at least 95 percent for the performance test period. Whenever downtime  
50 occurs, correct defects before resuming test. Failure, due to an  
51 individual sensor or controller, **shall not** count as system downtime provided that:  
52 - The system records the fault.

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
6 May 1992

- 1           - The AEL for all sensors and controllers together is at least 99 percent of the test  
2           period.  
3

4       **SUBMITTALS**

5  
6       GENERAL

- 7        Submittals **shall** demonstrate compliance with technical requirements by reference to  
8       each subsection of this specification. Where a specific item does not comply with  
9       specification requirements, the deviation **shall** be presented to the Owner and A-E a  
10       minimum of 14 working days prior to bid, along with information as to how the intent of  
11       the specification requirement is to be satisfied, for approval. It is the Contractor's  
12       responsibility to demonstrate compliance. The Wake County Public School System  
13       **shall** have the right to reject any substitutions with deviate from this specification.
- 14        Owner meetings: The control subcontractor **shall** schedule a minimum of two meetings  
15       with Owner to review control drawings, software, and strategies before proceeding with  
16       the installation. The A/E, upon receipt of initial submittals, **shall** schedule the first  
17       meeting. The second meeting **shall** be scheduled following the first meeting.
- 18        Manufacturer's literature and data for all components including the following **shall** be  
19       submitted:  
20       1. One-line schematics of control piping and wiring of sensors and actuators to DCP  
21       cabinets.  
22       2. Schematic of all termination points within each cabinet.  
23       3. Catalog cut sheets of all equipment used. This includes, but is not limited to DCP's,  
24       peripherals, sensors, actuators, etc.  
25       4. Detailed descriptions of specified DDC algorithms.  
26       5. Flow charts for each sequence of operation or control strategy.  
27       6. Define a preliminary scope and sequence of field tests that **will** be executed to  
28       demonstrate that the system performs all specified functions. Include in the scope the  
29       method by which system accuracy **will** be demonstrated.  
30       7. FCC Part 15 listing certificates for all equipment.  
31       8. UL 864 and UL 873 and/or UL 916 listing certificates for all equipment.  
32       9. Details of communications wiring, electrical isolation, surge and lightning protection,  
33       etc.
- 34        Control Drawings: Integrate with HVAC drawings on one-line control diagrams. Show  
35       and identify all HVAC equipment and control devices for all air, water and steam systems.  
36       Equipment and control labels **shall** correspond to those shown on the drawings.
- 37        As-Built Control Drawings: Provide as part of project closeout. See Division 1.  
38       1. One complete set of prints.  
39       2. One set of applicable systems prints wall mounted in each mechanical room.  
40       3. One set of drawings in electronic media storage, AutoCAD V12.DWG format or fully  
41       compatible .DXF format.  
42
- 43        Operation and Maintenance (O/M) Manuals: Provide detailed product information on all  
44       control hardware, including but not limited to relays, sensors, transducers, actuators, etc.  
45       Any custom control programs **shall** be documented and explained in English and step-by-  
46       step instructions on how to change parameters and create additional custom control  
47       programs provided. Coordinate documentation format(s) with Wake County Public  
48       School System prior to creating O/M Manuals.  
49
- 50        Final Control Algorithms Documentation: Provide final version of all control software at  
51       completion of construction. Provide, for each control algorithm, a flowchart with

1 English language descriptions of all variables, functions, decisions, etc.  
2  
3

4 **TRAINING**

- 5  The controls subcontractor **shall** provide the Owner's system operators complete  
6 instructions for proper control of the system under all modes of operation. These modes  
7 **shall** include, but not be limited to, summer/winter, occupied/unoccupied, energy  
8 management, alarm event sequences, etc. Provide on the job training during start-up,  
9 checkout, and performance test period. On the job training **shall** consist of facilities  
10 personnel working with the Control System Supplier's installation and test personnel on a  
11 daily basis. During the performance test period, provide five 8-hour periods of  
12 instruction.

13 \*\*\*\*\*SPEC WRITER: IF OWNER DESIRES FORMAL INSTRUCTION,  
14 INCLUDE THE FOLLOWING PARAGRAPH AND INCLUDE A BID ALTERNATE FOR  
15 IT.\*\*\*\*\*

16  
17 Additional Instruction: Formal instruction, for a total of 24 classroom hours for up to  
18 10 persons, conducted prior to the performance test period, at a time mutually  
19 agreeable to the Control System Supplier and the Owner. The instructions **shall** be  
20 conducted during normal working hours, Monday through Friday at the job site and at  
21 the Energy Management Office, as directed by Owner.  
22

- 23  The O/M Manuals **shall** contain approved submittals as outlined above. In addition,  
24 provide diagrammatic layouts of the DDC systems specified. The layouts **shall** show all  
25 DDC cabinets, all connected mechanical systems, location and function of each sensor,  
26 actuator, and equipment cut sheets of the entire system. O/M Manual **shall** contain a  
27 detailed description of the systems and a complete listing of all software programs  
28 required to perform the sequence of operation. O/M Manual **shall** describe all commands,  
29 operating and trouble shooting instructions, and routine maintenance procedures to be  
30 used with the systems. Three (3) copies **shall** be supplied and utilized in operator's  
31 training curriculum.

32 **WARRANTY SERVICE**

- 33  Provide all labor, material and equipment necessary to maintain beneficial performance  
34 of the entire control system for a period of one (1) year after acceptance of the system  
35 or parts thereof, by an authorized representative of the owner. Any defects in  
36 workmanship or material during the warranty period **shall** be promptly corrected by the  
37 contractor at no charge to the owner. All work **shall** be accomplished during normal  
38 working hours, Monday through Friday excluding legal holidays. Precaution **shall** be  
39 taken to minimize disruption of facility operations.  
40  Owner's involvement in modifications to hardware and/or software or the addition of  
41 panels and points **shall not** void warranty.  
42

43 **PART 2 - CONTROL UNITS**

44 **GENERAL DESCRIPTION**

- 45  The Building Level DDC system **shall** be configured as a distributed processing network  
46 of direct digital control units connected to the existing MMI via a network interface  
47 module and dial-up telephone interface. **The system shall be completely modular**  
48 **and stand-alone in both hardware and software** and allow for expansion in both  
49 function and capacity. **Systems requiring a host processor or ECC for any of the**  
50 **systems control operations are not acceptable.**  
51  Job Conditions (Environmental Conditions of Operation)

1           1. The DCP's and all associated equipment **shall** be designed to operate in ambient  
2 conditions of 35 to 120 degrees F at a relative humidity of 0 to 95 percent  
3 non-condensing.

4           2. CU's **shall** operate properly with power fluctuations of plus 15 percent to minus  
5 10 percent of nominal supply voltage.

6  
7           3. Sensors and controlling devices **shall** be designed to operate  
8 in the environment which they are sensing or controlling but  
9 not less severe than for DCP's.

- 10  All DCP equipment **shall** be properly mounted and organized in a grounded UL-listed  
11 NEMA 1 cabinet (panel). Cabinet **shall** protect DCP equipment from dust, liquids or  
12 accidental blows. Cabinets with strong and framed transparent laminated plastic doors or  
13 windows are acceptable.

## 14 15 CONTROL UNITS

### 16 GENERAL

- 17  Control Units (CU): Multiple digital CU's **shall** be provided. Failure of any single  
18 controller **shall** have no effect on other controllers, except where a global control  
19 strategy is involved. All control functions **shall** be resident in the CU's, including those  
20 involved in building-wide strategies. There may be up to three types of CU's:

21           1. Remote Control Units (RCU): The RCU's **shall** communicate with other RCU's  
22 (and with the ECC) over a peer-to-peer local area network (Level 1 LAN) and **shall**  
23 provide general purpose control functions, global control functions, and history  
24 recording functions. The RCU's **shall** be provided as a networking stand-alone  
25 energy management panel enclosed in a sturdy metal enclosure containing a 16 bit  
26 microcomputer with nonvolatile memory, peripheral ports for CRT, printer and auto  
27 answer/auto dial modem(s), network communications, battery back-up, onboard  
28 keypad and display, and utilize a multi-tasking, multi-user operating system.

29           2. Auxiliary Control Units (ACU): The ACU's **shall** be functionally a part of an  
30 RCU, but may be located remotely from the RCU, and **shall** communicate over a  
31 dedicated communication circuit (Level 2 LAN, an RS232 or equivalent bus). ACU's  
32 **shall** be used to connect remote inputs and outputs to a supervisory RCU and **shall**  
33 contain all necessary I/O functions to connect to field sensors and control devices.  
34 ACU operation **shall** be fully supervised by the connected RCU.

35           3. Unitary Control Units (UCU): The UCU's **shall** be microprocessor based  
36 dedicated purpose devices, designed and programmed to accomplish a specific  
37 purpose. UCU's **shall** communicate with RCU's/ACU's over the Level 2 LAN.

- 38  CU's **shall** be microprocessor-based with all hardware, software, and communication  
39 interfaces. CU's **shall** have access to data within the network as needed in order to  
40 accomplish required global control strategies. If communication between RCU's (or  
41 between an RCU and the ECC) is disrupted, each CU **shall** continue to operate in  
42 standalone mode. Likewise, if communication between an ACU and its connected RCU,  
43 or between a UCU and its connected RCU, is disrupted, each CU **shall** continue to  
44 operate in standalone mode. The controllers **shall** each be either 32 bit, 16 bit, or 8 bit  
45 microprocessors as required to meet individual requirements. Controllers **shall** be  
46 configured in a true distributed manner where input-output processing is a function of the  
47 DDC controller.

- 48  Controllers **shall** be modular and wired in a grounded UL-listed NEMA 1 enclosed  
49 Distributed Control Panel (DCP) complete with all relays, digital to analog converters  
50 and terminal strips.

- 51  Controllers **shall** utilize Programmable Read-Only Memory (PROM) for application  
52 software storage and may utilize Random Access Memory (RAM) for general operation

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
March, 1999

1 requirement. All DDC algorithms and parameters **shall** be RAM-based for ready access  
2 for modification and adjustment. RAM **shall** be provided with minimum 72 hours battery  
3 backup. (Controllers that are downloaded automatically following power fail/restart or  
4 that have non-volatile RAM need not have battery backup.)

- 5  Diagnostic Devices: Each CU **shall** be supplied with connections to which maintenance  
6 personnel can connect portable diagnostic operators terminals (PDOT's) for data display,  
7 setpoint modification, and reloading and modification of controller programs. Unless the  
8 owner has other control systems in place which are identical to that proposed for this  
9 project and already has a portable diagnostic operator's terminal(s) (PDOT) which can be  
10 used to troubleshoot local HVAC equipment, provide a PDOT as part of this project. It  
11 **shall** be possible for the user to completely operate the controller via the PDOT and  
12 completely exercise all valves and dampers via the PDOT, display values in complete  
13 engineering units for setting analog control values, reading digital status, setting control  
14 parameters, commanding digital loads, and setting analog alarm limits. Full read-write  
15 capability **shall** be provided.

- 16  
17 1. The full English display **shall** provide easy to read visual display of system  
18 parameters and data. These displays **shall** accommodate all operating  
19 conditions of the RCU as well as the values and status of the sensors and contacts  
20 being monitored or controlled. Time and day and other pertinent program  
21 values may be displayed.  
22 2. Displayed data and values are accompanied by full English descriptors for ease of  
23 interpretation. The RCU **shall** utilize the English display to provide the  
24 operator with a self-prompting technique of entering data into the system. This  
25 prompting program **shall** automatically step the operator through the data  
26 entry procedure.  
27 3. In addition to the self-prompting programmability, the full English display may  
28 be set up in a mode to automatically scan either analog inputs, digital inputs,  
29 analog outputs, or relay (digital) outputs, displaying the value or status of each in  
30 sequence. For example, the operator can set the system up to provide a  
31 continual display/summary of all or a portion of all of the input sensors,  
32 displaying for a few seconds at a time, each value, and then advancing to the  
33 next sensor. This display mode **will** continue, uninterrupted until manually  
34 stopped by an authorized operator. With the full English display and the  
35 automatic scan any operator can tell at a glance what conditions are.

- 36  Spare Equipment: Provide spare control unit (CU) board and spare I/O board. It **shall** be  
37 possible for trained operations personnel to replace CU boards and load software via the  
38 PDOT. Provide one spare control unit board. If power supplies are separate, supply  
39 separate power supplies and other parts to make one complete set of DDC control  
40 equipment spares. If I/O boards are separate from the CU boards, provide two spare I/O  
41 boards for each spare CU board provided above. Deliver spares to WCPSS Energy  
42 Management Office and provide A/E with written confirmation of delivery.

43  
44 **SYSTEM SIGNAL TRANSMISSION**

- 45  CU input signal circuits **shall** be in metal conduit where exposed or subject to mechanical  
46 damage and be approved shielded cable.

- 47 1. Communications between RCU's and between the RCU's **shall** utilize a peer-to-  
48 peer local area network (Level 1 LAN). Peer-to-peer networks **shall** be  
49 commercially-available peer-to-peer LAN, which operates at 2.5 megabaud or  
50 faster. The LAN **shall** be capable of operating at distances of at least 4000 feet  
51 between most distant nodes. The system **shall** automatically reconfigure the  
52 LAN upon failure and restoration of breaks in the communication lines.

1                   Communication between RCU's and ACU's, and between RCU's and UCU's, **shall**  
2                   be via commercially available network modems, which operate at 9600 baud or  
3                   faster (Level 2 LAN).

- 4                   2. Transmission lines **shall** be electrically isolated from the CUs by optical couplers  
5                   at each interface to prevent any voltages in the transmission lines from damaging  
6                   any of the electronic circuits.

#### 8 **INPUT/OUTPUT**

9                    **Each point shall be discrete. No multiplexing to a single input or output shall**  
10                   **be acceptable.**

11                    Input/output points include sensors, two-state commands, binary counters or analog  
12                   outputs. The system **shall** have easily accessible terminal strips for connection of  
13                   input/output wiring. I/O voltages **shall not** exceed 24 volts AC or DC and current **shall**  
14                   **not** exceed 1.0 ampere.

15                    RCU's **shall** contain functions as required to meet the capacity of the project.

16  
17                   1. The digital outputs **shall** be used for two state commands to loads, such as  
18                   stop/start. The digital outputs **shall** provide a normally closed or open dry  
19                   contact output with a minimum contact rating of 1 amp at 24 volts.

20                   2. The digital inputs **shall** accept 2-state dry contacts for alarm or status  
21                   monitoring or can count pulses from an energy demand generator.

22                   3. Each RCU **shall** provide 1-11 volt DC analog outputs or 4-20 ma signals, not to  
23                   exceed 80 ma output total. The analog signals must be software scaled to  
24                   read-out in actual engineering units. Pulse width modulation **will not** be  
25                   acceptable.

26                   4. The analog inputs **shall** accommodate a wide range of industry standard sensors  
27                   including resistive copper RTDs, 1 to 11 volts or 4 to 20 ma DC. Analog inputs  
28                   **will** be scaled to read-out in engineering units, as appropriate.

#### 30 **PART 3 - SYSTEM SOFTWARE**

##### 31 **GENERAL REQUIREMENTS:**

32                    Each RCU **shall** be programmable through the integral keypad, PDOT, and/or MMI.  
33                   Software architecture **shall** allow set-up of points types, EMS programs, loops and  
34                   custom programs. In addition, the RCU **shall** allow the building operator a means of  
35                   interrogating input/output sensor conditions via the keypad and display unit, PDOT, or  
36                   through the MMI.

37                    Each RCU keypad **will** allow access to and programming of each of the other units on  
38                   the Level 1 LAN. (As an example: the operator **shall** be able to address all the discharge  
39                   temperatures from any RCU in the entire complex). Each RCU on the network **shall**  
40                   have a separate access code. Each UCU, via the PDOT, **shall** allow access to each of the  
41                   other UCU's connected to the Level 2 LAN.

42                    The RCU **shall** be capable of parenthetical, mathematical calculations and logic decisions  
43                   as programmed by an operator. Totalizations, optimizations and internal formatting of  
44                   data **shall** be independent of the MMI.

45                    The RCU **shall** format all data for recall via the MMI. Formats **shall** include such items  
46                   as engineering units (kwh, F, C, PSI, etc.), function descriptions, times, dates and other  
47                   information relating to point types.

48                    The Level 1 LAN **shall** have defined object registers for transferring values or state  
49                   commands at at least 9600 baud every second. Each of the RCU'S on the Level 1 LAN  
50                   **shall** be able to transmit and receive global information. Such information (such as  
51                   outside air temperature, demand-shed commands, enthalpy changeover and related

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
March, 1999

- 1 routines) **shall** be shared by all RCU's on the Level 1 LAN.
- 2  Level 1 LAN status **shall** be monitored through status objects. Loss of data transfer **will**  
3 trigger alarms, as well as default sequences to maintain system integrity and continued  
4 data transfer between all other RCU's on the Level 1 LAN.
- 5  Building alarm monitoring and reporting **shall** be user definable based upon the presence  
6 of abnormal alarm conditions such as high/low temperature input or abnormal change of  
7 state such as freezestats, firestats, filter alarm switches, etc. Printed reports upon alarm  
8 condition **shall** be assignable and generated at the locations specified. Up to three (3)  
9 different telephone numbers may be assigned for alarms or trend reports as defined by the  
10 Owner to alarm at up to three (3) separate locations. (Example - Maintenance alarms to  
11 Physical Plant and Energy related alarms to the Energy Management Office.) ALL  
12 ALARMS MUST USE THE EXISTING PHONE LINES AND NUMBERS IN THE  
13 ENERGY MANAGEMENT OFFICE.
- 14  One master clock **shall** provide automatic clock synchronization for all panels on the  
15 network. In case of master clock failure, each RCU **shall** resume stand alone clock  
16 operation. Additionally, daylight savings time adjustments **shall** be automatic based on  
17 the current year format or programmable.

18 **DDC CONTROL UNIT SOFTWARE**

- 19  The DDC system **shall** be a network of independent standalone CU's. Each CU **shall** be  
20 capable of full control of its assigned functions as a completely independent unit. The  
21 RCU's **shall** include standalone capability of direct digital control with integrated energy  
22 management programs including duty cycling, time scheduling, optimum start and stop  
23 and load reset programs. ACU's and UCU's, if provided, **shall** perform dedicated  
24 functions as assigned.
- 25 1. The CU operating system software **shall** be PROM resident. The operating  
26 system **shall** provide alarm monitoring and reporting, provide control  
27 application packages, and contain built-in automatic diagnostic routines. In  
28 addition, RCU's **shall** maintain supervisory control over all ACU's and UCU's to  
29 which they are connected.
  - 30 2. Each CU **shall** contain self-diagnostics that continuously monitor the integrity  
31 of the system. Any malfunction of the system **will** be reported to the MMI to  
32 inform the operator of the nature of the malfunction of the CU's affected. The  
33 controllers **shall** have memory error checking. Upon detection of a memory  
34 error, the CU **shall** correct the error or halt to prevent erroneous operation. All  
35 halts **shall** be reported.
  - 36 3. After a power failure and upon a power restoration, the system **shall** provide  
37 automatic sequential restart of equipment based on current program time and  
38 program requirements without operator invention.
- 39  All control functions **shall** execute within the standalone control units via DDC  
40 algorithms. The Owner **shall** be able to customize control strategies and sequences of  
41 operations defining the appropriate control loop algorithms and choosing the optimum  
42 loop parameters. Each CU **shall** include the following standalone functions:
- 43 1. Direct Digital Control algorithms and control sequences are to be CU resident and  
44 be capable of standalone operation. All DDC programs **shall** be custom written  
45 as required to meet the performance criteria spelled out in the sequence of  
46 operation paragraphs on the drawings for each controlled mechanical system.  
47 PID algorithm **shall** be employed as appropriate to the application and per  
48 sequences or operation.
  - 49 2. All CU resident DDC programs **shall** be capable of being enabled or disabled from  
50 the MMI or PDOT. In the enable mode all DDC loops **shall** be active and output  
51 signals **shall** be routed to the final control elements. In the disable mode all DDC  
52 loop calculations **shall** continue but outputs to actuators **shall** be suppressed.

- 1 (When disabled, control outputs **shall** stay in the same state or position as  
2 commanded from the central or until they are manually set to automatic.)
- 3 3. To eliminate integral windup, all PID programs **shall** automatically invoke  
4 integral windup prevention routines whenever the controlled unit is off, under  
5 manual control or under control of an EMS or time initiated program.
- 6  Default Value Operation: All CU's **shall** be capable of being programmed to utilize stored  
7 default values for assured fail-safe operation of critical processes. Default values **shall** be  
8 invoked upon sensor failure or, if the primary value is normally provided by the central  
9 or another CU, by loss of bus communication. Individual application software packages  
10 **shall** be structured to assume a fail-safe condition upon loss of input sensors. Loss of an  
11 input sensor **shall** result in output of a sensor failed message at the central control and  
12 command station. Each CU **shall** have capability for local readouts of all functions.
- 13  Control Loops **Shall** be able to Utilize any of the Following Control Modes:  
14 - Two position (on-off, slow-fast, etc.)  
15 - Proportional (P)  
16 - Proportional plus integral (PI)  
17 - Proportional plus integral plus derivative (PID)
- 18  System Diagnostics: System diagnostic software and hardware diagnostic software stored  
19 in non-volatile memory **shall** be provided for the central computer and each remote  
20 DCP CU. Each board within each remote DCP **shall** independently execute its own  
21 cold-start initialization diagnostic routines. These tests **shall** assure that the board  
22 circuitry is operating properly and that the individual boards within the system  
23 communicate with each other properly. If any test within the system detects a problem, a  
24 message **shall** be output to the peripheral devices provided the failure is not within the  
25 peripheral devices themselves or within the peripheral communication circuitry.  
26 Additionally, LED indicators, which are visible while the board is operating, **shall** be  
27 provided to localize the fault. The LED indicators **shall** operate in addition to the  
28 peripheral device reporting. Cold-start initialization diagnostics **shall** be initiated by  
29 power-up and operator request. Additional hardware and software **shall** be provided to  
30 continuously monitor on-line system operation and detect system faults.
- 31  Software Documentation: Provide software to automatically graphically document all  
32 DDC control points and software directly from control software code and providing a  
33 graphic output compatible with AutoCAD DWG or DXF format(s). This software **shall**  
34 effectively "reverse engineer" the control programs code to provide the Owner with a  
35 graphic representation of the control algorithm, control points, and control variables.
- 36  Application Software: All application software programs **shall** be distributed throughout  
37 the CU's in the system. Distributed software resident in the CU's **shall** be provided for  
38 standalone operation. All CU's **shall** contain OS software as necessary for scheduling and  
39 controlling resident programs, and for data file management. All sensor failures **shall** be  
40 immediately reported as an alarm.
- 41 1. Timed Programmed Commands (TPC): The RCU **shall** be capable of  
42 automatic start-up and/or shutdown of selected remote equipment and automatic  
43 adjustment of setpoint data according to preset schedules stored in the computer.
- 44
- 45 All remote fans, pumps, motors, lights, HVAC systems, boilers, chillers, etc., or any  
46 device which operates on a preset time basis can be assigned to this program. TPC  
47 **shall** operate in accordance with a yearly calendar with automatic adjustment for  
48 daylight savings time and leap year.
- 49
- 50 TPC **shall** operate a holiday schedule capability, which **will** automatically bring up a  
51 pre-defined holiday schedule of operation. Holidays can be scheduled up to one year  
52 in advance and **shall** be capable of any number of holidays per year. The technique

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
March, 1999

1 for scheduling holiday operation **shall** be to specify the date of the beginning day of  
2 the holiday and the date of the ending day of the holiday. For each of those days  
3 specified as a holiday, each timeclock **will** follow its unique holiday schedule.  
4

5 In addition to the time dependent two state control, TPC also provides time  
6 dependent setpoint control. This control provides the capability of outputting  
7 assignable, proportional setpoint values in accordance with the time of day and day of  
8 week. This program **shall** be used to accomplish night setback, morning warm-up,  
9 and normal daily operation setpoints of all control system loops controlled by the  
10 RCU. As with the two state control, time dependent setpoint control **shall** be  
11 subject to the holiday schedule.  
12

13 The setpoints desired **shall** be user definable at the keypad and display. The operator  
14 **shall** be capable of reading and/or altering all stored data pertaining to time of day,  
15 day of week, on/off times, setpoint values and holiday designation.  
16

- 17 2. Optimum Start Program (OS): The optimum start-up time of assigned  
18 equipment **shall** be determined based on a software calculation, which takes into  
19 consideration outdoor air conditions and space conditions. Any or all zones and their  
20 associated loop control **shall** be capable of being optimized by the optimum start  
21 program.  
22

23 The software program **shall** be capable of determining the ideal start-up time in the  
24 heating and cooling system. Each zone being optimized may have its own unique set  
25 of variables, such as temperature and occupancy time. The optimum start program  
26 **shall** control the start-up of the HVAC cooling and heating equipment to achieve  
27 the target occupancy space temperature at the precise time of building occupancy. By  
28 use of the onboard keypad, the operator **shall** have the ability to program the  
29 occupancy time and target temperature for each zone to be optimized.  
30

31 Provide a built-in "learning" technique that allows the RCU to automatically adjust  
32 itself to the most effective time to start equipment in order to achieve the desired  
33 occupancy target temperature. Each zone being optimized **shall** have its own  
34 learning curve. However, it **shall** be possible for the operator to input values into  
35 the program and disable the "learning" function.  
36

- 37 3. Enthalpy Optimization (EO): The enthalpy optimization program **shall**  
38 reduce system cooling requirements when the total heat of the O.A. is less than that  
39 of return air. The total heat, which is a combination of the latent heat and sensible  
40 heat, **will** be calculated for outdoor air and compared against that of the return air  
41 and a decision made as to which source would provide the most economical operation.  
42 Dampers **will** be automatically adjusted in accordance with this decision. Dry bulb  
43 sensor inputs in conjunction with relative humidity input **will** be used to calculate the  
44 enthalpy in both air streams.  
45

- 46 4. Custom Control Programs (CCP): The RCU **shall** be capable of providing  
47 operator programmable custom event/response routines. A user programmable  
48 language **will** provide the ability for the user to compose unique programs for  
49 handling building requirements, which are not covered, by the available standard  
50 programs of the system. The custom control program can provide an output in  
51 response to any combination of the logical input functions AND, OR, NAND, NOR  
52 and XOR.

1  
2 In addition, the custom control program must also have the ability to perform  
3 mathematical operation, including ADD, SUBTRACT, SQUARE ROOT,  
4 MULTIPLY, DIVIDE, AVERAGE, MAXIMUM (highest signal select) separate from  
5 or in combination with logical functions. The program must accommodate separate  
6 and unique custom control programs.

7  
8 5. Direct Digital Control (DDC): DDC capability using a custom control  
9 program, manual command or time program initiated commands **shall** be provided as  
10 a standard feature of this system. It **shall** be possible to input sensor or group of  
11 sensors to the RCU, process the data using the features of a loop control program,  
12 and output and analog control signal or setpoint directly to a controlled device. It  
13 **shall not** be necessary to provide intermediate controllers to condition the signal.  
14 The output signal **shall** be scaled in software to be compatible with industry standard  
15 control signal variables, such as 3 to 6 volts or 6 to 9 volts. Integral to the direct  
16 digital control capability **shall** be industry standard control types, e.g. hysteresis  
17 (floating control), proportional control/direct or reverse acting, proportional and  
18 integral (PID)/direct acting or reverse acting. The units of control **will** be in  
19 engineering units, such as degrees Fahrenheit, kilowatt hours or percent relative  
20 humidity. In the case of hysteresis control, dead band **shall** be entered in engineering  
21 units, such as degrees Fahrenheit. For proportional control, throttling range **shall**  
22 be specified in engineering units. For proportional and integral and PID control, reset  
23 time in quarter minutes or differential rate in units per minute **shall** be an operator  
24 entered constant. Any software loop output in the RCU **shall** have the ability to  
25 control staged control or provide analog direct digital control. All loop parameters  
26 **shall** be user definable and **shall** include "Minimum On-Time", "Minimum  
27 Off-Time" and "Optimum Cycle Time" for each stage of control.

28  
29 6. Trend Analysis Reporting: Trended points may be digital inputs or outputs,  
30 analog inputs or outputs or calculated values. Time interval between samples **shall**  
31 be operator selectable. Trend logs **shall** be capable of providing history of facility  
32 condition and **shall** continue uninterrupted until the program is manually stopped or  
33 altered by an authorized operator. The trend function **shall**:  
34 

- 35 • Monitor the same point or points according to an interval and store
- 36 each value.
- 37 • Monitor a point or points when directed by an alarm condition.
- 38 • Store the time at which the data was taken for each point.
- 39 • Point data according to an interval (length determined by user) or
- 40 during an alarm condition.
- 41 • Print a column header with point designation and engineering units
- 42 for each point.
- 43 • Print the time and point data information in its respective column for
- 44 all values for that point.

## 45 PART 5 - VARIABLE AIR VOLUME DIGITAL CONTROLS

### 46 GENERAL

- 47  Controls **shall** be microprocessor based pressure independent or pressure dependent  
48 Variable Air Volume Digital Controllers (VAVDC), as indicated on the drawings.
- 49  The VAVDC **shall** consist of a UCU, power supply, enclosure, actuator (when required),  
50 differential pressure transducer, field terminations, field adjustments and  
51 operating/application system software in a single integrated package.
- 52  All input/output signals **shall** be directly hardwired to the VAV DDC controller.

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
March, 1999

- 1 Troubleshooting of input/output signals **shall** be easily executed with a PDOT connected  
2 at the wall sensor location.
- 3  The VAVDC **shall** have a room sensor with integral room setpoint adjustment. The  
4 room sensor/setpoint **shall** be capable of being shared by up to four VAVDC's to provide  
5 coordinated control of zones containing multiple VAVDC's. The sharing of the  
6 sensor/setpoint **shall** be through hardwire connection. Systems sharing data through  
7 communications **shall not** be acceptable. The room sensor **shall** contain a pushbutton  
8 for override of unoccupied conditions and a plug-in communications jack for connection  
9 of the PDOT.
- 10  VAVDC control algorithms **shall** be designed to limit the frequency of damper  
11 repositioning, to assure a minimum 10 year life from all components of the VAVDC.  
12 The VAVDC **shall** provide zone control accuracy of not more than +/- 1 Deg. F.
- 13  All control sequences programmed in the VAVDC **shall** be stored in non-volatile  
14 memory, which is not dependent upon the presence of a battery to be retained. Power  
15 failures **shall**, therefore, not cause the VAVDC memory to be lost, nor **shall** there be  
16 any need for batteries to be recharged or replaced.
- 17  The VAV terminal unit manufacturer **shall** provide a multi-point, averaging, differential  
18 pressure sensor mounted on the inlet to each VAV terminal unit and **shall** adjust the unit  
19 for airflow's indicated on the drawings.

20 \*\*\*\*\*SPEC WRITER: COORDINATE THE REQUIREMENTS FOR MOUNTING  
21 CONTROL DEVICES WITH THE VAV TERMINAL UNIT  
22 SPECIFICATION.\*\*\*\*\*

- 23  The VAV terminal unit manufacturer **shall** mount actuators, controllers, etc., provided  
24 by the control subcontractor. The control subcontractor **shall** ship actuators,  
25 controllers, etc. to the VAV terminal unit manufacturer for installation. The control  
26 subcontractor **shall** provide all reheat control valves to the mechanical contractor for  
27 mounting and piping. The control subcontractor **shall** provide and install all wiring  
28 between the valve and VAVDC and between the room sensor and the VAVDC.

29  
30 **FAN ASSISTED, INDUCTION, REHEAT UNITS**

- 31  In addition to the inputs and output points described above, VAVDC for terminal units  
32 which are fan assisted of induction or of reheat configurations **shall** provide the  
33 following additional control points:
- 34 • Up to 4 digital outputs for fan control, up to 4 stages of electric reheat,  
35 floating valve actuator control of occupancy control of blinds, lights, etc.
  - 36 • A 4-20mA (0-10 VDC) true proportioned analog output signal for control of  
37 a proportioning hydronic reheat valve.

38  
39 **PART 6 - FIELD SENSORS AND DEVICES**

40 **GENERAL**

- 41  Provide all remote sensing points and instrumentation as required for the systems. All  
42 sensors **shall** have accuracies as stated hereinafter.
- 43  Field Wiring for each digital device **shall** be two or three conductor No. 18 AWG, or  
44 larger twisted sets of copper conductors 300 volts, thermoplastic. When line voltage is  
45 present in conduits or wiring trays the insulation on all conductors **shall** be 600 volts.  
46 For multiconductor wire having four or more conductors, wire size **shall** be not less than  
47 No. 20 AWG solid copper.

48  
49 **SAFETY/STATUS SWITCHES**

- 50  Differential liquid pressure switches **shall** be piped in parallel across all water circuits for  
51 positive indication of flow - Example: Heat pump loop, cooling tower loop, heat

1 exchangers and storage tanks. Snap action SPDT switches **shall** operate from a  
2 neoprene slack diaphragm, corrosion-resistant stainless steel diaphragm or copper  
3 diaphragm capable of being adjusted through the total pressure range.

- 4  Switches **shall** withstand at least twice the working pressure of the system including any  
5 standing head, and have a temperature range exceeding the worst case liquid and ambient  
6 temperature range conditions. Provide a NEMA 4 enclosure for the switch assembly.  
7 For ease of service and maintenance, install the switch with a 3 valve manifold piped in  
8 copper to pressure taps in the liquid lines.
- 9  Current sensing relay **shall** be used for pump and/or fan motor status. The current  
10 sensing relay **shall** be adjustable within three ranges; .1-6amps, 6-40amps and  
11 40-200amps. Contact rating **shall** be .15amps at 30VDC.
- 12  Differential air pressure switches **shall** be piped in parallel across fans for positive  
13 indication of flow. Static pressure sensing tips **shall** be used for both high and low inputs.  
14 Pressure range **shall** be adjustable between .07 and 1.0" W.C. Snap acting contact **shall**  
15 be rated at 300 VA at 120 VAC.

#### 16 17 **SENSOR ACCURACY**

- 18  Sensors are only one element in the overall system accuracy to which the CU can  
19 respond. That response includes alarm decision, value display, value calculation on which  
20 analog values must be multiplied, subtracted, square rooted, etc. As such, the system  
21 end-to-end accuracies are herein stated. Sensors that have a tendency to drift with age  
22 **shall** be supplied with self-correcting circuits. The following range/ accuracies are  
23 required:

24 +/- .5 for the air temperatures.  
25 +/- 1.0 for water temperatures.  
26 +/- 0.1 for water temperatures in the range 40 - 55 F.  
27 KWH and KW monitoring within 1.0% of full scale value.  
28 +/- 2.0 psig for water or steam pressure in the range of 0 - 200 psig.  
29 +/- 1.0% of full scale value for potential or current transducers.  
30 +/- 2.0% for 0-80% RH, +/- 3.0% for 80-100% RH

- 31  Sensors for differential temperature readings to be used in BTU calculations **shall** be a  
32 matched pair with a differential accuracy of plus or minus 0.1 deg. F.
- 33  Space Temperature Sensors **shall** have a temperature range of -40 to 160 deg. F. The  
34 sensor **shall** be stainless steel plate with a 10k thermistor thermally bonded to back with  
35 fully insulated gasket and nylon mounting screws.
- 36  Duct Temperature Sensors **shall** have an insertion measuring probe 6 inches long with a  
37 temperature range of -40 to 250 deg. F. The sensor **shall** include a utility box and gasket  
38 to prevent air leakage and vibration noise. For all mixed air and preheat air applications,  
39 install bendable averaging duct sensors with a minimum 5 ft. long sensor element.
- 40  Liquid Immersion Temperature Sensors **shall** have a temperature range of -40 to 250  
41 deg. F.
- 42  Outside Air Temperature Sensor **shall** be mounted in the outdoors where natural air flow  
43 occurs, away from any artificial affect from mechanical sources. The temperature range  
44 **shall** be -40 to 220 deg. F. Provide a sun shield and weatherproof assembly for mounting  
45 to 1/2 in. rigid conduit.
- 46  Duct Relative Humidity Sensors **shall** be duct mounted devices that produce a linear  
47 output over the complete range of 0-100% RH. A thin film polymer sensing element  
48 **shall** respond quickly to changes in humidity and **shall** be protected from contamination  
49 by a sintered filter. The sensor **shall** be factory calibrated with periodic field  
50 recalibration capability. The sensor **shall** be mounted in a duct probe assembly and be  
51 installed only after the construction or renovation area is free of contamination.

- 1  Space Relative Humidity Sensors: The sensor **shall** be an analog precision capacitance  
2 type relative humidity detector. Sensing element **shall** be rated for the relative humidity  
3 range 0-80%.

4 **TEMPERATURE AND HUMIDITY SENSORS**

- 5  Temperature Sensors: The following **shall** apply to temperature sensors:  
6 • Stem or tip sensitive types.  
7 • Sensing elements **shall** be hermetically sealed.  
8 • Stem and tip construction **shall** be 304 stainless steel.  
9 • All external trim material **shall** be corrosion resistant designed for the  
10 intended application.  
11 • Thermometer wells **shall** be stainless steel. Heat transfer compounds **shall**  
12 be compatible with the sensors.  
13

14 **PRESSURE**

- 15  Air pressure transmitter **shall** universally measure very low static or differential pressure  
16 using a variable capacitance technique. Static pressure **shall** measure in ranges from 0 to  
17 10 inches water column. Differential air pressure **shall** have a range of 0 to +/-0.5  
18 inches. Transmitter accuracy, including non-linearity, hysteresis and non-repeatability  
19 **shall** be within 1% of full scale.  
20  Dirty Filter Indication: Dirty filter **shall** be indicated as an alarm. Sensor **shall** be  
21 Dwyer 1823-0 or 1823-1 which ever is required.  
22

23 **POWER METERING**

- 24  Electrical demand **shall** be from pulsing dry contacts provided by owner and installed by  
25 the Utility Company at the power meter. The DDC system **shall** be capable of  
26 measuring and scaling any pulse rate provided by the utility company.  
27

28 **SURGE AND LIGHTNING PROTECTION**

- 29  Line voltage protection: The CU's **shall** be powered by 120 VAC circuits provided with  
30 surge protection. This protection is in addition to any internal protection provided by  
31 the manufacturer. The protection **shall** be a LA302RUL manufactured by Delta  
32 Lightning Arresters Inc. or an approved equal. For all DCP locations with telephone  
33 modem, an MP11 (as manufactured by GSI or equal) **shall** be used to provide AC line and  
34 telephone line protection. A grounding conductor, (minimum 12 awg), **shall** be brought  
35 to each control panel from either a driven ground rod or the ground bus in a breaker  
36 panel. Conduit grounds **will not** be acceptable.  
37  Inter-unit Communications: All panel to panel data networks that are routed outside or  
38 between buildings **shall** be protected by a SPR 422E or approved equal. The protection  
39 device **shall** match the voltage levels of the inter-unit communications network.  
40

41 \*\*\*\*\*SPEC WRITER: DELETE THIS SUBSECTION IF FIBER OPTIC  
42 CABLING IS NOT UTILIZED.\*\*\*\*\*

43  
44 **FIBER OPTIC DEVICES AND CABLE**

- 45  Fiber Optic Repeaters: The repeaters **shall** be provided as required and **shall** convert  
46 RS-485 to Fiber Optics. The repeaters **shall** also extend communication distance up to 3  
47 miles (16,000 ft.) All Repeater Modules **shall** have Light Emitting Diode (LED)  
48 diagnostic indication. The LED's indicate when power is applied and show the  
49 communications activity. Each Repeater **shall** be installed in a Nema one (1) enclosure  
50 and be surge tested to comply with IEEE-587 (ANSI/IEEE std. C62.41) transient  
51 suppression withstand test for category A and B type devices.

- 1  Fiber Optic Cable: The Fiber Optic Cable **shall** be as manufactured by Ensign-Bickford,  
2 Avon, CT. Part #HCP-M0200T-A-02E-BO7 or approved equal.  
3

4 **FINAL CONTROL ELEMENTS AND OPERATORS**

- 5  Fail Safe Operation: Design and install control valves and dampers to activate "closed"  
6 upon a loss of control signal.
- 7  Valves: Controls subcontractor **shall** be responsible for selection of the proper control  
8 valves including line size, pressure rating, flow-coefficient, shutoff rating and allowable  
9 leakage factor. Valves 2-1/2 in. and larger **shall** have minimum 125 psig cast-iron body  
10 and **shall** have stainless steel stems and flanged connections with field replaceable  
11 packings. Valves smaller than 2-1/2 in. **shall** be constructed of brass with screwed  
12 connections, stainless steel stems and field replaceable packings. All valves 1-1/2 in. and  
13 larger **shall** have gear train heavy duty actuators.
- 14  Maximum Pressure Drop through Valve:
- 15 • Two Position Steam Control: 20% of inlet gauge pressure.
  - 16 • Modulating Steam Control: 80% of inlet gauge pressure (acoustic velocity  
17 limitation).
  - 18 • Modulating Water Flow Control: Greater of 10 ft. of water or the pressure  
19 drop through the apparatus.
  - 20 • Two position water valves **shall** be line size.
- 21  Valve Positioning: All control valves 2-1/2 in. or larger **shall** have position indication.  
22 Modulating valves **shall** have an analog input to the DDC system. End switches **shall**  
23 provide a digital input for 2-position valves. Voltage output indications are not  
24 acceptable. Feed-back **shall** be provided by slide-wire potentiometer or equal.
- 25  Dampers: Control dampers **shall** be opposed blade (except where two-position action is  
26 indicated) with interlocking gasketed edges, jamb seals and ball type oilite bearings.  
27 Blades and frames **shall** have galvanized finish. Frames **shall not** be less than 5 in. X  
28 1/2 in. X 16 gauge channel iron and **shall** be reinforced to form a rigid assembly. Blades  
29 **shall** be 16 gauge with maximum blade width of 10 in. Dampers over four feet high or  
30 wide, or over 16 sq.ft. **shall** be built in two or more sections with interconnections on  
31 every other blade. Gasket material **shall** be molded neoprene or approved equal.  
32 Damper leakage **shall not** exceed 6.0 CFM/SF at 1in. SP, fully closed.
- 33  Damper Operator: Operators **shall** be heavy duty electric gear train type for modulating  
34 automatic dampers in response to a varying signal. Motor **shall** be of sufficient size to  
35 operate damper positively and smoothly to obtain correct sequence as indicated. Provide  
36 NC operator with spring return on 2-position dampers.
- 37  All applications requiring proportional operation **shall** utilize truly proportional electric  
38 actuators. Pulsed positioning of actuators/operators **will not** be acceptable.
- 39  Computer generated mylar labels **shall** be provided so as to properly identify all control  
40 components.
- 41  A telephone line **shall** be supplied and wired from the telephone board to the DDC system.  
42

43 **PART 7 - SEQUENCE OF OPERATION**

44 **GENERAL**

- 45  AHU's **shall** each have an RCU. Additional RCU's **shall** be provided as indicated or  
46 required.

47  
48 \*\*\*\*\*SPEC WRITER: EDIT THIS PARAGRAPH TO PREVENT  
49 REQUIRING EXCESS CONTROL PANELS.\*\*\*\*\*

- 50  
51  Each RCU or ACU **shall** be provided with 2 spare universal I/O points to allow for future

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
March, 1999

1 modifications. (If more than one panel exists in an equipment room or closet only 2  
2 points are required in this situation). Systems not providing universal I/O's **shall** provide  
3 4 additional points, i.e. one of each (A/I, A/O, D/I and D/O), at each panel.

4 AHU CONTROL

- 5  Each AHU is a zone that can be individually assigned an operation schedule or operate in  
6 conjunction with other zones as defined by the Owner. Each zone **shall** have a  
7 push-button override located in the Administration area to provide for a programmable  
8 amount of time for override. If the button is pushed during normally occupied times, no  
9 change in operation **will** occur. If the button is pushed during normally unoccupied  
10 times, both the AHU and central heating and cooling source **will** operate in the occupied  
11 mode for the programmed time duration. Each AHU transmitter **shall** have adjustable  
12 heating and cooling setpoints which can be operator adjusted.
- 13  During night setback operation, both the AHU and central heating source **will** be cycled  
14 on/off to maintain a minimum 55 deg.F. space temperature. Actual minimum  
15 temperature **shall** be adjustable, through software, with a 4 deg. F. differential (also  
16 adjustable) to prevent frequent cycling. Any required water pumps **shall** also be  
17 commanded on if an AHU is required to operate during unoccupied times. The outside air  
18 damper for each AHU **shall** open only during occupied times and **shall** remain closed  
19 during morning warm-up/cool down and night setback operation.
- 20  The AHU fan **shall** be started and stopped based on a pre-programmed, adjustable time  
21 schedule.
- 22  The supply air temperature **shall** be reset from 55 deg F. to 65 deg F. as required by the  
23 zone demand, as measured by the zone sensors. Supply air temperature **shall** be  
24 maintained by modulation of outside/return/relief dampers if the O.A. temperature is  
25 below supply air temperature setpoint and 3-way chilled water valve on the cooling coil if  
26 O.A. temperature is at or above supply air temperature setpoint.
- 27  DDC system **shall** modulate the inlet vane actuator on the Supply Fan as required to  
28 maintain the minimum duct static pressure setpoint.
- 29  A space mounted static pressure sensor/transmitter, acting through the DDC system,  
30 **shall** modulate the vaneaxial operator on the Return Fan as required to maintain the  
31 minimum building static pressure setpoint.
- 32  A software freeze stat **shall** shut down the unit if the mixed air temperature should fall  
33 below 34 deg F.
- 34  Each AHU **shall** initialize a morning warm-up cycle. The outside air damper **shall** close  
35 to minimum position and return air **shall** open to its minimum position. The cycle  
36 **shall** continue until the return air temperature reaches 70 deg F., at which time the  
37 system **shall** switch back to its normal operating mode.

38 VAV TERMINAL CONTROL

- 39  A wall mounted temperature sensor, acting through the VAVDC, **shall** modulate the VAV  
40 terminal and the proportional hot water reheat valve in sequence as required to maintain  
41 the space temperature setpoint. During AHU warm-up, the VAV terminal control action  
42 **shall** be reversed to allow the terminals to operate at their controlled maximum CFM  
43 and the reheat valves **shall** open to full flow.

44 CENTRAL PLANT CONTROL

- 45  The DDC system **shall** start/stop the pumps and central equipment whenever an AHU or  
46 fan coil unit (FCU) zone is indexed to occupied and the outside air is above/below the  
47 appropriate setpoint. Upon command from the DDC system, and when the outside air  
48 temperature is above 60 deg F. (adjustable) the chilled water pump **shall** start. When the  
49 chilled water pump is started, and when the chilled water flow is proven by a flow switch  
50 and a current sensing relay on the pump, the chiller **shall** be enabled and **shall** operate  
51 under control of its integral operating and safety controls. Upon command from the

1 DDC system, when the outside air temperature is below 55 deg F. (adjustable), and when  
2 required to maintain the HWS setpoint, the hot water pump **shall** start. When the hot  
3 water pump is started, and when the hot water flow is proven by a current sensing relay  
4 on the pump, the boiler **shall** be enabled and **shall** operate under control of its integral  
5 operating and safety.

#### 6 SEQUENCE EXISTING BUILDING(S)/OVERRIDES

7  The Equipment **shall** be grouped into building zones as directed. Each zone **will** be  
8 addressable for "on/off" and optimum start/stop operation and temperature monitoring  
9 (one temperature sensor per zone). Timed override switches (panel mounted) located in  
10 the office area **will** allow manual override of the schedule for up to two hours. Each  
11 timed override switch status **shall** be an input to the DDC system.

#### 12 FAN COIL UNIT CONTROL (FCU)

13  For each power circuit serving fan coil units, the control subcontractor **shall** provide a  
14 contactor that **will** close on a signal from the DDC system. The control subcontractor  
15 **shall** provide the control wiring to the contactors. All power wiring **shall** be by the  
16 Electrical Contractor. DX FCU's **shall** be started and stopped by relays breaking the  
17 control voltage and not the power circuits.

18  In the occupied mode, when the FCU's are indexed for operation through the contactors,  
19 the fans **shall** run continuously at the speed previously selected on the 3-speed fan  
20 switch and the return air thermostat **shall** control the chilled water valve to maintain  
21 desired space conditions. Each FCU **will** have a factory supplied and wired return air  
22 thermostat, 3-way valve and 3-speed fan switch. Note: The FCU'S **shall** be locked out  
23 whenever the outside air temperature is below 65 deg F. (adjustable).

#### 24 ELECTRICAL DEMAND LIMITING

25  The DDC system **shall** limit electric demand to a value specified by the Owner.  
26 1. First stage of demand limiting **shall** be by shifting heating and cooling  
27 setpoints.  
28 2. Second stage **shall** be to turn off exhaust fans and close outside air dampers  
29 to reduce building load.

30  The DDC system **shall** measure and record building electrical demand and building  
31 electrical consumption. Program trend logs to record:  
32 1. Maximum demand and consumption per hour on hourly intervals.  
33 2. Building demand and consumption on a daily interval.  
34 3. Building demand and consumption on a monthly interval.

35

#### 36 SECURITY SYSTEM INTERFACE

37  The DDC system **shall** connect to the school's security system and when that system is  
38 "armed" the DDC system **shall** switch all of the equipment in the complex to the  
39 night/unoccupied mode and stop all mechanical equipment unless a night setback/setup or  
40 freeze condition is in effect.

#### 41 KITCHEN EQUIPMENT FREEZER AND COOLER CONTROL

42  Provide wall mounted refrigerator/freezer temperature sensors to monitor both the  
43 freezer and cooler areas. Each sensor **shall** be an input to the DDC system for indication  
44 and alarm.

#### 45 LIGHTING CONTROL

46  The control subcontractor **shall** provide the number of outputs for lighting control as  
47 indicated on the drawings. These loads **will** be controlled based on time-of-day and  
48 special scheduling supplied by owner. The control subcontractor **shall** also connect to a  
49 dry contact point in the school's security system such that when a security breach is  
50 alarmed the lights **will** be activated.

51  The control subcontractor **shall** provide all wiring between the DDC system and the light

1 and security contact. All power wiring to lighting contacts **shall** be by the Electrical  
2 contractor. Lighting and security contact are supplied by others.

- 3  Provide push button override located above or near security keypad as D/I into DDC  
4 system for unoccupied use of lights.

#### 5 SMOKE DETECTORS

- 6  Smoke detectors are supplied and wired by Electrical Contractor. The control  
7 subcontractor **shall** mount detectors. Electrical Contractor **shall** supply and install a  
8 relay near the motor controller to shut down the unit. Central fire alarm panel **shall** be  
9 provided with one contact output to the DDC system to indicate activation or failure of  
10 any smoke detector. Wiring required for alarm points **shall** be provided by the control  
11 subcontractor.

#### 12 MAINTENANCE MANAGEMENT

- 13  The DDC system **shall** measure and record run time for all start/stop points in the  
14 system. Based upon the accumulated run time provide maintenance messages on the  
15 interval recommended by the equipment manufacturers.

- 16  Any digital input point that is used for maintenance purposes (i.e. Dirty Filter) **shall** also  
17 generate a maintenance message.

- 18  All maintenance messages are to be sent via LAN or Modem to the MMI.

#### 19 TROUBLE ALARMS

- 20  The control subcontractor **shall** establish a trouble high and trouble low alarm limit for each analog  
21 input and annunciate a corresponding alarm message at the MMI.

#### 22 MODIFICATION

- 23  All software setpoints, limits, alarms, messages, schedules, sequences, etc., as specified  
24 herein are to provide an initial setup of the control system. The control subcontractor  
25 **shall** provide software modifications that may be required to "tune" the DDC system to  
26 accurately respond to actual building parameters. Further, these software functions **shall**  
27 be readily modifiable by the Owner's personnel as changes in building operation dictate.

#### 28 DOMESTIC HOT WATER

- 29  Provide one temperature sensor for each kitchen and/or gym domestic water heater.  
30 Provide single digital output for water heater start/stop control. Recirculating pump(s)  
31 may be controlled by separate digital output or same output controlling water heater,  
32 depending upon application.

#### 33 DATATALK INTERFACE

- 34  The DDC system **shall** be capable of utilizing DATATALK. WCPSS already owns  
35 DATATALK software and hardware and therefore **will** only require additional site  
36 software for this job. All alarms, overrides, etc. required **shall** report and run in  
37 complete compatibility with the existing software package.

- 38  New CU's **shall** have the ability to report to the existing software such that setpoints,  
39 schedules, analog values and digital values can be interrogated and changed from any  
40 remote touch tone telephone. Appropriate alarms **shall** contact personnel via  
41 telephone. Maintenance personnel can dial into system from remote touch tone  
42 telephone to interrogate problem.

### 44 PART 8 - EXECUTION

#### 45 INSTALLATION-GENERAL

- 46  Work schedule **shall** be in accordance with Division 1.

- 47  Existing facilities **shall** remain in use during all phases of construction under this  
48 Contract.

- 49  The Contractor **shall** cooperate with the Owner in every way possible to keep  
50 interruption of, and interference with, normal functions, activities, and operations to a  
51 minimum. Where construction or attendant work interrupts normal functions in any

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
6 May 1992

- 1 area, a schedule of work **shall** be submitted for approval of the Owner and after  
2 approval, strictly followed.
- 3  Modification to existing work **shall** be done as required.
  - 4  All work **shall** be performed in such a manner as to prevent any interruption of any  
5 service or utility.
  - 6  Where it is necessary to interrupt service for cut-in or changeover, the work **shall** be  
7 scheduled well in advance of the interruption and the interruption approved by the  
8 Owner. If required by Owner, change-over work **shall** be done during night, weekends,  
9 holidays, or other off peak period as approved.
  - 10  No equipment **shall** be disconnected without approval of the Owner's Representative.
  - 11  Existing material which is removed may be reused if specifically approved by the Owner's  
12 Representative.
  - 13  All temporary wiring and/or other control components required for temporary operation  
14 of the facility **shall** be provided.
  - 15  Wiring: The term wiring is construed to include furnishing of wire, conduit, miscellaneous  
16 material and labor to install a working system. Outdoor installations **shall** be of  
17 weatherproof construction or in NEMA 3R or 4 enclosures.
  - 18  Routing: Except for short apparatus connections, run conduit parallel to or at right  
19 angles to the building structure. Conceal conduit in finished spaces. **Do not** run conduit  
20 concealed under insulation or inside ducts. Mount control devices, and conduit located on  
21 ducts or apparatus with external insulation on stand-off support to avoid interference  
22 with insulation.
  - 23  Run wire connecting devices on or in control cabinets parallel with the sides of the  
24 cabinet neatly racked to permit tracing. Rack connections bridging a cabinet door along  
25 the hinge side and protect from damage.

26  
27 D. Field Materials:

28  
29 1. Sensors and Controls: Permanently mark terminal blocks for identification.  
30 Protect all circuits to avoid interruption of service due to short-circuiting or other  
31 conditions. Line-protect all wiring that comes from external sources to the site from  
32 lightning and static electricity. Label or code each field wire at each end.  
33 Permanently label or code each point of all field terminal strips to show the  
34 instrument or item served. Color-coded cable with cable diagrams may be used to  
35 accomplish cable identification.

36  
37 a. Temperature sensors: Temperature sensors **shall** be readily accessible and  
38 adaptable to each type of application in such a manner as to permit for quick,  
39 easy replacement and servicing without special tools or skills.

40  
41 Mount duct sensors in locations to sense the correct temperature of the air  
42 only, within the vibration and velocity limits of the sensing element. Mount  
43 extended surface element, when used, securely within the duct and position to  
44 measure the best average temperature. Thermally isolate elements from  
45 brackets and supports to respond to air temperature only. Securely seal duct  
46 penetrations.

47  
48 Install pipe sensors in top of pipe for horizontal runs and at a positive slope  
49 on vertical runs to prevent condensation from flowing to sensor head.

50  
51 b. Temperature sensing elements installed in liquid systems **shall** be installed

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
March, 1999

1 in thermowells.  
2

3 c. Relative humidity sensors **shall** have air guards when installed in air flows  
4 of more than 15 meters per minute across the sensor element.  
5

6 d. Pressure Instruments:  
7

8 Pressure sensors (all types) installed on liquid lines **shall** have drains.  
9 Pressure sensors installed on steam lines **shall** have drains and  
10 siphons. All pressure sensors **shall** have valves for isolation, venting,  
11 and taps for calibration. Pressure sensors **shall** be verified by  
12 calibration. Differential pressure sensors **shall** have nulling valves.  
13

14 Pressure switches (all types) installed on liquid lines **shall** have drains.  
15 Pressure switches installed on steam lines **shall** have drains and  
16 siphons. All pressure switched **shall** have valves for isolation, and  
17 taps for calibration. Pressure switches **shall** be adjusted to proper  
18 setpoint, and **shall** be verified by calibration. Differential pressure  
19 switches **shall** have nulling valves. Switch contact ratings and duty  
20 **shall** be selected for the application.

21 The duct static-pressure sensing element, (tap or pitot tube), **shall** be  
22 located approximately two-thirds of the distance from the supply fan  
23 to the end of the duct with the greatest pressure drop. Provide taps  
24 for transmitter calibration.  
25

26 e. Install potential and current transformers in NEMA enclosures. Current  
27 transformer leads **shall** be shorted when they are not connected to the  
28 measurement circuits.  
29

30 f. Install relays and contactors in NEMA enclosures. H-O-A switches and  
31 override switches **shall** be installed so that controls function through the  
32 automatic position. Safety and fire or life safety interlocks **shall** function  
33 through both hand and automatic switch positions.  
34

35 g. Damper Actuators:  
36

37 Actuators **shall not** be mounted in the air stream.  
38

39 Outside air, return air, and relief dampers **shall** have individual  
40 actuators.  
41

42 Actuators **shall** be installed so that their action **shall** seal the damper  
43 to the extent required to maintain leakage at or below the specified  
44 rate and **shall** move the blades smoothly.  
45

46 2. DCP's: Install in accordance with manufacturer's published instructions and  
47 requirements.  
48

49 E. Signal Transmission System Equipment:  
50

51 1. General: Install all system components in accordance with the National Electrical  
52 Code and the manufacturer's recommendations; fuse and ground them properly.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40

a. Splices: Splices in shielded and coaxial cables **shall** consist of terminations and the use of shielded cable couplers. Terminations **shall** be in accessible locations. Cables **shall** be harnessed with cable ties.

b. Equipment: Fit all equipment contained in cabinets or panels with service loops, each loop being at least 12 inches long. Equipment for fiber optics system **shall** be rack mounted, as applicable, in ventilated, self-supporting, code gauge steel enclosure. Cables **shall** be supported for minimum sag.

c. Cable Runs: Keep cable runs as short as possible. connecting to the terminal board. **Do not** bend flexible coaxial cables in a radius less than ten times the cable outside diameter. **Use** vinyl tape, sleeves, or grommets to protect cables from abrasion or damage. Allow extra length for vibration at points where they pass around sharp corners, through walls, and panel cabinets.

d. Grounding: Ground system per manufacturer's requirements for proper and safe operation.

F. Field Test and Inspections

1. System Equipment: Upon completion of installation of each piece of equipment, field inspect and mechanically and electrically test equipment for proper function.

2. Field Materials: Upon completion of installation of each piece of equipment, field inspect and mechanically and electrically test equipment for proper function.

3. Signal Transmission System Equipment:

a. Ground Rod Tests: Before any wire is connected to the ground rods, **use** a portable ground testing instrument to test each ground or group of grounds.

b. Coaxial Cable Tests: Implement NEMA WC41 as a minimum.

4. Inspections: Inspection of the electrical work **shall** be done by the N.C. Department of Insurance "State Electrical Inspector" and by a representative of the State Construction Office.

END OF SECTION



1  
2 SECTION 16000 - ELECTRICAL WORK  
3

4 GENERAL  
5 DESIGN REQUIREMENTS

- 6  Engineer **shall** be required to incorporate the EPA "Green Lights" program and "Energy  
7 Star" program requirements for all designs.
- 8  All electrical systems main service equipment and panelboards **shall** be designed with  
9 25% minimum spare capacity, both physically and electrically, for future growth  
10 capabilities.
- 11  In any building where future expansion is definitely planned, as conveyed by the WCPSS,  
12 the Engineer **shall** provide adequate capacity and connection points in the electrical  
13 systems as directed by the WCPSS. The additional capacity **shall** be clearly noted on the  
14 front of the electrical drawings.
- 15  Provide ten (10) 3/4 in. spare conduits for all recessed panelboards to stub out above lay-  
16 in ceilings.
- 17  Provide sufficient electrical service, transformer, spare panelboard space and 2 in.  
18 conduits to a junction box located on exterior face of building for four (4) future portable  
19 classrooms. Assume each portable classroom will require 200 amp, 240 volt single phase  
20 service.
- 21  Provide lightning and surge suppression on all security, intercom, Building Automation  
22 System (BAS), MATV and fire alarm systems.
- 23  Provide phase loss protection at electrical panels serving HVAC motors and compressors.
- 24  Electrical Contractor **shall** provide conduit and pull string from demand meter to main  
25 Mechanical Room.
- 26  Electrical Contractor **shall** be responsible for all costs associated with demand meter.
- 27  Electrical Contractor **shall** provide dedicated and protected 120V power to all HVAC  
28 control panels and damper operators. Provide junction box and on/off service switch  
29 directly over control panel.
- 30  Electrical Contractor **shall** provide a telephone jack in each mechanical room.
- 31  Engineer **shall** require contractor to dimension actual location of all underground  
32 conduits on as-built drawings. A minimum of two dimensions from building reference  
33 points **shall** be provided and a bury depth indicated.
- 34  Provide a 120 V receptacle adjacent to kiln to provide power to kiln downdraft exhaust  
35 fan. Locate this receptacle a maximum of 4 ft. away from kiln. Kiln room **shall** also  
36 have a high temperature heat detector tied into the fire alarm panel.

37  
38 DRAWING REQUIREMENTS

- 39  All text and numbers **shall** be a minimum of 3/32 in. high to allow for a 1/2 reduction of the  
40 drawing size and still be readable.
- 41  Provide key plan for all sheets.
- 42  Show details of all conduit penetration details on the drawings for all fire rated walls to meet UL  
43 and Local Code Requirements.
- 44  Show all fire rated walls on all drawings for all trades with the rating spelled out or show different  
45 wall symbol for each rating, (1HR, 2HR, or 4HR).
- 46  Show dotted lines on floor plans to designate clearance requirements for electrical equipment.
- 47  Show a complete legend and symbol list on the first electrical sheet.
- 48  All building connected electrical loads (kW) and estimated maximum electrical demand (kW)  
49 **shall** be clearly shown on the first electrical sheet.

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
**DESIGN GUIDELINES**  
6 May 1992

- 1  All capacities provided for future building additions **shall** also be shown on the first electrical  
2 sheet.  
3  Draw all electrical equipment to scale including panelboards, fire alarm panels, sound panels, etc.  
4  
5 **OPERATING AND MAINTENANCE MANUALS** (See Section 01000-General Data)  
6  Specify that four (4) complete set of operation and maintenance manuals **shall** be delivered to  
7 the owner through the A/E two (2) weeks before the pre-final inspection is held.  
8  The O&M manuals **shall** be installed in three (3) ring heavy back note books with the name of  
9 the building and the words "Operations and Maintenance Manuals" permanently affixed to the  
10 cover and spine. The manuals **shall** contain the following items as a minimum:  
11 1. Index and page numbers  
12 2. Certificate of Substantial Completion  
13 3. Summary sheet of warranties with dates noted and a copy of all warranties  
14 4. List of all subcontractors and suppliers with names, addresses and phone numbers  
15 5. All submittal data and shop drawings  
16  
17  
18 **FINAL INSPECTIONS** - see section 01000-General Data.  
19  
20 **POST INSPECTIONS** - see section 01000-General Data.  
21  
22 **END OF SECTION**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28

**SECTION 16110 - CONDUIT**

**PRODUCTS**

- Conduit types **shall** be rigid steel, IMC, schedule 40 (or heavier) PVC or EMT.
- Fittings **shall** be all steel. Cast, pot metal, set-screw or crimp type fittings **shall not** be permitted.
- EMT connectors **shall** be insulated throat. Plastic bushings may be used in lieu of insulated throat.
- EMT couplings **shall** be compression type.

**EXECUTION**

- Conduit Uses:
  1. Rigid steel conduit or IMC may be used for underground branch circuit wiring without concrete encasement. All rigid steel and IMC feeder conduits **shall** be encased with 3 in. of concrete on all sides. All branch circuits exposed less than 8 ft. above finish floor and all feeder conduits run above grade **shall** be in rigid steel conduit or IMC.
  2. PVC conduit may be used without concrete encasement for branch circuits directly under concrete slabs and when turning up out of the slab inside walls to the first junction box. All PVC conduit outside the building slab and all PVC feeder conduits **shall** be encased in 3 in. of concrete on all sides.
  3. EMT may be used inside walls, in ceilings and exposed above 8 ft. above finish floor.
- Plastic bushings or insulated throat connectors **shall** be used in all conduit terminations.
- Conduit **shall** be used in walls, from the outlet to the ceiling, for public address, intercom and MATV wiring. Conduit is not required in ceilings for public address, intercom or MATV wiring. Provide plenum rated cable where necessary.

**END OF SECTION**

1  
2  
3  
4  
5  
6  
7

**SECTION 16120 - WIRES AND CABLES**

**GENERAL**

All conductor material **shall** be copper. Aluminum conductors are prohibited.

**END OF SECTION**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21

**SECTION 16142 - ELECTRICAL CONNECTIONS TO EQUIPMENT**

**GENERAL**

- Power wiring to all Plumbing or HVAC equipment **shall** be provided by the Electrical Contractor. The Plumbing or HVAC Contractors **will** be required to make final connections inside the equipment from slack wire left by Electrical Contractor for system check out. All disconnect switches and starters **shall** be supplied by the Plumbing or HVAC Contractors and turned over to the Electrical Contractor for mounting and wiring. All fuses and heaters **shall** be furnished by the Plumbing or HVAC Contractors. Show detailed drawing to avoid confusion. See Attachment 16142-A.
- Provide dedicated 120 volt, 20 AMP circuits to all Building Automation System (BAS) panel locations and in all mechanical rooms or other mechanical equipment locations requiring 120 volt control power.
- Provide a dedicated 120 volt, 20 amp circuit at the Fire Alarm Control Panel location.
- A \$1,000.00 allowance **shall** be provided in the electrical contract for demand meter pulse relay installation by the power company. A 3/4 in. empty conduit with pull wire **shall** be run by the Electrical Contractor from the pulse relay location to a BAS panel location , usually in the main mechanical room. See Attachment 16142-B.

**END OF SECTION**

ATTACHMENT 16142-A – STANDARD ELECTRICAL CONNECTIONS TO EQUIPMENT

BRANCH CIRCUIT AND CONDUIT IN ELECTRICAL WORK  
 SEE PANELBOARD SCHEDULES FOR WIRE AND BREAKER  
 SIZES TO HVAC AND PLUMBING EQUIPMENT

EXTERNALLY OR INTERNALLY MOUNTED  
 DISCONNECT SWITCH FURNISHED BY  
 HVAC OR PLUMBING CONTRACTOR, OR  
 OTHER TRADES AND INSTALLED BY THE  
 ELECTRICAL CONTRACTOR.

EXTERNALLY MOUNTED STARTER  
 FURNISHED BY HVAC OR PLUMBING  
 CONTRACTOR OR OTHER TRADES,  
 INSTALLED BY ELECTRICAL CONTRACTOR.  
 LINE AND LOAD CONNECTIONS BY  
 ELECTRICAL CONTRACTOR. CONTROL  
 CONNECTIONS BY OTHERS. \*

EQUIPMENT IN HVAC OR PLUMBING WORK  
 OR WORK OF OTHER TRADES. SEE HVAC,  
 PLUMBING AND ARCHITECTURAL DRAWINGS  
 FOR LOCATION OF ALL EQUIPMENT.

FINAL CONNECTIONS INSIDE EQUIPMENT  
 TO BE MADE BY THE HVAC OR PLUMBING  
 CONTRACTOR OR OTHER TRADES


JUNCTION BOX MAY BE SHOWN ON  
 ELECTRICAL PLANS FOR SOME  
 EQUIPMENT (NOT NECESSARY IF  
 WIRING IS CONNECTED DIRECTLY  
 TO STARTER OR DISCONNECT  
 SWITCH.)

WIRING IN ELECTRICAL WORK


PANELBOARD

WIRING IN ELECTRICAL WORK

\*A COMBINATION STARTER MAY BE USED  
 IN LIEU OF A SEPARATE DISCONNECT  
 SWITCH AND STARTER



ATTACHMENT 16142-B – STANDARD PULSE RELAY CONDUIT DETAIL



1    **SECTION 16143 - WIRING DEVICES**

2

3    **PRODUCTS**

4     All receptacles and switches **shall** be minimum 20 amp. rated, heavy duty, specification  
5    grade.

6     Two-level lighting switches **shall** be 20 amp., double-pole, double throw, center off. See  
7    Attachment 16515-A for two-level lighting wiring scheme.

8

9    **EXECUTION**

10    Receptacles (Convenience Outlets)

11    1. Receptacles should be properly located throughout the building for cleaning  
12    equipment and other similar uses.

13    2. A minimum of one duplex receptacle **shall** be provided on the interior near the top  
14    of the ladder serving the scuttle to the roof area and at each exterior mechanical  
15    equipment location.

16    3. All receptacles over counters near sinks **shall** be either GFCI type or on a GFCI  
17    protected circuit.

18    4. Provide a duplex receptacle and work light in all crawl spaces, open chases and attic  
19    spaces.

20    Switches

21    1. All room switches should be placed in the most convenient location, preferably on  
22    the strike side of the entrance door to the area served, 48 in. above finish floor.

23    2. Building light switching and control methods are noted in Section 16515.

24

25

**END OF SECTION**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12

**SECTION 16420 - SERVICE ENTRANCE**

**GENERAL**

- The engineer **shall** coordinate with power supplier and indicate and/or specify all requirements for:
  - a. Point of service
  - b. Division of work (contractor and power company)
  - c. Fault current: Overcurrent device(s) **shall** have interrupting capacity in excess of available fault current throughout system.

**END OF SECTION**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23

**SECTION 16470 - PANELBOARDS**

**PRODUCTS**


- All panelboards **shall** have copper bus with bolt-in breakers. All panelboards **shall** be provided with main breakers, even for sub-panelboards that are served from another panelboard except where sub-panelboards are located in the same room as the panelboard serving them.

**EXECUTION**

- NEC required clearances **shall** be required around all panelboards. Show a clearance detail on drawings for clarification. See Attachment 16470-A.
- Provide dedicated surge protected circuits serving computers.
- Lighting panelboards **shall** only contain lighting circuits. All other loads such as receptacles, mechanical/plumbing equipment, etc. **shall** be served from separate panelboard(s).
- All panelboards **shall** be selected for 25% minimum spare electrical and physical capacity above the anticipated demand load.
- Specify typed directories in all panelboards. Room names and numbers in directories **shall** match final signage used at the site.
- Specify screwed on laminated plastic identification labels on cover of all panelboards.

**END OF SECTION**

1  
 2 ATTACHMENT 16470-A – PANELBOARD WORKING SPACE REQUIREMENTS  
 3



STRATES THE  
 N FRONT OF  
 ENT REQUIRED  
 IS OF THE  
 ICAL CODE.

NOTE:  
 NO PIPING, DUCTS OR EQUIPMENT FOREIGN TO THE ELECTRICAL EQUIPMENT OR ARCHITECTURAL APPURTENANCES SHALL BE PERMITTED TO BE INSTALLED IN, ENTER OR PASS THROUGH THE DEDICATED SPACES SHOWN ABOVE

BEST COPY AVAILABLE

1 **SECTION 16515 - LIGHTING**

2  
3 **GENERAL**

- 4  These requirements pertain to all interior, exterior canopy and exterior building lighting.  
5 Generally site lighting, such as for parking lots, is provided by the Power Company or  
6 others and is not a requirement of the building work. Coordinate with the WCPSS  
7 concerning the outdoor lighting requirements.
- 8  All lighting systems **shall** be designed based on IES and ANSI schoolhouse lighting  
9 standards.
- 10  Discuss lighting ideas and control strategies with WCPSS Energy Management and  
11 Physical Plant offices before design and layout of lighting systems.
- 12  Fluorescent light fixtures **shall** be T-8 lamps with electronic ballasts.
- 13  Area lighting **shall** be designed and provided by CP&L. Engineer to send set of plans to  
14 CP&L at the Design Development stage. Area lights to be "cobra heads" on 30 foot  
15 metal poles.
- 16  CP&L area lighting **shall** be shown on site plan prior to 100% C.D. submittal. Electrical  
17 contractor to provide conduit from area lights located in paved areas to adjacent non-  
18 paved surface.
- 19  Engineer **shall** review CP&L area lights and provide additional exterior building lighting  
20 (wall packs) as needed to insure that all exterior entrances and first floor windows are  
21 illuminated.
- 22  **Do not** locate light fixtures over stairwells. Use wall mounted light fixtures to light  
23 stairwells.

24  
25 **PRODUCTS**

- 26  Four (4) lamp prismatic fluorescent fixtures **shall** be used.
- 27  The use of indirect lighting or parabolic fixtures in areas of high computer concentration  
28 is acceptable.
- 29  Metal halide fixtures with color corrected lamps and automatic restrike may be used in  
30 gyms, multi-purpose rooms, high corridors and high library ceilings. High-pressure  
31 sodium fixtures **shall** be used for exterior corridors, walkways and on the building facade.  
32 Standard lamps **shall** be used in all fixtures.
- 33  Incandescent lighting **shall not** be used except for stage or special utility lighting, as  
34 approved by the WCPSS.
- 35  "U"tube fluorescent fixtures **shall not** be used.
- 36  No high-pressure sodium lamps under 100 watts are to be specified.
- 37  Do not specify "Emergency Light" brand emergency light fixtures.
- 38  Ballast manufacturers for fluorescent fixtures **shall** be Sylvania, Advance or Magna-  
39 Tech.
- 40  Lamp manufacturers for fluorescent fixtures **shall** be Sylvania, GE or Phillips.

41  
42 **EXECUTION**

- 43  Fluorescent lighting **shall** be laid out so that long dimensions are parallel with dry erase  
44 boards on primary wall. If no dry erase boards are present then fixtures should be parallel  
45 to cabinets and shelves.
- 46  All interior corridors and group toilet lights **shall** be controlled with key operated light  
47 switches and the use of lighting contactors. Provide Hand-Off-Auto (HOA) switch for  
48 each lighting contactor. Location of all lighting contactors to be clearly identified on  
49 plans.
- 50  Provide minimal night lighting in corridors and stairs.

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
March, 1999

- 1  All classrooms, labs, and other rooms greater than 100 sq. ft. **shall** have two level  
2 lighting with two (2) circuits per fixture controlled by a three (3)-position switch. See  
3 the accompanying drawing, Attachment 16515-A, for switching scheme.
- 4  When fixtures are used which require a warm-up, switches need to be located to assure  
5 against accidental or malicious switching. If the switches can not be located in a secure  
6 location, then locking switches are required.
- 7  Exterior lighting **shall** be provided for building entrances, outdoor storage areas, loading  
8 docks, bus ports, covered walkways, exterior mechanical room doors and other outdoor  
9 areas where in the judgment of the engineer or WCPSS, lighting is required for night  
10 functions, security, or safety.
- 11  Provide exterior floodlighting as required for present and future mobile classrooms.
- 12  Illumination Levels: Use Illuminating Engineering Society handbook as a guide.
- 13  Lighting calculations: **shall** be based on room surface reflectance for interior finishes  
14 selected by the architect, which in all cases **shall not** be less than the following for  
15 instructional areas. Ceiling Cavity - 80%, Walls - 50%, Floor Cavity - 20%.
- 16  Lighting calculations: The illumination levels shown in Attachment 16515-B are  
17 recommended minimum initial design levels.
- 18  Engineer **shall** furnish a copy of all lighting calculations to the Owner for review.
- 19  Fixture selection and placement **shall** provide the minimum practical amount of  
20 brightness and glare.
- 21  Due to constantly changing lighting technology, special designs not strictly adhering to  
22 the preceding recommended light levels, but still meeting the lighting needs in the  
23 engineer's opinion, **will not** be prohibited but should have prior approval of the WCPSS.

24  
25 **EXIT SIGNS**

- 26  Exit signs and directional signs related thereto **shall** be provided with power from two  
27 sources.
- 28  The primary source may be connected at any point within the normal lighting system.  
29 The secondary source **shall** operate automatically upon interruption of the primary  
30 source and **shall** be self-contained batteries unless a building emergency generator is  
31 provided.
- 32  Exit signs and directional signs related thereto **shall** be provided at all exit doors and as  
33 required to mark egress routes.
- 34  All exit signs **shall** be "LED" type with long-life light emitting diodes as manufactured  
35 by Exitronix, Lithonia (Signature Series) or equal.

36  
37 **EMERGENCY LIGHTING**

- 38  Emergency lighting **shall** be provided with power from two sources.
- 39  The primary source may be connected at any point within the normal lighting system.  
40 The secondary source **shall** operate automatically upon interruption of the primary  
41 source and **shall** be self-contained batteries unless a building emergency generator is  
42 provided.
- 43  The following areas **shall** have emergency illumination, whether having natural lighting  
44 or not:
- 45 -Exits and exit access corridors  
46 -Small and large assembly areas  
47 -Areas occupied by over 50 persons  
48 -Gymnasium dressing rooms  
49 -Band and choral rooms  
50 -Industrial arts, prevocational and shops  
51 -Administration or other building control centers

- 1       -Kitchens
- 2       -Group toilets
- 3       -Main electrical service disconnect location
- 4       -Main mechanical/boiler room
- 5       -Mechanical mezzanines
- 6       -Mechanical rooms
- 7       -Emergency power equipment location

8  
9

#### **LIGHTING SYSTEM SECURITY**

- 10    All practical measures should be taken to provide protection for lighting fixtures and  
11   equipment.
- 12    Vandal-resistant materials or metal guards **shall** be used for fixtures within reach of floors  
13   and all outdoor locations.
- 14    Mounting heights should be specified to afford protection, consistent with ease of  
15   maintenance. Mount light fixtures in stairwells 10 ft. above landing floors.
- 16    Exit signs and directional signs related thereto should be wall-mounted where possible in  
17   lieu of ceiling-mounted, as ceiling-mounted signs are subject to a much greater degree of  
18   abuse. Signs must be visible from anywhere within the length of an exit access corridor or  
19   directional signs **shall** be provided.
- 20    Certify foot-candle levels at job completion documents and provide report to Owner as  
21   part of closeout.

22  
23

**END OF SECTION**

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
**DESIGN GUIDELINES**  
 March, 1999

1  
 2  
 3  
 4  
 5

**ATTACHMENT 16515-B LIGHTING LEVEL TABLE**

<b>Type of Interior Areas</b>	<b>Recommended Minimum Initial Design Level</b>	<b>Remarks</b>
All interior areas other than listed below	70 foot-candles	Multipurpose rooms and auditorium stages need 70 foot-candles at full bright dimmer setting
Industrial art, prevocational or trade and industrial shops, laboratory and lecture room demonstration areas, and task lighting areas	100 foot candles	
Gymnasiums	50 foot candles	
Cafeterias and commons, stairways, and auditorium seating areas	30 foot candles	Auditorium seating areas need 30 foot-candles at full bright dimmer setting
Corridors, toilet areas, dressing rooms, storage rooms and boiler, mechanical or electrical rooms	25 foot candles	

6  
 7  
 8  
 9  
 10  
 11  
 12  
 13  
 14

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54

## SECTION 16721 FIRE ALARM SYSTEMS

### PART 1 - GENERAL

- //Spec writers notes: Search on "/" to locate commonly deleted items, items which are usually modified, or locations which require information to be input. Delete all items **not** required for the specific project being written then correct page breaks as required.

### RELATED DOCUMENTS

- Drawings and general provisions of Contract, including General and Supplementary Conditions and Division-1 Specification sections, apply to work of this section.

### SCOPE

- This section of the specifications includes the furnishing, installation, and connection of the microprocessor controlled, intelligent reporting fire alarm equipment required to form a complete coordinated system ready for operation. It **shall** include, but **not** be limited to, alarm initiating devices, alarm notification appliances, control panels, auxiliary control devices, annunciators, power supplies, and wiring as shown on the Drawings and specified herein.

- //Spec writers note: If system is being installed to replace an existing system verify that the Drawings detail the scope of any demolition that may be required. Pay particular attention to items that may be reused in the new system.

### QUALITY ASSURANCE

- Manufacturer's Qualifications: Firms regularly engaged in manufacture of fire alarm systems of types, sizes, and electrical characteristics required, and whose products are Listed and Labeled. Products of firms that **do not** maintain factory authorized service organization and spare parts stock are **not** acceptable for use on this project.
- Codes and Standards:
  - NFPA Compliance: Comply with applicable requirements of NFPA-72, National Fire Alarm Code.
  - NEC Compliance: Comply with applicable requirements of NFPA-70, National Electrical Code (NEC) standards pertaining to fire alarm systems.
  - Testing Laboratory Compliance: Comply with provisions of UL safety standards pertaining to fire alarm systems. Provide products and components which are Listed and Labeled.
  - FM Compliance: Provide fire alarm systems and accessories which are FM approved.

### SUBMITTALS - GENERAL

- Submittals **shall** demonstrate compliance with technical requirements by reference to each subsection of this specification. Where a submitted item **does not** comply fully with each and every requirement of the specifications, the submittal **shall** clearly indicate such deviations. Identification requirements for non-complying features of items are very specific. See Section //01 //, SUBMITTALS, for exact requirements.
  - Product Data: Submit Manufacturer's technical product data, including specifications and installation instructions, for each type of fire alarm system equipment.
  - Shop Drawings: Submit shop drawings showing equipment, device locations, and connecting wiring of entire fire alarm system. Include wiring and riser diagrams. Copies of Project Construction Documents or details therefrom may **not** be a part of the shop drawing submittal.

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
March, 1999

- 1 - Installation Instructions: Submit Manufacturer's detailed installation instruction  
2 for all duct mounted smoke detectors, flow switches, tamper switches, supervisory  
3 switches, and similar items which require mechanical installation.  
4  
5 - Maintenance Data: Submit maintenance data and parts lists for each type of fire  
6 alarm equipment installed, including furnished specialties and accessories. Include  
7 this data, product data, and shop drawings in maintenance manual.  
8 - Maintenance Contract: Submit a quote for a maintenance contract to provide all  
9 maintenance, test, and repair described below and/or in accordance with NFPA-  
10 72, "Guide for Testing Protection Signaling Systems". Include also a quote of  
11 unscheduled maintenance/repair, including hourly rates for technicians trained on  
12 this equipment, and response travel costs. Submittals that **do not** identify all post  
13 contract maintenance costs **will not** be accepted. Rates and costs **shall** be valid  
14 for the period of five (5) years after expiration of the guaranty. Maintenance  
15 and testing **shall** be on a semiannual basis //or as required by the local AHJ//. A  
16 preventive maintenance schedule **shall** be provided by the Contractor that **shall**  
17 describe the protocol for preventive maintenance. The schedule **shall** include:  
18 1. Semiannual systematic examination, adjustment and cleaning of all  
19 detectors, manual fire alarm stations, control panels, power supplies,  
20 relays, water flow switches and all accessories of the fire alarm  
21 system.  
22 2. Semiannual testing of each circuit in the fire alarm system.  
23 3. Semiannual testing of each smoke detector in accordance with the  
24 requirements of NFPA 72, Chapter 7.  
25 - //Post-Contract Expansion: If requested in writing by the A/E, the Contractor  
26 **shall** furnish as a part of the submittal package the cost of providing proposed  
27 system modifications and/or expansion.  
28 - Certifications: Submit a certification from the major equipment manufacturer  
29 indicating that the proposed supervisor of installation and the proposed  
30 performer of contract maintenance is an authorized representative of the major  
31 equipment manufacturer. Include names and addresses, and telephone numbers in  
32 the certification.  
33

## 34 PART 2 - PRODUCTS

### 35 MANUFACTURERS

- 36  Sample manufacturers are as follows:

37 Simplex  
38 Fire Control Instruments  
39 Cerebus Pyrotronics  
40

### 41 FIRE ALARM CONTROL PANEL (FACP)

- 42  FACP - General: The FACP **shall** meet the following general requirements:  
43 - Signal Line Circuits: Alarm, trouble and supervisory signals from all intelligent  
44 reporting devices **shall** be encoded onto an NFPA Style 6 (Class A) Signaling  
45 Line Circuit (SLC).  
46 - Initiation Device Circuits: Initiation Device Circuits (IDC) **shall** be wired Class  
47 A (NFPA Style D).  
48 - Notification Appliance Circuits: Notification appliance circuits **shall** be wired  
49 Class B (NFPA Style Y).  
50 - Digitized electronic signals **shall** employ check digits or multiple polling. In  
51 general a single ground or open on any system signaling line circuit, initiating  
52 device circuit, or notification appliance circuit **shall not** cause system  
53 malfunction, loss of operating power or the ability to report an alarm.  
54



WAKE COUNTY PUBLIC SCHOOL SYSTEM  
**DESIGN GUIDELINES**  
 March, 1999

1	Alarm Verification with Tally	Drift Compensation	
2	Automatic Day/Night Sensitivity Adjust	Device Blink Control	
3	Pre-alarm Control Panel Indication	Trouble Reminder	
4	NFPA 72 Smoke Detector Sensitivity Test	Walk Test	
5	System Status Reports	Periodic Detector Test	
6	Alarm Verification, by device, with tally	Multiple	Printer
7	Interface		
8	Multiple CRT Display Interface	Security	Monitor
9	Points		
10	Non-Alarm Module Reporting	Block Acknowledge	
11	Smoke Detector Maintenance Alert	Control-By-Time	
12	Ability to interface to Motorola Alert Central		

13  
 14  Central Processing Unit: The Central Processing Unit (CPU) **shall** communicate with,  
 15 monitor, and control all other modules within the control panel. Removal, disconnection  
 16 or failure of any control panel module **shall** be detected and reported to the system  
 17 display by the CPU.

- 18  
 19 - The CPU **shall** contain and execute all control-by-event (including ANDing,  
 20 ORing, NOTing, CROSSZONEing) programs for specific action to be taken if an  
 21 alarm condition is detected by the system. Such control-by-event programs **shall**  
 22 be held in non-volatile programmable memory, and **shall not** be lost with system  
 23 primary and secondary power failure. The CPU **shall** also provide a real-time  
 24 clock for time annotation of all system displays. The Time-of-Day and date  
 25 **shall not** be lost if system primary and secondary power supplies fail.  
 26 - The CPU **shall** be capable of being programmed on site without requiring the use  
 27 of any external programming equipment. Systems that require the use of external  
 28 programmers or change of EPROMs are **not** acceptable.  
 29 - The CPU and associated equipment are to be protected so that they **will not** be  
 30 affected by voltage surges or line transients consistent with UL standard 864.

31  Display: The system display **shall** provide all the controls and indicators used by the  
 32 system operator and may also be used to program all system operational parameters.  
 33 The display assembly **shall** contain, and display as required, custom alphanumeric labels  
 34 for all intelligent detectors, addressable modules, and software zones.

- 35 - The system display **shall** provide an 80-character back-lit alphanumeric Liquid  
 36 Crystal Display (LCD). It **shall** also provide five Light-Emitting-Diodes (LEDs),  
 37 that **will** indicate the status of the following system parameters: AC POWER,  
 38 SYSTEM ALARM, SYSTEM TROUBLE, DISPLAY TROUBLE, and SIGNAL  
 39 SILENCE.  
 40 - The system display **shall** provide a 25-key touch key-pad with control capability  
 41 to command all system functions, entry of any alphabetic or numeric  
 42 information, and field programming. Two different password levels **shall** be  
 43 accessible through the display interface assembly to prevent unauthorized system  
 44 control or programming.  
 45 - The system display **shall** include the following operator control switches:  
 46 SIGNAL SILENCE, LAMP TEST, RESET, and ACKNOWLEDGE.

47  Signaling Line Circuit (SLC) Interface Board: The FACP **shall** contain SLC interface  
 48 boards as required to communicate with the SLC loops as shown on the Drawings. Each  
 49 SLC board **shall** monitor and control a minimum of 198 intelligent addressable devices.  
 50 This includes 99 analog detectors (Ionization, Photoelectric, or Thermal) and 99  
 51 monitor or control modules.

- 52 - Each SLC interface board **shall** contain its own microprocessor, and **shall** be  
 53 capable of operating in a local mode (any SLC input activates all or specific SLC  
 54 outputs) in the event of a failure in the main CPU of the control panel. The SLC  
 55 interface board **shall not** require any jumper cuts or address switch settings to  
 56 initialize SLC Loop operations. SLC interface boards **shall** provide power and  
 57 communicate with all intelligent addressable detectors and modules connected to



WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
6 May 1992

- 1           it's SLC Loop on a single pair of wires. This SLC Loop **shall** be capable of  
2 operation as NFPA Style 4, Style 6, or Style 7.
- 3           - Each SLC interface board **shall** receive analog information from all intelligent  
4 detectors and **shall** process this information to determine whether normal,  
5 alarm, or trouble conditions exist for that particular detector. The SLC interface  
6 board software **shall** include software to automatically maintain the detector's  
7 desired sensitivity level by adjusting for the effects of environmental factors,  
8 including the accumulation of dust in each detector. The analog information may  
9 also be used for automatic detector testing and for the automatic determination of  
10 detector maintenance requirements.
- 11
- 12    Serial Interface Board: The FACP **shall** contain a serial interface board to provide an  
13 EIA-232 interface between the fire alarm control panel and the UL Listed Electronic  
14 Data Processing (EDP) peripherals. The serial interface board **shall** allow the use of  
15 multiple printers, CRT monitors, and other peripherals connected to the EIA-232 ports.  
16 In addition, the serial interface board **shall** provide one EIA-485 port for the serial  
17 connection to annunciation and control subsystem components; LEDs **shall** be provided  
18 to show operational status. All serial interface input/outputs **shall** be optically isolated  
19 to provide protection from surges and/or earth grounds.
- 20
- 21            //The serial interface **shall** be compatible to Motorola's Alert Central software  
22 package. This interface **shall** be used to communicate the complete fire alarm  
23 control panel 80 character message to pocket pagers.
- 24
- 25    Operators Terminal: Provide an operators terminal which allows the following  
26 minimum functions. In addition, the operators terminal **shall** support any other  
27 functions required for system control and/or operation:
- 28           1. Acknowledge (ACK/STEP) Switch  
29           2. Signal Silence Switch  
30           3. System Reset Switch  
31           4. System Test Switch  
32           5. Lamp Test Switch
- 33    Video Display Terminal: Where indicated on the Drawings provide a video display  
34 terminal with detachable keyboard to provide a visual display and an audible alert of all  
35 changes in status of the system and **shall** annotate such displays with the current time-  
36 of-day and date.
- 37    Printer: Where indicated on the Drawings provide a printer to provide hard-copy  
38 printout of all changes in status of the system. The printer **shall** time-stamp such  
39 printouts with the current time-of-day and date. The printer **shall** be standard carriage  
40 with 80-characters per line and **shall use** standard pin-feed paper. Thermal printers are  
41 **not** acceptable. The printer **shall** operate from a 120 VAC, 60 Hz power source.
- 42
- 43            //The system **shall** have a strip printer capable of being mounted directly in the  
44 system enclosure. Alarms **shall** be printed in easy to read RED, other messages,  
45 such as troubles, **shall** be printed in black. This printer **shall** receive power from  
46 the system power supply and **shall** operate via battery back-up in the event that  
47 AC power is are lost. The strip printer **shall** be UL-864 listed.
- 48
- 49    Remote Transmissions: The FACP **shall** be interfaced to a separate Digital Alarm  
50 Communications Transmitter (DACT) as indicated on the Drawings. Systems which  
51 contain built-in DACTs **shall** be acceptable on the condition of total compatibility with  
52 the Owner's receiving station equipment.
- 53    Power Supply: The FACP power supply(ies) **shall** operate on 120 VAC, 60 Hz and  
54 **shall** have a continuous rating adequate to power all equipment and functions in full  
55 alarm continuously. All modules and drivers must be able to withstand prolonged short  
56 circuits in the field wiring, either line-to-line or line-to-ground, without damage. Further,

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
March, 1999

1 the power supply **shall** be expandable for additional notification appliance power in 3.0  
2 Ampere increments.

- 3 - The power supply **shall** provide a battery charger for 24 hours of standby using  
4 dual-rate charging techniques for fast battery recharge.  
5

- 6  Enclosures: The FACP **shall** be housed in a UL listed cabinet suitable for surface or  
7 semi-flush mounting. Cabinet and front **shall** be corrosion protected, given a  
8 rust-resistant prime coat, and manufacturer's standard finish. The door **shall** provide a  
9 key lock and **shall** include a glass or other transparent opening for viewing of all  
10 indicators. For convenience, the door may be hinged on either the right or left side (field  
11 selectable).  
12

### 13 ALARM APPLIANCES

- 14  Programmable Electronic Sounders **shall** be located as shown on the Drawings; sounders  
15 located outdoors **shall** be listed for use in wet locations. Electric sounders **shall** have the  
16 following specifications:

- 17 - Voltage: Programmable electronic sounders **shall** operate on 24 VDC nominal.  
18 - Programming: Electronic Sounders **shall** be field programmable without the use  
19 of special tools, to provide slow whoop, continuous, or interrupted tones with an  
20 output sound level of at least 90 dBA measured at 10 feet from the device.  
21 - Mounting: Provide flush mounting devices suitable for mounting in a standard  
22 single gang device box unless otherwise indicated on the Drawings. Unless  
23 otherwise indicated on the Drawings, electronic sounders **shall** be mounted at 7'-  
24 6" (2.3 M) Above Finished Floor (AFF) or 6" (15.3 Cm) Below Finished Ceiling  
25 (BFC), whichever is lower.  
26

- 27  Strobe Lights **shall** be located as shown on the Drawings. Strobe lights indicated for use  
28 at exterior of the building **shall** be mounted at the indicated elevation and listed for use  
29 in wet locations. Strobe lights **shall** have the following specifications:

- 30 - Voltage: Strobe lights **shall** operate on 24 VDC nominal.  
31 - Maximum pulse duration: 2/10ths of one second.  
32 - Mounting: Provide flush mounting devices suitable for mounting in a standard  
33 single gang device box unless otherwise indicated on the Drawings. Unless  
34 otherwise indicated on the Drawings, strobe lights **shall** be mounted at 7'-6" (2.3  
35 M) Above Finished Floor (AFF) or 6" (15.3 Cm) Below Finished Ceiling (BFC),  
36 whichever is lower.  
37 - Strobe intensity and flash rate: Must meet minimum requirements of UL 1971.  
38 Provide strobe lights with specific intensity Candela (Cd) rating if such is  
39 indicated adjacent to the device symbol on the Drawings.

- 40  Audible/Visual Combination Devices **shall** be located as shown on the Drawings and **shall**  
41 comply with all applicable requirements for both Programmable Electronic Sounders and  
42 Strobe Lights. Unless otherwise indicated on the Drawings, combination A/V devices  
43 **shall** be mounted at 7'-6" (2.3 M) Above Finished Floor (AFF) or 6" (15.3 Cm) Below  
44 Finished Ceiling (BFC), whichever is lower.

- 45 - Bells **shall** be 10" diameter vibrating type located as shown on the Drawings;  
46 bells located outdoors **shall** be listed for use in wet locations. Bells **shall** have  
47 the following specifications:  
48 - Voltage: Bells **shall** operate on 24 VDC nominal.  
49 - Mounting: Provide flush mounting devices suitable for mounting in a standard  
50 single gang device box unless otherwise indicated on the Drawings. Bell mounting  
51 elevation **shall** be as described on the Drawings.  
52

### 53 INITIATING DEVICES

- 54  Addressable Devices - General: Unless otherwise indicated on the Drawings all initiating  
55 devices **shall** be individually addressable. Addressable devices **shall** comply with the  
56 following requirements:

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
6 May 1992

- 1           - Address Setting: Addressable devices **shall** provide an address-setting means that  
2 use rotary decimal switches configured to provide decade (numbered 1 to 10) type  
3 addresses. Devices which use a binary address setting method, such as a dip switch,  
4 are **not** acceptable.  
5
- 6           - Connections: Addressable devices **shall** be connected to a Signaling Line Circuit  
7 (SLC) with two (2) wires. Signaling Line Circuits **shall** originate as indicated on  
8 the Riser Diagram shown in the Drawings.  
9           - Operational Indications: Addressable initiation devices **shall** provide dual alarm  
10 and power LEDs. Both LEDs **shall** flash under normal conditions, indicating  
11 that the device is operational and in regular communication with the control  
12 panel. Both LEDs **shall** be placed into steady illumination by the FACP to  
13 indicate that an alarm condition has been detected. The flashing mode operation  
14 of the detector LEDs **shall** be optional through the system field program. An  
15 output connection **shall** also be provided in the device base to connect an  
16 external remote alarm LED.  
17           - Intelligent Initiation Devices: All smoke detectors **shall** be the "intelligent" in  
18 that smoke detector sensitivity **shall** be set through the FACP and **shall** be  
19 adjustable in the field through the field programming of the system. Sensitivity  
20 **shall** be capable of being automatically adjusted by the FACP on a time-of-day  
21 basis. Using software in the FACP, detectors **shall** be capable of automatically  
22 compensating for dust accumulation and other slow environmental changes that  
23 may affect performance. The detectors **shall** be listed by UL as meeting the  
24 calibrated sensitivity test requirements of NFPA Standard 72, Chapter 7.  
25           - Device mounting Base: Unless otherwise specified all detectors **shall** be ceiling-  
26 mount and **shall** include a separate twist-lock base with tamper proof feature.  
27           - Sounder Base: Where indicated on the Drawings, provide bases with a built-in  
28 (local) sounder rated at 85 dBA minimum. Configure sounder bases such that  
29 sounders are activated under conditions as described or otherwise indicated on the  
30 Drawings.  
31           - Test Means: The detectors **shall** provide a test means whereby they **will**  
32 simulate an alarm condition and report that condition to the control panel. Such  
33 a test may be initiated at the detector itself (by activating a magnetic switch) or  
34 initiated remotely on command from the control panel when in the "test"  
35 condition.  
36           - Device Identification: Detectors **shall** store an internal identifying type code  
37 that the control panel **shall** use to identify the type of device. Device  
38 identifications **shall** be either PHOTO or THERMAL.
- 39  Addressable Pull Stations - General: Addressable pull stations **shall**, on command from  
40 the Control Panel, send data to the panel representing the state of the manual switch.  
41 They **shall** use a key operated test-reset lock, and **shall** be designed so that after actual  
42 emergency operation, they cannot be restored to normal use except by the use of a key.  
43 Pull stations that employ a glass break rod are **not** acceptable.  
44           - All pull stations **shall** have a positive, visual indication of operation and utilize a  
45 key type reset.  
46           - Construction: Pull stations **shall** be constructed of Lexan or other material  
47 suitable to the installation environment with clearly visible operating instructions  
48 provided on the cover. The word FIRE **shall** appear on the front of the stations  
49 in raised letters, 1.75 inches or larger. Stations **shall** be suitable for surface  
50 mounting or semiflush mounting as shown on the plans. Unless otherwise  
51 indicated on the Drawings pull stations **shall** be mounted at 48" Above Finished  
52 Floor.
- 53  Photoelectric Smoke Detectors: Photoelectric smoke detectors **shall** use the  
54 photoelectric (light-scattering) principal to measure smoke density and **shall**, on  
55 command from the control panel, send data to the panel representing the analog level of  
56 smoke density. Unless otherwise indicated on the Drawings all smoke detectors **shall** be  
57 photoelectric type.

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
March, 1999

- 1    ❑ Thermal Detectors: Thermal Detectors **shall** be intelligent addressable devices rated at  
2    200°F. (93° C.) and unless otherwise indicated on the Drawings **shall** have a rate-of-rise  
3    element rated at 15° F. (9.4° C.) per minute. It **shall** connect via two wires to the Fire  
4    Alarm Control Panel Signaling Line Circuit. Up to 99 intelligent heat detectors may  
5    connect to one SLC loop. Thermal detectors **shall use** an electronic sensor to measure  
6    thermal conditions caused by a fire and **shall**, on command from the control panel, send  
7    data to the panel representing the analog level of such thermal measurements.  
8  
9    ❑ Non-Rate of Rise Detectors: Where indicated on the Drawings provide thermal detectors  
10   with non-rate of rise thermal elements. Non-rate of rise detectors are indicated by NRR  
11   adjacent to the thermal detector symbol.  
12   ❑ Duct Smoke Detector: In-Duct Smoke Detector Housings **shall** accommodate either an  
13   intelligent ionization sensor or an intelligent photoelectric sensor as described elsewhere.  
14   The device, independent of the type used, **shall** provide continuous analog monitoring  
15   and alarm verification from the panel. When sufficient smoke is sensed, an alarm signal  
16   **shall** be initiated at the FACP.  
17       - Installation: Duct detectors and related items **shall** be furnished and connected  
18       by the Division 16 (Electrical) Contractor but installed by the Division 15  
19       (Mechanical) Contractor.  
20

21   **MISCELLANEOUS SYSTEM ITEMS**

- 22   ❑ Addressable Dry Contact Monitor Module: Addressable Monitor Modules **shall** be  
23   provided to connect one supervised IDC zone (either Style D or Style B) of conventional  
24   Alarm Initiating Devices (any Normally Open [N.O.] dry contact device) to one of the  
25   Fire Alarm Control Panel Signaling Line Circuit Loops. Monitor modules **shall** be  
26   installed as required by the system configuration. All required monitor modules may **not**  
27   be shown on the Drawings.  
28   ❑ Indication of Operation: Unless otherwise indicated on the Drawings an LED **shall** be  
29   provided that **shall** flash under normal conditions, indicating that the Monitor Module is  
30   operational and in regular communication with the control panel.  
31       - Mounting Requirements: Monitor Modules **shall** mount in a standard 4-inch  
32       square, 2-1/8" deep electrical boxes.  
33   ❑ Two Wire Detector Monitor Module: Addressable Monitor Modules **shall** be provided to  
34   connect one supervised IDC zone, either Class A or B (Style D or Style B operation) of  
35   conventional 2- wire smoke detectors or alarm initiating devices (any N.O. dry contact  
36   device) to one of the Fire Alarm Control Panel Signaling Line Circuit Loops. Monitor  
37   modules **shall** be installed as required by the system configuration. All required monitor  
38   modules may **not** be shown on the Drawings.  
39       - Indication of Operation: Unless otherwise indicated on the Drawings an LED  
40       **shall** be provided that **shall** flash under normal conditions, indicating that the  
41       Monitor Module is operational and in regular communication with the control  
42       panel.  
43       - Mounting Requirements: Monitor Modules **shall** mount in a standard 4-inch  
44       square, 2-1/8" deep electrical boxes.  
45   ❑ Addressable Control Module: Addressable Control Modules **shall** be provided to supervise  
46   and control the operation of one conventional Notification Appliance Circuit (NAC) of  
47   compatible, 24 VDC powered, polarized Audio/Visual (A/V) Notification Appliances. For  
48   fan shutdown and other auxiliary control functions, the control module may be set to  
49   operate as a dry contract relay. The control module **shall** provide address-setting means  
50   using decimal switches and **shall** also store an internal identifying code that the control  
51   panel **shall use** to identify the type of device. An LED **shall** be provided that **shall**  
52   flash under normal conditions, indicating that the control module is operational and is in  
53   regular communication with the control panel.  
54       - Mounting Requirements: Control Modules **shall** mount in a standard 4-inch  
55       square, 2-1/8" deep electrical boxes.  
56       - Configuration: The control module NAC circuit may be wired for Style Z or Style  
57       Y (Class A/B) with up to 1 Amp of inductive A/V signal, or 2 Amps of resistive

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
6 May 1992

- 1 A/V signal operation, or as a dry contact (Form C) relay. The control module  
2 **shall** be suitable for pilot duty applications and rated for a minimum of 0.6 amps  
3 at 30 VDC. The relay coil **shall** be magnetically latched to reduce wiring  
4 connection requirements, and to insure that 100% of all auxiliary relay or NACs  
5 may be energized at the same time on the same pair of wires.
- 6 - Power Source: Audio/visual power **shall** be provided by a separate supervised  
7 power loop from the main fire alarm control panel or from a supervised, UL  
8 listed remote power supply. A/V power sources and connections are **not** shown  
9 on the Drawings
  - 10 - Test Switch: A magnetic test switch **shall** be provided to test the module without  
11 opening or shorting its NAC wiring.
- 12  Isolator Module: Isolator Modules **shall** be provided to automatically isolate wire-to-  
13 wire short circuits on an SLC loop. The Isolator Module **shall** limit the number of  
14 modules or detectors that may be rendered inoperative by a short circuit fault on the SLC  
15 Loop.
- 16 - Operation: Isolator Modules **shall** operate such that if a wire-to-wire short  
17 occurs, the Isolator module **shall** automatically open-circuit (disconnect) the  
18 SLC loop. When the short circuit condition is corrected, the Isolator Module  
19 **shall** automatically reconnect the isolated section. The Isolator Module **shall**  
20 **not** require any address-setting, and its operations **shall** be totally automatic. It  
21 **shall not** be necessary to replace or reset an Isolator Module after its normal  
22 operation.
  - 23 - Mounting: The Isolator Module **shall** mount in standard 4-inch square, 2-1/8"  
24 deep electrical boxes. It **shall** provide a single LED that **shall** flash to indicate  
25 that the Isolator is operational and **shall** illuminate steadily to indicate that a  
26 short circuit condition has been detected and isolated.

27  
28 //DELETE THE FOLLOWING TWO ITEMS FOR BUILDINGS WITHOUT SPRINKLER  
29 SYSTEMS

- 30
- 31  Water Flow Switch: Flow switches **shall** be integral, mechanical, non-coded,  
32 non-accumulative retard type. Flow switches **shall** have an alarm transmission delay  
33 time that is conveniently adjustable from 0 to 60 seconds. Initial settings **shall** be 30-45  
34 seconds. Flow switches **shall** be located a minimum of one (1) foot from a fitting that  
35 changes the direction of the flow and a minimum of three (3) feet from a valve.
- 36 - Location: Locations shown on the Drawings for water flow switches are  
37 approximate. Coordinate exact location with the sprinkler system installer.
  - 38 - Installation: Water Flow Switches **shall** be furnished and installed by the  
39 Division 15 (Mechanical) Contractor and electrically connected by the Division  
40 16 (Electrical) Contractor.
- 41  Sprinkler and Standpipe Valve Supervisory Switch: Supervisory switch mechanisms **shall**  
42 be contained in a weatherproof aluminum housings that **shall** provide a 3/4 inch tapped  
43 conduit entrance and **shall** incorporate the necessary facilities for attachment to the  
44 valves. Switch housing **shall** be finished in red baked enamel.
- 45 - Installation: Mount switch so as **not** to interfere with the normal operation of  
46 the valve and adjust to operate within two revolutions toward the closed position  
47 of the valve control, or when the stem has moved no more than one-fifth of the  
48 distance from its normal position. The entire installed assembly **shall** be tamper  
49 resistant and **shall** be arranged to cause a switch operation if the housing cover is  
50 removed or if the unit is removed from its mounting.
  - 51 - Installation: Supervisory switches **shall** be furnished and installed by the Division  
52 15 (Mechanical) Contractor and electrically connected by the Division 16  
53 (Electrical) Contractor.

54  
55 //DELETE THE PROCEEDING TWO ITEMS FOR BUILDINGS WITHOUT SPRINKLER  
56 SYSTEMS

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
March, 1999

- 1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52
- **Serially Connected LED Annunciator:** Annunciator **shall** communicate with the fire alarm control panel *via* an EIA-485 communications loop (four-wire) and **shall** individually annunciate all zones in the system. System zones **shall** be as indicated on the Drawings. Up to 10 annunciators may be connected to the EIA-485 communications loop.
    - **Annunciator Indicators:** The annunciator **shall** provide a red Alarm LED per zone, and a yellow Trouble LED per zone. The annunciator **shall** also have an "ON-LINE" LED, local piezo sounder, local acknowledge/lamp test switch, and custom zone/function identification labels. All annunciator switches and indicators **shall** be software programmable.
  - **LCD Alphanumeric Display Annunciator:** The Alphanumeric display annunciator **shall** be a supervised, remotely located back-lit LCD display containing a minimum of eighty (80) characters for alarm annunciation in clear English text. The LCD annunciator **shall** display all alarm and trouble conditions in the system.
    - **System Capacity:** The system **shall** allow a minimum of four LCD annunciators. In addition to annunciation functions, each LCD annunciator **shall** be capable of the following software programmed system functions: Acknowledge, Signal Silence and Reset.
    - **Connections:** The annunciator **shall** connect to a two-wire EIA-485 interface. The two-wire connection **shall** be capable operation at distances of 6,000 feet. Provide interface to fiber optic cable systems and/or repeater units where such are indicated on the Drawings.
  - **Batteries:** **Shall** be completely maintenance free and **shall not** require liquids, fluid level checks, refilling, and **shall not** be capable of producing spills and/or leaks. Battery voltage **shall** be as required by the FACP and related equipment. Battery **shall** have sufficient capacity to power the fire alarm system for **not** less than twenty-four hours plus 5 minutes of alarm upon a normal AC power failure.
  - **Remote Annunciator Indicator Lights (RAIL):** Remote annunciator indicator lights **shall** be provided in locations where indicated on the Drawings. RAILS **shall** be provided with a key type switch for testing of the annunciated device. In addition, RAILS **shall** have the following features:
    - **Voltage:** RAILS **shall** operate on 24 VDC nominal.
    - **Mounting:** Provide flush mounting devices suitable for mounting in a standard single gang device box unless otherwise indicated on the Drawings. Unless otherwise indicated on the Drawings, RAILS **shall** be mounted as described for electronic sounders above.
  - **Door Hold-Open Magnets:** Door hold open magnets **shall** be suitable for mounting in a single gang electrical device box. Door hold open magnets **shall** be furnished with keepers, door chains, and other accessories as required to properly hold open doors as indicated on the Drawings. Holding force of the magnet **shall** be appropriate for the door to be held open. Proper attachment of door magnet hardware to doors is the responsibility of the Division 16 contractor. Door hold open magnets **shall** operate in a fail safe manner, *i.e.*, the door **shall** release in event of a failure of voltage to the device.
    - **Door hold open magnets:** Door hold open magnets **shall** be configured to operate from a nominal 24 VDC system as supplied by the FACP. All hold open magnet supply sources **shall** be supervised.
    - **Device box support:** Door hold open magnet device boxes **shall** be securely attached to the building structure by means of wood blocking or other equally effective means. Boxes attached directly to only one metal stud or boxes supported by means of expansion type fasteners are **not** acceptable.

53 **PART 3 - SYSTEM REQUIREMENTS**

- 54 □ Fire and smoke detection and alarm systems **shall** comply with the following system  
55 requirements with regard to operation and installation.

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
6 May 1992

- 1 - All equipment and components **shall** be installed in strict compliance with  
2 manufacturers' recommendations. Consult the manufacturer's installation  
3 manuals for all wiring diagrams, schematics, physical equipment sizes, etc., before  
4 beginning system installation. Refer to the Riser/Connection diagram for all  
5 specific system installation/termination/wiring data.  
6
- 7 - All system components **shall** be attached to walls and ceiling/floor assemblies and  
8 **shall** be held firmly in place (*e.g.*, detectors **shall not** be supported solely by  
9 suspended ceilings). Fasteners and supports **shall** be adequate to support the  
10 required load. Adhesives are **not** permitted to mount fire alarm system  
11 components to building surfaces or structure.
- 12  The system **shall** be new and furnished with a warranty (parts & labor) of at least one  
13 year from the date of final inspection and acceptance by the Owner. Equipment,  
14 initiating devices, and alarm appliances **shall** be arranged as described in the Drawings;  
15 annunciator zones **shall** be configured as described in the Drawings.
- 16  The system **shall** be equipped with the following protective devices to prevent damage  
17 or nuisance alarms by nearby lightning strikes, stray currents, or voltage transients. The  
18 devices are to be provided by the fire alarm equipment supplier:
- 19 - On AC Input: Leviton 51010-WM, Square-D Q02175SB or equivalent Listed  
20 device. Install at panelboard and trim excess lead lengths. Wind small coil in  
21 branch circuit conductor, within panelboard, downstream of the suppressor  
22 connection. Coil is to be about 1" diameter, 5 to 7 turns, and tie-wrapped.
- 23 - On DC Circuits Extending Outside Building: Near the point of entry to or exit  
24 from each building, provide a "pi" filter on each leg. The filter **shall** consist of a  
25 primary arrestor, typically a gas tube, a series impedance of 1 mH or more, and a  
26 fast acting secondary arrestor which clamps between 30 and 40 Volts. Acceptable  
27 models include Simplex 2081-9027 and 2081-9028, Transtector FSP4002, and  
28 TSP9002, Citel America B280-24V, Edco P264 and P642, or equivalent by  
29 Innovative Technology or other supplier.
- 30  Both audible and visible alarm signals **shall** be provided. Visible signals must be the strobe  
31 (flash discharge) type, with white or clear lens, and **shall** comply with current ADA  
32 requirements for intensity and placement.
- 33  The FACP must have an Alarm Silence switch, and be equipped with the Subsequent  
34 Alarm (alarm resound) feature. Any remote annunciators or graphic displays located  
35 away from the alarm area must also include an audible signal with alarm resound feature.
- 36  //If the system includes AHU shutdown or smoke removal startup, silencing the alarm  
37 (without resetting) must **not** reverse them. A supervised "AHU Shutdown Defeat" switch  
38 must be provided in the FACP. The switch must be labeled and its "Normal" position  
39 indicated. Provide supervised Hand-Off-Auto switch(es) at the FACP for any building  
40 smoke control equipment (pressurization or exhaust fans).
- 41  The coverage of each fire alarm zone as described in the Drawings **shall** be indicated on  
42 the FACP and any remote annunciator. This may be accomplished by engraved labels,  
43 framed directories, and/or graphic displays. Label tape or handwritten labels are **not**  
44 acceptable.
- 45  //Detectors used for elevator capture are identified on the Drawings by the designation EL  
46 adjacent to the detector. Primary and/or alternate recall points are indicated by the  
47 designation PRI or ALT respectively. Elevator capture or control signals must come  
48 from the FACP as relayed by control modules. Use of detector auxiliary contacts for  
49 elevator capture is **not** acceptable.
- 50  Systems are to be provided with a separate and independent source of emergency power.  
51 Switching to emergency power during alarm **shall not** cause signal drop-out. Batteries  
52 must meet the appropriate NFPA capacity requirements, with a 25% safety factor. This  
53 requirement is in effect even if generator power is supplied to the Fire Alarm Control  
54 Panel.

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
March, 1999

- 1  Style 6 Circuits Required: Systems with one or more addressable sub-panels that (1) have  
2 an integral addressable loop controller, or (2) monitor multiple conventional initiation  
3 zones, **shall** comply with the NFPA 72 requirements for Style 6 circuits.
- 4  All wiring **shall** be color coded in accordance with the following scheme, which **shall** be  
5 maintained throughout the system, without color change in any wire run:  
6
- |    |    |                                     |                                  |
|----|----|-------------------------------------|----------------------------------|
| 7  | // | Initiating Circuits, General        | Red (+)/White (-)                |
| 8  | // | Initiating Circuits, Smoke Only     | Violet (+)/Gray (-)              |
| 9  |    | Signal Line Circuit cable           | Red jacket with Red (+)/Black(-) |
| 10 |    | Alarm Indicating Appliance Circuits | Blue (+)/Black (-)               |
| 11 |    | AHU Shutdown Circuits               | Yellow (+)/Brown (-)             |
| 12 |    | Door Control Circuits               | Orange                           |
| 13 |    | Elevator Capture Circuits           | Brown                            |
- 14 //Spec writers note: Some of the above colors are **not** relevant to addressable systems  
15 and apply only to extension of existing zoned systems.  
16
- 17  There **shall** be NO splices in the system other than at terminal blocks. "Wire nuts,"  
18 crimp splices, or insulation piercing type connectors are **not** acceptable. All terminal  
19 block screws **shall** have pressure wire connectors of the self-lifting or box lug type.
- 20  Permanent wire markers **shall** be used to identify all splices and terminations for each  
21 circuit. For splices, **use** markers or other means to indicate which conductors leads to  
22 the FACP. All junction boxes and covers **shall** be painted red, unless in finished areas.
- 23  //In multistory buildings, all circuits leaving the riser on each floor **shall** feed through a  
24 labeled terminal block in a hinged enclosure, located for convenient access.
- 25 - //Spec writers note: The following section deals with fire alarm system raceway.  
26 Always provide RACEWAYS section in the Division 16 specifications. For fire  
27 alarm systems in existing structures be sure RACEWAY section details the  
28 conditions under which surface metal raceway is required, how it is to be installed,  
29 and how it is to be painted.
- 30  All wiring and cable must be in EMT, 3/4" minimum diameter, unless indicated otherwise  
31 on the Drawings or elsewhere in the Specifications. All fire alarm system raceway,  
32 couplers, and connectors must meet the performance and installation requirements of  
33 Section //16 // "RACEWAYS".
- 34 - The exterior of all junction boxes containing fire alarm conductors **shall** be  
35 painted red; box interiors **shall not** be painted. Box covers for junction boxes  
36 containing fire alarm conductors **shall** be painted red on both sides. All painting  
37 of junction boxes and junction box covers **shall** be accomplished prior to  
38 installation of the boxes to avoid possible problems with overspray.
- 39 - Box covers **shall** be labeled to indicate the circuit(s) or function of the  
40 conductors contained therein. Labels **shall** be neatly applied black lettering on a  
41 clear background. Handwritten labels or labels made from embossed tape are **not**  
42 acceptable.
- 43  Wire **shall** be new AWG #14 minimum stranded copper, type THHN/THWN. Wiring  
44 for electronic communications between system components where individual conductors  
45 are **not** judged appropriate by the equipment manufacturer may be routed in  
46 multi-conductor cable Listed for the purpose. Minimum cable conductor size is AWG #16  
47 stranded copper conductors.
- 48  Detection or alarm circuits must **not** be included in raceways containing AC power or AC  
49 control wiring. Within the FACP, any 120 VAC control wiring or other circuits with an  
50 externally supplied AC/DC voltage above the nominal 24 VDC system power must be  
51 properly separated from other circuits and the enclosure must have an appropriate  
52 warning label to alert service personnel to the potential hazard.
- 53  Provide an engraved label in FACP identifying its 120 VAC power source. This label  
54 **shall** include panelboard location, identification, and circuit number.
- 55  All wiring **shall** be checked for grounds, opens, and shorts, prior to termination at panels  
56 and installation of detector heads. The minimum resistance to ground or between any

- 1 two conductors **shall** be ten megohms (10 M $\Omega$ ), as verified with a megger. Provide  
2 advance notice to the A/E of these tests.
- 3  All connections at the FACP must be made by the Manufacturer's authorized, factory  
4 trained representative (rather than by the electrical contractor).
- 5  The system **shall** be electrically supervised for open or (+/-) ground fault conditions in  
6 SLC, alarm circuits, and control circuits. Removal of any detection device, alarm  
7 appliance, plug-in relay, system module, or standby battery connection **shall** also result  
8 in a trouble signal. Fire alarm signal **shall** override trouble signals, but any pre-alarm  
9 trouble signal **shall** reappear when the panel is reset.
- 10  //Sprinkler system supervisory circuits for monitoring valve position, air pressure, water  
11 temperature, pump status, etc., must cause distinct audible and visible indications at the  
12 FACP. The audible supervisory signal **shall** either be a 4" diameter bell or a pulsing  
13 piezo-electric alarm. Provide the following engraved label adjacent to the bell/alarm:  
14 "SPRINKLER STATUS ABNORMAL". If only valve position is supervised, provide an  
15 engraved label reading: "SPRINKLER VALVE CLOSED".
- 16  Spare Parts: Provide the following spare parts with the system, each individually  
17 packaged and labeled. For multi-building projects, calculate separately for each building:
- |                                |                                   |
|--------------------------------|-----------------------------------|
| 18 Fuses                       | 2 of each size used in the system |
| 19 Manual Stations             | 2% of installed quantity          |
| 20 Indoor Horns/Strobes        | 4% of installed quantity          |
| 21 Spot Smoke Detectors, Bases | 6% of installed quantity          |
- 22 -Increase decimal quantities of spare parts to the next higher whole number. For  
23 example if a system has 20 spot-type smoke detectors provide 2 spare detectors with  
24 bases.

#### 25 26 SMOKE DETECTORS

- 27  Detectors must be the plug-in type, each having a separate base, to facilitate replacement  
28 and maintenance. When installed in a room, detectors **shall** be oriented so their alarm  
29 light is visible from the nearest door to the corridor, unless Remote Alarm Indicator  
30 Light (RAIL) equipped.
- 31  Spot type smoke detectors mounted within 12 feet of a walking surface **shall** have their  
32 built-in locking device activated.
- 33  Unless suitably protected against dust, paint, etc., detectors **shall not** be installed until  
34 the final construction clean-up has been completed. Contaminated detectors must be  
35 REPLACED by the Contractor at no additional cost to the Owner.
- 36  Identification of individual detectors is required, by the unique number indicated on the  
37 Drawings. These device numbers, which must also be shown on the shop drawings, **shall**  
38 be permanently affixed to the detector base. Device labels may **not** be affixed to the  
39 device. Identification labels must be printed labels with black lettering on a clear  
40 background. Handwritten labels or labels made from embossed tape are **not** acceptable.
- 41  //Where shown on the Drawings air duct/plenum detectors must have a RAIL located in  
42 the nearest corridor or public area and identified by an engraved label affixed to the wall  
43 or ceiling. These detectors **shall** be installed in a manner that provides suitable access  
44 for required periodic cleaning and calibration.
- 45  //Duct detector sampling tubes **shall** extend the full width of the duct. Those over 36  
46 inches long must be provided with rear support. The preferred method for doing this is to  
47 have the tube go through the far side of the duct, with the point of penetration tightly  
48 sealed to prevent air leakage around the tube. This facilitates smoke testing and tube  
49 cleaning. Duct smoke detector mounting position and air sampling tube orientation, are  
50 critical for proper operation. The Manufacturer's detailed installation instructions must  
51 be followed. The contractor **shall** mark the direction of air flow on the duct at each duct  
52 detector location.
- 53  //Smoke detector guards, where indicated on the Drawings **shall** be Listed for use with the  
54 specific model of smoke detector being protected. All smoke detector guards are to have  
55 a separate base which must be very securely anchored to wall or ceiling. The cover must  
56 be readily removable by the Owner for periodic detector cleaning and servicing but, to

1 prevent unauthorized entry, must be secured to the base by a lock or tamper resistant  
2 screws approved by the A/E. Metal guards must be 16 gauge or heavier steel.

3  
4 **AUTOMATIC SMOKE DOOR HOLD OPEN MAGNET REQUIREMENTS**

- 5  Wall-mounted magnetic door holders and separate heavy-duty closers **shall** be used,  
6 instead of combination door control units.  
7  The electromagnets **shall** be controlled by the building's smoke detection system FACP.  
8 Individual smoke detector auxiliary contacts **shall not** be used to release door holders.

9  
10 **SPRINKLER SYSTEM MONITORING**

- 11  The following sprinkler system alarm and supervisory functions **shall** be provided as a  
12 part of the fire alarm system:  
13 1. Waterflow alarm, by sprinkler zone (**not** to exceed one floor).  
14 2. Supervision of each control valve.  
15 3. Supervision of air pressure, if used (both high and low).  
16 4. Supervision of fire pump.  
17  Sprinkler supervisory monitoring of flow switches, tamper switches, and similar functions  
18 **shall** be accomplished with a separate system address for each activity monitored.

19  
20 **KITCHEN EXHAUST HOOD EXTINGUISHING SYSTEMS**

- 21  Installation **shall** comply with the current edition of NFPA Standard for the type of  
22 system installed.  
23  System(s) **shall** be interconnected with the fire alarm system as a separate system  
24 address.  
25  The following operational requirements are generally provided directly by the  
26 extinguishing system. The Contractor **shall** verify that the means for providing the  
27 following operation sequence is in place:  
28 - The exhaust fan must continue running after the system has been discharged,  
29 (except on carbon dioxide systems) to remove smoke; the supply fan should  
30 stop.  
31 - All sources of heat for appliances served by the extinguishing system (both  
32 electric and/or gas) must be turned off.

33  
34 **FIRE ALARM SYSTEM INSTALLATION AND CONFIGURATION**

- 35  In addition to other requirements of these Specifications the fire alarm system must  
36 comply with the following:  
37 - The addressable fire alarm system **shall** be connected, programmed, and tested  
38 only by the Manufacturer or by an authorized distributor who stocks a full  
39 compliment of spare parts for the system.  
40 - Technicians performing this service **shall** be trained and individually certified by  
41 the Manufacturer for the model of system being installed.  
42 - Copies of installer certification must be included with the Contractor's submittal.  
43  Any Personal Computer (PC), laptop, or other similar items or equipment necessary to  
44 program the fire alarm system **shall** be furnished by the Contractor as required to  
45 accomplish programming at no additional cost to the Owner. It is **not** the intention of  
46 this section to require the Contractor to provide a PC to the Owner as a part of the fire  
47 alarm system.  
48  The complete configuration data (site-specific programming) for the system must be  
49 permanently stored on a computer disk or diskette and archived by the manufacturer or  
50 authorized distributor. A diskette copy of this data must be submitted to the A/E for  
51 transmission to the Owner when the system is commissioned.  
52  The Manufacturer or authorized distributor must maintain software version (VER) records  
53 on the system installed. The system software **shall** be upgraded free of charge if a new  
54 VER is released for any reason during the warranty period. For any new VER to correct  
55 problems, free upgrade **shall** apply during the entire life of the system.

- 1  All addressable loop controller circuits must be "Class A" and **shall** have a minimum of  
2 20% spare addresses for future use. "T-taps" from the loop are **not** permitted. To  
3 minimize the impact of a wiring fault on the system, isolation modules must be provided  
4 as follows:  
5 1. After each 30 devices/control points on any addressable circuit.  
6 2. For each circuit extending outside the building.  
7 3. At the FACP, at each end of the loop.  
8  
9  Supervision required: The connection between individual addressable modules and their  
10 contract type initiating device(s) must be supervised.  
11  The Fire Alarm System **shall** have multiple access levels which permit the Owner's  
12 authorized personnel to make temporary changes in the system alarm response matrix  
13 without actually changing the system programming. This must include the ability to  
14 override selected alarm inputs or system responses to alarms without affecting the  
15 remaining portions of the system.  
16  
17 //The fire alarm system **shall** have a self-contained modem with a minimum  
18 speed of 9,600 baud for external communications purposes. All system  
19 functions and programming features must be available through the modem  
20 port. The modem port **shall** be password protected with multiple access  
21 levels as described above. Telephone lines and connections to the modem  
22 **will** be furnished and installed by the Owner.//  
23  
24  Where indicated on the Drawings, a Graphic Annunciator (GA) with separate Light  
25 Emitting Diodes (LED) indication for each alarm and supervisory signal initiating device  
26 **shall** be included. Multiple initiating devices of the same type within a single room may  
27 be permitted to share a common LED. The GA must show all major building features  
28 such as corridors, elevators, stairs, exits, and "YOU ARE HERE". GA layout must be  
29 submitted for approval.  
30  In addition to the system tests and certification described elsewhere, the Manufacturer or  
31 authorized distributor must 100% test all site-specific software functions for the system  
32 and provide a written test report or detailed check list. This documentation must include  
33 a system operation matrix showing the actual FACP response for each initiating device  
34 input.  
35  
36

### 37 PART 3 - SYSTEM TESTING & CERTIFICATION

- 38  Upon completion of the installation the Division 16 Contractor and the Manufacturer's  
39 authorized representative together **shall** test each and every alarm initiating device for  
40 proper response and annunciation, every alarm signaling appliance for effectiveness, and  
41 all other functions such as elevator capture, control of smoke doors/dampers, proper  
42 operation of HVAC systems, and pressurization fans. ALL supervised circuits must also  
43 be tested to verify proper supervision. (Control circuits and remote annunciation lines  
44 are among those required to be supervised.)  
45  The A/E must be given 7 days advance notice of the tests.  
46  The contractor must submit the following test documentation:  
47 1. Written verification that this 100% system test was done.  
48 2. Measured sensitivity of each smoke detector.  
49 3. NFPA-72 "Fire Alarm System Certification and Description".  
50  
51  After completion of the 100% system test and submission of the above documentation,  
52 the contractor **will** request in writing that the A/E to set up a final inspection with the  
53 Owner and the Authority Having Jurisdiction. The system must operate for at least two  
54 days prior to this inspection. The system **will** be inspected and functionally tested on a  
55 sample basis. Equipment intended for open area protection or releasing device service

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
March, 1999

1 may be subjected to simulated or actual test fires, in accordance with ANSI/UL guidelines  
2 and sound engineering practice, to verify proper response.

- 3  
4  If the initial inspection determines that the required 100% system test was **not**  
5 reasonably done, or if a reinspection of the project is requested without the punch list  
6 being nearly completed, the Contractor *may* be required to reimburse the Owner for  
7 inspection costs as //defined in the Supplementary General Conditions of the Contract//.  
8  
9  After successful completion of inspections and tests, the warranty period begins. In the  
10 event of malfunctions or excessive nuisance alarms, the Contractor must take prompt  
11 corrective action. The Owner may require a repeat of the Contractor's 100% system  
12 test, or other inspections. Continued improper performance during the warranty period  
13 **shall** be cause to require the Contractor to remove the system.

14  
15 **SYSTEM DOCUMENTATION, TRAINING, AND MAINTENANCE**

- 16  The contractor **shall** provide the A/E with three copies of the following:  
17 1. As-built wiring and conduit layout diagrams, including wire color code and/or  
18 label numbers, and showing all interconnections in the system.  
19 2. Electronic circuit diagrams of all control panels, modules, annunciators,  
20 communications panels, etc.  
21 3. Technical literature on all major parts of the system, including control  
22 panels, batteries, detectors, manual stations, alarm indicating appliances,  
23 power supplies, and remote alarm transmission means.  
24  
25  The contractor **shall** provide the A/E with one copy of the following:  
26 1. All software required, both for the installed fire alarm system and for any  
27 personal computer (PC) necessary to access the fire alarm system for trouble  
28 shooting, programming, modifications, monitoring, de-bugging, or similar  
29 functions.  
30 2. Complete documentation for all software for both the installed fire alarm  
31 system and for any interface PC software necessary for system functions as  
32 described in (1) above.  
33  
34  The Contractor **shall** provide the A/E with one each interconnection cable where such is  
35 required to connect the fire alarm system to a PC.  
36  The Manufacturer's authorized representative **shall** provide training for the Owner's  
37 designated employees in proper operation of the system and in all required periodic  
38 maintenance.  
39  Scheduling of training must be arranged to meet the Owner's schedule.  
40  A maximum of 20 hours of training **shall** be provided at no additional cost to the Owner  
41 with additional training available at a cost to be mutually agreed upon by the Owner and  
42 the Contractor.  
43  The instruction **shall** include a minimum of two copies of a written, bound training  
44 summary, for future reference.  
45  Basic operating instructions **shall** be framed and mounted at the FACP.

46  
47  
48 **END OF SECTION**

**BEST COPY AVAILABLE**

1  
2 **SECTION 16740 - TELEPHONE/DATA SYSTEMS**

3  
4 **GENERAL**

5  Overview

6 The telephone voice/data system **shall** consist of a main telecommunications room,  
7 telecommunications subclosets, service entrance conduits, main telephone/data distribution  
8 frame(MDF), intermediate distribution frames(IDF's), hub cabinets(HC's), local exchange  
9 carrier(LEC) demarcation, voice and data cross-connects and interconnecting hardware, voice  
10 and data backbone pathways and cables, voice and data horizontal pathways and cables, and  
11 telephone and/or data outlets(TCO's). The system **shall** have a 5 year warranty for material  
12 and labor.  
13

14  Industry Standards

15 The system **shall** in general comply with the requirements of EIA/TIA-568A (Commercial  
16 Building Standard for Telecommunications Wiring), EIA/TIA-569 (Commercial Building  
17 Standard for Telecommunications Pathways and Spaces), EIA/TIA-607 (Commercial Building  
18 Telecommunications Grounding/Bonding Requirements), EIA/TIA TSB 67 (Transmission  
19 Performance Specification for Field Testing of Unshielded Twisted-Pair Cabling Systems),  
20 and EIA/TIA TSB 72 (Centralized Optical Fiber Cabling Guidelines).  
21

22  System Configuration: The system **shall** be configured in a star topology.

23 1. Main Telecommunications Room (Location of LEC and MDF)

24 The MDF **will** be located in this room and **shall** consist of the required number 3/4"  
25 plywood backboards and 19" racks. The LEC **shall** provide service to the main  
26 telecommunications room for both voice and wide area network(WAN) services.  
27 LEC equipment **shall** be mounted on a dedicated section of the backboard. Central  
28 network switching equipment **will** be mounted in the racks. All fiber optic and  
29 copper terminating hardware **shall** be rack mounted. Main voice and data cross-  
30 connects **will** be made at the MDF. Interconnection between the LAN and the WAN  
31 **will** be made at the MDF.  
32

33 2. Telecommunications Subclosets (Location of IDF's)

34 Additional telecommunications subclosets **shall** be provided as required to insure that  
35 no TCO or HC requires a single run of cable from the closet in excess of 295 feet.  
36 IDF's **shall** consist of fiber and copper terminating hardware. All fiber optic cables  
37 **shall** be terminated in wall mounted fiber distribution enclosures(FDE's) mounted  
38 directly to wall. All copper cables **shall** be terminated on patch panels attached  
39 directly to wall.  
40

41 Services **shall** be provided for each type of area as outlined in the following sections.  
42 Other special type areas may arise on a particular project and **will** be addressed  
43 individually during the design process. Refer to Attachments 16740-1A and 16740-  
44 1B.

45  General Purpose Classrooms, Computer Labs/Classrooms, Business Labs with Computers,  
46 Science Classrooms and Modular Classrooms:

47  **shall** contain a cabinet (Hub Cabinet - HC) for housing electronic switching  
48 equipment such as Ethernet hubs. Refer to Attachment 16740-2 for HC details.  
49 Hub cabinets **shall** be mounted 36" AFF to center of cabinet whenever possible.

50  **shall** have two strands of fiber extended back to the MDF. The fiber **will** extend  
51 directly back to the MDF in a single cable when the classroom is located in the  
52 area of the MDF. When the classroom is located in the area of an IDF the 2

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
**DESIGN GUIDELINES**  
March, 1999

- 1 strand fiber cable **will** terminate at a FDE at the IDF and be extended in a  
2 multiple strand fiber distribution cable on to the MDF.
- 3  **shall** contain multiple TCO's for data as required by the school program. TCO's  
4 **shall** contain an 8-position modular female connector per port. Each port **shall**  
5 have a 4 pair cat.5 cable extended to the HC. The cables in the HC **shall** be  
6 terminated on 8-position modular male plugs.
- 7  **shall** contain one(1) 2-port TCO for the teacher for voice/data. The data port  
8 of the TCO **shall** be extended to the HC just like the data TCO's above. The  
9 voice port of the TCO **shall** have a 4 pair cat. 5 cable extended back to the MDF  
10 or an IDF, if applicable. Voice cables terminated at an IDF **will** be cross-  
11 connected with patch cords to a voice distribution cable which in turn extends to  
12 the MDF.
- 13
- 14  Typical Mechanical Room, Pay Phone Location or other Phone Only Location:
- 15  **shall** contain one(1) 1-port outlet for voice. The voice port **shall** have a 4  
16 pair cat. 5 cable extended back to the MDF or an IDF, as applicable. Voice cables  
17 terminated at an IDF **will** be cross-connected with patch cords to a voice  
18 distribution cable which in turn extends to the MDF.
- 19
- 20  Typical Outlets in All Other Areas:
- 21  **shall** contain one (1) or more 2-port TCO's for voice/data. There are two (2)  
22 types of TCO's. One (1) type contains both 8-position modular female  
23 connectors for voice and data. The other type of TCO contains one (1) 8-  
24 position modular female connector for voice and one (1) ST fiber optic  
25 connector for data. The copper only TCO's are used for outlets that terminate  
26 at the MDF. The copper/fiber TCO's are used for outlets that terminate at  
27 IDF's. Voice cables terminated at an IDF **will** be cross-connected with patch  
28 cords to a voice distribution cable which in turn extends to the MDF. Data cables  
29 terminated at an IDF **will** be cross-connected to a fiber distribution cable and  
30 extended to the MDF.
- 31

32 **DESIGN CRITERIA**

- 33  The main telecommunications room for the MDF should be ideally located near both the  
34 administrative area and the media center.
- 35  This room **shall** be dedicated to the functions outlined below.
- 36  The room should be sized to accommodate:
- 37 - the LEC demarcation
- 38 - 19 in. racks for terminating all backbone cables
- 39 - individual outlet cables
- 40 - all electronic equipment, and accessories including rack mounted power strips and  
41 cable management hardware
- 42 - the public address system controller (refer to other section of Design Guidelines for  
43 system requirements)
- 44 - the security system control panel (refer to other section of Design Guidelines for  
45 system requirements)
- 46 - the MATV headend unit(refer to other section of Design Guidelines for system  
47 requirements)
- 48 - the energy management system Global Control Module (coordinate this with the  
49 mechanical engineer).
- 50
- 51  Subclosets for IDF's should be strategically located in each major area of a building.

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
6 May 1992

- 1 These subclosets may be incorporated as space in non-plenum mechanical and/or  
2 electrical rooms.
- 3  All above telecommunications rooms **shall** be provided with dedicated electrical power  
4 circuits as required to meet equipment loads.
  - 5  Provide multiple outlets located about the space for convenience. Specify power strips  
6 with NEMA 5-20R receptacles for 19 in. racks.
  - 7  Provide individual split DX cooling system for main telecommunications room.
  - 8  The system **shall** be designed with surge suppression on all copper distribution cables  
9 from building-to-building and all horizontal voice cables from building-to-modular  
10 classroom.
  - 11  Provide protection on both ends of cables where entering buildings. Protection **shall**  
12 comply with NEC 800.
  - 13  Drawing requirements: The drawings **shall** contain as a minimum the following:
    - 14 - all TCO's shown on plans.
    - 15 - all HC's in classrooms shown on plans.
    - 16 - MDF and IDF's shown on plans. Use enlarged plans where necessary for clarity.
    - 17 - all routing of raceways shown where required to be exposed in existing buildings.
    - 18 - all TCO's scheduled showing room numbers, number of ports, termination point  
19 (IEMDF or IDF #), type of cabling, and number of cables.
    - 20 - a riser diagram showing the LEC Demarcation, the MDF, each IDF, and all  
21 distribution/backbone cables and also showing a typical arrangement for each type  
22 of station/outlet or hub cabinet connection.
    - 23 - details of racks, cabinets, and outlets.

24  
25 **PRODUCTS**

- 26  The telephone backboards **shall** be 4 ft. x 8 ft. x 3/4 in. minimum, painted on both sides  
27 with fire-resistant paint.
- 28  All copper TCO's **shall** be EIA/TIA 568 Type B configuration and category 5  
29 compliant. TCO's designated as two (2) port for voice and data **shall** consist of two (2)  
30 8-position modular jacks mounted in a single gang box with stainless coverplate. See  
31 Attachments 16740-3A through E for labeling details.
- 32  All fiber optic connections **shall** be type ST.
- 33  Cables intended for voice **shall** have different colored sheaths than cables intended for  
34 data.
- 35  All racks **shall** be 19 in. with EIA standard hole configurations. Use floor mounted  
36 racks for MDF.
- 37  All copper station cables **shall** be category 5 compliant.
- 38  All copper distribution cables **shall** be category 5 compliant when available for  
39 application.
- 40  All fiber optical cable **shall** be 62.5/125 micrometer multimode type cable.
- 41  The above cable types **shall** be general, riser, or plenum rated as required in accordance  
42 with the NEC and **shall** be UL listed.
- 43  Distribution cables **shall** be suitable for use( indoor, outdoor, distribution type, breakout  
44 type, etc.). Use of tight-buffered indoor/outdoor cable is preferred for exterior  
45 applications.
- 46  All copper cables **shall** be terminated on patch panels located in racks (at MDF) or wall  
47 brackets (at IDF's).
- 48  Patch panels **shall** match cables regarding category classification.
- 49  All fiber optic cables **shall** be terminated on fiber optic interconnection units located in  
50 racks at the MDF and terminated in FDE's at IDF's.

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
DESIGN GUIDELINES  
March, 1999

- 1  Surge protection **shall** be Lucent Technologies 110ANA1-25 Multipair Protector Panels  
2 or approved equal.  
3

4 **EXECUTION**

- 5  Provide a minimum of 120% of the required strands for fiber optic and pairs for copper  
6 distribution cables.  
7  Install a #6 copper ground wire from the main building ground to the MDF. Install a #6  
8 copper ground wire from the MDF to each IDF.  
9  Install #6 copper ground wire from MDF and each IDF to the building steel, if applicable.  
10  Use a grounding bus bar mounted to the plywood backboard at the MDF and at each IDF  
11 to make all grounding connections.  
12  Install all cables in raceway within walls and inaccessible spaces.  
13  Use nylon bushings at top of conduit where stubbed into accessible ceiling spaces.  
14  Support all cables in accessible ceilings with cable tray or "J" type hooks where cable tray  
15 is not available. Cables **shall** be supported directly by the building structure.  
16  Route all cables underground between buildings. All fiber optic cable **shall** be routed in  
17 raceway everywhere except in cable tray. Use of listed optical fiber raceway is preferred  
18 in concealed spaces. Maintain proper bending radius for fiber optic cables.  
19  Copper distribution cables **shall** be punched down in a 1 pair per port configuration. The  
20 cable **shall** be terminated on the WHT/BLU and BLU/WHT 110 connectors at patch  
21 panels. This corresponds to pair #1. Install surge suppressors as required by the NEC.  
22  Specify labeling of all system components in accordance with Wake County Public  
23 School System - Technology Department and all applicable industry standards. Refer to  
24 attached figures 16740-3A through E. All labeling **shall** be approved by the school  
25 system prior to installation.  
26  Provide testing in accordance with industry standards.  
27  
28  
29


**END OF SECTION**

**BEST COPY AVAILABLE**

1  
 2  
 3  
 4  
 5  
 6  
 7  
 8

**ATTACHMENT 16740-1A - MDF CABLE SCHEDULE**

PER PORT  
 PER PORT  
 HUB CABINET  
 VOICE DISTRIBUTION  
 DATA DISTRIBUTION




NOTE: DRAWING NOT TO SCALE

BEST COPY AVAILABLE

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
**DESIGN GUIDELINES**  
 March, 1999

1  
 2 ATTACHMENT 16740-1B - IDF CABLE SCHEDULE

N  
 FOR DATA PER PORT  
 FOR VOICE PER PORT  
 DATA TO EACH HIIB CABINET



□□□□ □□□□□□ □□□□□□ □□□□□□ □□□□□□  
DESIGN GUIDELINES  
□ □□□ □□□□

- ATTACHMENT 16740-2 - HUB CABINET DETAIL
- 

NOTES (HUB CABINET):

1. CABINET SHALL BE CONSTRUCTED FROM 16 GAUGE COLD ROLLED STEEL. HINGES SHALL BE FORMED STEEL TYPE OR EQUIVALENT AND SWING FROM SIDE OR BOTTOM. FRONT PANEL TO HAVE LOUVERS TO AID IN THE DISSIPATION OF HEAT. UNIT SHALL HAVE KEYLOCK DEVICE. ALL HUB CABINETS IN GROUP TO BE KEYED ALIKE. UNIT SHALL HAVE A POLYESTER POWDER ENAMEL, OR EQUIVALENT TYPE FINISH.
2. CABINET SHALL HAVE 1/2" PLYWOOD BACKBOARD TO MOUNT EQUIPMENT. CABINET TO CONTAIN FIBER RADIUS HOOPS FOR CABLE MANAGEMENT. CABINET SHALL HAVE SEALED RUBBER CABLE ENTRY GROMMETS WHERE REQUIRED. OWNER TO SUPPLY AND INSTALL HUB, FIBER TRANSCEIVER, POWER SUPPLY AND CAT. 5 CABLES TO WORKSTATIONS.
3. CONTRACTOR TO SUPPLY CABLE MANAGEMENT DEVICE AS SHOWN AND PROVIDE A MINIMUM OF 6' OF SLACK FIBER. CONTRACTOR TO TERMINATE FIBER WITH ST CONNECTORS.
4. CABINET SHALL BE MOUNTED TO WALL WITH FOUR (4) 1/4" BOLTS IN WALL ANCHORS. USE TOGGLE BOLTS FOR HOLLOW PARTITIONS AND LEAD ANCHORS FOR SOLID MASONRY WALLS. BOLTS SHALL PASS THROUGH THE 1/2" PLYWOOD CABINET BACKBOARD, THE CABINET AND INTO THE WALL ANCHOR.
5. CABLE SHALL BE ROUTED TO CABINET AS FOLLOWS:  
NEW CONSTRUCTION: 3/4" EMT ROUGHED IN WALL TO A SINGLE GANG OUTLET BOX. CABINET SHALL HAVE A 1-1/2" DIA. OPENING IN BACK AND BE MOUNTED DIRECTLY OVER OUTLET BOX.  
EXISTING WALL - HOLLOW PARTITION: CABINET SHALL HAVE A 1-1/2" DIA. OPENING IN BACK AND BE MOUNTED DIRECTLY OVER A 1-1/2" DIA. OPENING IN WALL. CABLE TO BE ROUTED IN WALL AS STATED IN SPECIFICATIONS.  
EXISTING WALL - SURFACE MOUNT: ROUTE CABLE DOWN WALL IN SURFACE METAL RACEWAY MECHANICALLY FASTENED TO WALL INTO TOP OF CABINET. USE A SURFACE METAL RACEWAY TYPE  
-----



□□□ □□□□□□□□ □□□□□□  
NOT TO SCALE

1 ATTACHMENT 16740-3A - DESCRIPTION OF TELEPHONE/DATA SYSTEM

LABEL EACH BACKBONE(DISTRIBUTION) COPPER CABLE AS FOLLOWS:

LABEL DISTRIBUTION PATCH PANEL AT IDF - "FEEDER CABLE TO X  
-RMAAA"

WHERE X IS THE 'MDF' OR 'DEMARC' AS APPLICABLE.

AAA IS THE TELECOM CLOSET/ROOM NUMBER WHERE THE MDF  
OR DEMARC IS LOCATED.

LABEL DISTRIBUTION PATCH PANEL AT DEMARC OR MDF - "FEEDER  
CABLE TO IDF - R1 AAA".

WHERE AAA IS THE TELECOM CLOSET/ROOM NUMBER WHERE  
THE IDF IS LOCATED.

JACK NUMBERS SHALL MATCH EXACTLY AT BOTH ENDS OF ALL  
COPPER DISTRIBUTION CABLES.


LABEL BACKBONE (DISTRIBUTION) FIBER CABLES AS FOLLOWS:  
AT THE MDF LABEL ALL FIBER CONNECTOR PAIRS SEQUENTIALLY  
FROM LEFT TO RIGHT FROM TOP TO BOTTOM. CARRY THIS NUMBER  
ALL THE WAY TO THE HUB CABINET OR FIBER OUTLET. NUMBER SHALL  
MATCH AT ALL INTERMEDIATE IDF'S OR FDE'S. TAG CABLE AT ALL  
CONNECTIONS, IDENTIFY DISTRIBUTION SIDE AT ALL IDF'S AND FDE'S  
WITH - "FEEDER CABLE TO MDF - ROOM AAA".

WHERE AAA IS THE TELECOM CLOSET/ROOM NUMBER, WHERE  
THE MDF IS LOCATED, IDENTIFY FEEDER DISTRIBUTION AT MDF WITH -  
"FEEDER CABLE TO X - ROOM AAA".

WHERE X IS 'FDE' OR 'IDF' AS APPLICABLE, AAA IS  
THE TELECOM CLOSET/ROOM NUMBER, WHERE THE MDF IS LOCATED.

BEST COPY AVAILABLE

- 1 LABELING
- 2 ATTACHMENT 16740-3B – TYPICAL LABELING ON HUB CABINET W/ COPPER
- 3 OUTLETS



ATTACHMENT 16740-3E – HUB CABINET FEEDS AND FIBER OUTLETS

NOTE:


WAKE COUNTY PUBLIC SCHOOL SYSTEM  
 DESIGN GUIDELINES  
 March, 1999

ATTACHMENT 16740-3E - TYPICAL MDF OR IDF RACK ELEVATION

SECTION

TYPICAL FIBER OPTIC  
 RACK - MOUNT CABINETS  
 (SIZE AND NUMBER AS  
 REQUIRED)

TYPICAL COPPER PATCH  
 PANELS (SIZE AND NUMBER  
 AS REQUIRED)




NOTE: DRAWING NOT TO SCALE EMS

BEST COPY AVAILABLE

5 GENERAL

WAKE COUNTY PUBLIC SCHOOL SYSTEM  
 DESIGN GUIDELINES  
 March, 1999

ATTACHMENT 16780-A - STANDRD CABLE TV DIAGRAM



3 GANG BOX WITH THREE F81 CONNECTORS IN FLUSH MOUNTED PLATE



GANG BOX WITH TWO F81 CONNECTORS

NOTE: DRAWING NOT TO SCALE

STEMS

BEST COPY AVAILABLE



**U.S. Department of Education**  
Office of Educational Research and Improvement (OERI)  
National Library of Education (NLE)  
Educational Resources Information Center (ERIC)



**REPRODUCTION RELEASE**  
(Specific Document)

**I. DOCUMENT IDENTIFICATION:**

Title: Wake County Public School System Design Guidelines	
Author(s):	
Corporate Source: Wake County Public School System	Publication Date: March, 1999

**II. REPRODUCTION RELEASE:**

In order to disseminate as widely as possible timely and significant materials of interest to the educational community, documents announced in the monthly abstract journal of the ERIC system, *Resources in Education* (RIE), are usually made available to users in microfiche, reproduced paper copy, and electronic media, and sold through the ERIC Document Reproduction Service (EDRS). Credit is given to the source of each document, and, if reproduction release is granted, one of the following notices is affixed to the document.

If permission is granted to reproduce and disseminate the identified document, please CHECK ONE of the following three options and sign at the bottom of the page.

The sample sticker shown below will be affixed to all Level 1 documents

PERMISSION TO REPRODUCE AND DISSEMINATE THIS MATERIAL HAS BEEN GRANTED BY

\_\_\_\_\_

Sample

\_\_\_\_\_

TO THE EDUCATIONAL RESOURCES INFORMATION CENTER (ERIC)

**1**

Level 1



Check here for Level 1 release, permitting reproduction and dissemination in microfiche or other ERIC archival media (e.g., electronic) and paper copy.

The sample sticker shown below will be affixed to all Level 2A documents

PERMISSION TO REPRODUCE AND DISSEMINATE THIS MATERIAL IN MICROFICHE, AND IN ELECTRONIC MEDIA FOR ERIC COLLECTION SUBSCRIBERS ONLY, HAS BEEN GRANTED BY

\_\_\_\_\_

Sample

\_\_\_\_\_

TO THE EDUCATIONAL RESOURCES INFORMATION CENTER (ERIC)

**2A**

Level 2A



Check here for Level 2A release, permitting reproduction and dissemination in microfiche and in electronic media for ERIC archival collection subscribers only

The sample sticker shown below will be affixed to all Level 2B documents

PERMISSION TO REPRODUCE AND DISSEMINATE THIS MATERIAL IN MICROFICHE ONLY HAS BEEN GRANTED BY

\_\_\_\_\_

Sample

\_\_\_\_\_

TO THE EDUCATIONAL RESOURCES INFORMATION CENTER (ERIC)

**2B**

Level 2B



Check here for Level 2B release, permitting reproduction and dissemination in microfiche only

Documents will be processed as indicated provided reproduction quality permits.  
If permission to reproduce is granted, but no box is checked, documents will be processed at Level 1.

*I hereby grant to the Educational Resources Information Center (ERIC) nonexclusive permission to reproduce and disseminate this document as indicated above. Reproduction from the ERIC microfiche or electronic media by persons other than ERIC employees and its system contractors requires permission from the copyright holder. Exception is made for non-profit reproduction by libraries and other service agencies to satisfy information needs of educators in response to discrete inquiries.*

**Sign here, →**  
release

Signature: <i>Christina Lighthall</i>	Printed Name/Position/Title: <b>CHRISTINA LIGHTHALL, SR. DIR FACILITIES</b>	
Organization/Address: <i>Wake County Public School System 1551 ROCK QUARRY RD RALEIGH NC 27610</i>	Telephone: <i>919 856 8274</i>	FAX: <i>919-664-5604</i>
	E-Mail Address: <i>clighthall@wcpss.net</i>	Date: <i>3/3/00</i>



### III. DOCUMENT AVAILABILITY INFORMATION (FROM NON-ERIC SOURCE):

If permission to reproduce is not granted to ERIC, or, if you wish ERIC to cite the availability of the document from another source, please provide the following information regarding the availability of the document. (ERIC will not announce a document unless it is publicly available, and a dependable source can be specified. Contributors should also be aware that ERIC selection criteria are significantly more stringent for documents that cannot be made available through EDRS.)

Publisher/Distributor:
Address:
Price:

### IV. REFERRAL OF ERIC TO COPYRIGHT/REPRODUCTION RIGHTS HOLDER:

If the right to grant this reproduction release is held by someone other than the addressee, please provide the appropriate name and address:

Name:
Address:

### V. WHERE TO SEND THIS FORM:

Send this form to the following ERIC Clearinghouse:	<b>National Clearinghouse for Educational Facilities National Institute of Building Sciences 1090 Vermont Ave., N.W., Suite 700 Washington, DC 20005-4905</b>
---	---

However, if solicited by the ERIC Facility, or if making an unsolicited contribution to ERIC, return this form (and the document being contributed) to:

**ERIC Processing and Reference Facility  
1100 West Street, 2<sup>nd</sup> Floor  
Laurel, Maryland 20707-3598**

Telephone: 301-497-4080

Toll Free: 800-799-3742

FAX: 301-953-0263

e-mail: [ericfac@inet.ed.gov](mailto:ericfac@inet.ed.gov)

WWW: <http://ericfac.piccard.csc.com>

EFF-088 (Rev. 9/97)